

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B1 : Preliminary Construction Programme

| No. Activity Description | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
|--|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|-----|-----|--|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | |
| I Existing Buildings ^[1] | | | | | | | | | | | | | | | | | | | | | |
| 1 Phase 1 & Site Wide Structure | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | | | | | | | | | | |
| II New Building ^[2] | | | | | | | | | | | | | | | | | | | | | |
| 2 Foundation | Y | Y | Y | Y | Y | Y | Y | | | | | | | | | | | | | | |
| 3 Excavation and Lateral Support (ELS) | | | | | | | | | Y | Y | Y | Y | Y | Y | | | | | | | |
| 4 Basement / Superstructure Construction | | | | | | | | | | | | | | Y | Y | Y | Y | Y | Y | Y | |

Notes:

- [1] Phases 2 to 4 are A&A works for existing buildings mainly under indoor environment with minimal noise impact and therefore is not included in the construction noise impact assessment.
- [2] Noise impact from curtain wall installation and fitting out works for the new buildings are expected to be minimal and therefore is not included in the construction noise impact assessment.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-1 : Construction Plant Inventory - Unmitigated

| No. Activities | Plant | TM / EPD ^[1] / BS 5228 ref. | No. of PME | On- time % | Unit SWL, dB(A) | SWL, dB(A) | Total SWL, dB(A) ^[2] |
|---|---|---|---------------|--|--------------------|---------------|---------------------------------------|
| I) Existing Buildings | | | | | | | |
| 1 Phase 1 & Site Wide Structure | | | | Sub-total SWL for Phase 1 & Site Wide Structure = 121 | | | |
| Demolition | | | | | | | |
| | Breaker, hand-held, mass < 10kg | CNP 023 | 4 | 50% | 108 | 111 | 121 |
| | Breaker, excavator mounted (pneumatic) | CNP 027 | 1 | 75% | 122 | 121 | |
| | Dump truck, 5.5 tonne < gross vehicle weight < 38 tonne | CNP 068 | 2 | 50% | 105 | 105 | |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | |
| Excavation and Lateral Support (ELS) | | | | | | | |
| | Excavator/loader, wheeled/tracked | CNP 081 | 2 | 75% | 112 | 114 | 118 |
| | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | 110 | 112 | |
| | Air Compressor, air flow > 30m ³ /min | CNP 003 | 2 | 75% | 104 | 106 | |
| | Water pump (electric) | CNP 281 | 3 | 50% | 88 | 90 | |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | |
| | Compactor, vibratory | CNP 050 | 2 | 50% | 105 | 105 | |
| | Crane, mobile/barge mounted (diesel) | CNP 048 | 2 | 50% | 112 | 112 | |
| | Grout mixer | EPD/PME/14 | 1 | 75% | 90 | 89 | |
| | Grout pump | EPD/PME/15 | 1 | 75% | 105 | 104 | |
| II) New Building | | | | | | | |
| 2 Foundation | | | | Sub-total SWL for Foundation = 120 | | | |
| Piling | | | | | | | |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | 116 |
| | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | 110 | 112 | |
| | Air Compressor, air flow > 30m ³ /min | CNP 003 | 2 | 75% | 104 | 106 | |
| | Grout mixer | EPD/PME/14 | 1 | 75% | 90 | 89 | |
| | Grout pump | EPD/PME/15 | 1 | 75% | 105 | 104 | |
| | Crane, mobile/barge mounted (diesel) | CNP 048 | 2 | 50% | 112 | 112 | |
| | Crane, tower (electric) | CNP 049 | 1 | 75% | 95 | 94 | |
| CAP | | | | | | | |
| | Excavator/loader, wheeled/tracked | CNP 081 | 2 | 75% | 112 | 114 | 120 |
| | Saw, circular, wood | CNP 201 | 2 | 50% | 108 | 108 | |
| | Bar bender and cutter (electric) | CNP 021 | 2 | 75% | 90 | 92 | |
| | Breaker, hand-held, mass > 20kg and < 35kg | CNP 025 | 1 | 50% | 111 | 108 | |
| | Concrete lorry mixer | CNP 044 | 2 | 50% | 109 | 109 | |
| | Concrete pump, stationary/lorry mounted | CNP 047 | 2 | 50% | 109 | 109 | |
| | Poker, vibratory, hand-held | CNP 170 | 4 | 50% | 113 | 116 | |
| | Compactor, vibratory | CNP 050 | 2 | 40% | 105 | 104 | |
| | Water pump (electric) | CNP 281 | 2 | 50% | 88 | 88 | |
| | Air Compressor, air flow > 30m ³ /min | CNP 003 | 1 | 75% | 104 | 103 | |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | |
| | Crane, tower (electric) | CNP 049 | 1 | 75% | 95 | 94 | |
| | Crane, mobile/barge mounted (diesel) | CNP 048 | 1 | 50% | 112 | 109 | |
| | Dump truck, 5.5 tonne < gross vehicle weight < 38 tonne | CNP 068 | 1 | 50% | 105 | 102 | |

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-1 : Construction Plant Inventory - Unmitigated

| No. | Activities | Plant | TM / EPD ^[1] / BS 5228 ref. | No. of PME | On- time % | Unit SWL, dB(A) | SWL, dB(A) | Total SWL, dB(A) ^[2] |
|---|------------|---|---|---------------|---------------|--------------------|--|---------------------------------------|
| 3 Excavation and Lateral Support (ELS) | | | | | | | Sub-total SWL for ELS = 118 | |
| | | Excavator/loader, wheeled/tracked | CNP 081 | 2 | 75% | 112 | 114 | 118 |
| | | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | 110 | 112 | |
| | | Air Compressor, air flow > 30m ³ /min | CNP 003 | 2 | 75% | 104 | 106 | |
| | | Water pump (electric) | CNP 281 | 3 | 50% | 88 | 90 | |
| | | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | |
| | | Compactor, vibratory | CNP 050 | 2 | 50% | 105 | 105 | |
| | | Crane, mobile/barge mounted (diesel) | CNP 048 | 2 | 50% | 112 | 112 | |
| | | Grout mixer | EPD/PME/14 | 1 | 75% | 90 | 89 | |
| | | Grout pump | EPD/PME/15 | 1 | 75% | 105 | 104 | |
| 4 Basement / Superstructure Construction | | | | | | | Sub-total SWL for Basement / Superstructure Works = 120 | |
| | | Excavator/loader, wheeled/tracked | CNP 081 | 2 | 75% | 112 | 114 | 120 |
| | | Saw, circular, wood | CNP 201 | 2 | 50% | 108 | 108 | |
| | | Bar bender and cutter (electric) | CNP 021 | 2 | 75% | 90 | 92 | |
| | | Breaker, hand-held, mass > 20kg and < 35kg | CNP 025 | 1 | 50% | 111 | 108 | |
| | | Concrete lorry mixer | CNP 044 | 2 | 50% | 109 | 109 | |
| | | Concrete pump, stationary/lorry mounted | CNP 047 | 2 | 50% | 109 | 109 | |
| | | Poker, vibratory, hand-held | CNP 170 | 4 | 50% | 113 | 116 | |
| | | Compactor, vibratory | CNP 050 | 2 | 40% | 105 | 104 | |
| | | Water pump (electric) | CNP 281 | 2 | 50% | 88 | 88 | |
| | | Air Compressor, air flow > 30m ³ /min | CNP 003 | 1 | 75% | 104 | 103 | |
| | | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | 95 | 95 | |
| | | Crane, tower (electric) | CNP 049 | 1 | 75% | 95 | 94 | |
| | | Crane, mobile/barge mounted (diesel) | CNP 048 | 1 | 50% | 112 | 109 | |
| | | Dump truck, 5.5 tonne < gross vehicle weight < 38 tonne | CNP 068 | 1 | 50% | 105 | 102 | |

Notes:

- [1] SWLs of EPD/PME items refer to the document prepared by the Noise Control Authority (http://www.epd.gov.hk/epd/english/application_for_licences/guidance/files/OtherSWLe.pdf)
BS - British Standard BS 5228:2009, Part 1 Noise and Vibration Control on Construction and Open Sites
- [2] The figures are rounded-up to a whole number.

Annex B2-2 : Summary of Predicted Noise Levels during Daytime Period - Unmitigated

| | NSR Location | EIAO-TM Noise Criteria, dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | | | Max. CNL, dB(A) | | |
|----|---|-------------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|-----------------------|-----|-----|
| | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | May | Jun | | Jul | Aug |
| N1 | Amber Lodge | 75 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 85 | 85 | 85 | 79 | 79 | 79 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 86 |
| N2 | Ho Fook Building | 75 | 87 | 87 | 87 | 87 | 87 | 87 | 87 | 86 | 86 | 86 | 80 | 80 | 80 | 82 | 82 | 82 | 82 | 82 | 82 | 82 | 87 |
| N3 | Old Bailey Street Police Married Quarters | 75 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 85 | 85 | 85 | 81 | 81 | 81 | 83 | 83 | 83 | 83 | 83 | 83 | 83 | 86 |
| N4 | Cambridge Villa | 75 | 87 | 87 | 87 | 87 | 87 | 87 | 87 | 86 | 86 | 86 | 84 | 84 | 84 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 87 |
| N5 | Chancery House | 75 | 89 | 89 | 89 | 89 | 89 | 89 | 89 | 87 | 87 | 87 | 86 | 86 | 86 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | 89 |
| N6 | Chancery Mansion | 75 | 89 | 89 | 89 | 89 | 89 | 89 | 89 | 87 | 87 | 87 | 86 | 86 | 86 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | 89 |

Note:

[1] **Bold** value indicates exceedance of noise criteria of 75 dB(A) for residential premises.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3a Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N1

Amber Lodge

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 44 | -41 | 3 | 84 | 84 | 84 | 84 | 84 | 84 | 84 | 84 | 84 | 84 | | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 50 | -42 | 3 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 50 | -42 | 3 | | | | | | | | 79 | 79 | 79 | 79 | 79 | | | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 50 | -42 | 3 | | | | | | | | | | | | | | 81 | 81 | 81 | 81 | 81 | 81 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 85 | 85 | 85 | 79 | 79 | 79 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 86 |

Notes:

[1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$

[2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3b Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N2

Ho Fook Building

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | Max. CNL dB(A) | | | | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|----------------------|-----|-----|-----|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | 2013 | | | | | | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | Jan | Feb | Mar | Apr | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 38 | -40 | 3 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | 85 | | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 46 | -41 | 3 | 82 | 82 | 82 | 82 | 82 | 82 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 46 | -41 | 3 | | | | | | | | 80 | 80 | 80 | 80 | 80 | 80 | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 46 | -41 | 3 | | | | | | | | | | | | | | 82 | 82 | 82 | 82 | 82 | 82 | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 87 | 87 | 87 | 87 | 87 | 87 | 87 | 86 | 86 | 86 | 80 | 80 | 80 | 82 | 82 | 82 | 82 | 82 | 82 | 87 |

Notes:

[1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$

[2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3c Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N3

Old Bailey Street Police Married Quarters

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 52 | -42 | 3 | 82 | 82 | 82 | 82 | 82 | 82 | 82 | 82 | 82 | 82 | | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 40 | -40 | 3 | 83 | 83 | 83 | 83 | 83 | 83 | 83 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 40 | -40 | 3 | | | | | | | | 81 | 81 | 81 | 81 | 81 | | | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 40 | -40 | 3 | | | | | | | | | | | | | | 83 | 83 | 83 | 83 | 83 | 83 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 85 | 85 | 85 | 81 | 81 | 81 | 83 | 83 | 83 | 83 | 83 | 83 | 83 | 86 |

Notes:

[1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$

[2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3d Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N4

Cambridge Villa

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | Max. CNL dB(A) | | | | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|----------------------|-----|-----|-----|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | 2013 | | | | | | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | Jan | Feb | Mar | Apr | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 57 | -43 | 3 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 30 | -37 | 3 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 30 | -37 | 3 | | | | | | | | 84 | 84 | 84 | 84 | 84 | 84 | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 30 | -37 | 3 | | | | | | | | | | | | | | 86 | 86 | 86 | 86 | 86 | 86 | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 87 | 87 | 87 | 87 | 87 | 87 | 87 | 86 | 86 | 86 | 84 | 84 | 84 | 86 | 86 | 86 | 86 | 86 | 86 | 86 |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3e Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N5

Chancery House

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | Max. CNL dB(A) | | | | | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|----------------------|-----|-----|-----|-----|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | 2013 | | | | | | | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 57 | -43 | 3 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | | | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 23 | -35 | 3 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 23 | -35 | 3 | | | | | | | | 86 | 86 | 86 | 86 | 86 | 86 | | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 23 | -35 | 3 | | | | | | | | | | | | | | 88 | 88 | 88 | 88 | 88 | 88 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 89 | 89 | 89 | 89 | 89 | 89 | 89 | 87 | 87 | 87 | 86 | 86 | 86 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | 89 |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B2-3f Construction Airborne Noise Impact Assessment - Unmitigated

NSR: N6

Chancery House

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | Max. CNL dB(A) | | | | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|-----|----------------------|-----|-----|-----|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | 2013 | | | | | | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | Jan | Feb | Mar | Apr | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 121 | 57 | -43 | 3 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 120 | 23 | -35 | 3 | 88 | 88 | 88 | 88 | 88 | 88 | 88 | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 118 | 23 | -35 | 3 | | | | | | | | 86 | 86 | 86 | 86 | 86 | 86 | | | | | | | |
| 4 | Basement / Superstructure Construction | 120 | 23 | -35 | 3 | | | | | | | | | | | | | | 88 | 88 | 88 | 88 | 88 | 88 | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 89 | 89 | 89 | 89 | 89 | 89 | 89 | 87 | 87 | 87 | 86 | 86 | 86 | 88 | 88 | 88 | 88 | 88 | 88 | 89 |

Notes:

[1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$

[2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-1 : Summary of Predicted Fixed Plant Noise Levels due to the Operation of the Proposed Development (During Day-time & Evening Time Periods)

| NSRs | | Predicted Fixed Plant Noise Level (dB(A)) | Predicted PA Noise Level (dB(A)) | Cumulative Predicted Noise Level (dB(A)) | Noise Criteria (dB(A)) |
|------|---|---|----------------------------------|--|---------------------------------|
| | | Day-time & Evening Time Periods | Day-time & Evening Time Periods | Day-time & Evening Time Periods | Day-time & Evening Time Periods |
| N1 | Amber Lodge | 42 | 53 | 53 | 59 |
| N2 | Ho Fook Building | 48 | 50 | 52 | 59 |
| N3 | Old Bailey Street Police Married Quarters | 49 | 55 | 56 | 59 |
| N4 | Cambridge Villa | 45 | 52 | 53 | 54 |
| N5 | Chancery House | 49 | 53 | 54 | 54 |
| N6 | Chancery Mansion | 50 | 51 | 54 | 54 |

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2a Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N1 Amber Lodge

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 148.0 | 5 | -51.4 | 3 | 0 | 28 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 148.0 | 5 | -51.4 | 3 | 0 | 28 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 155.5 | 5 | -51.8 | 3 | 0 | 36 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 164.0 | 5 | -52.3 | 3 | -10 | 20 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 107.0 | 0 | -48.6 | 3 | -10 | 28 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 90.0 | 3 | -47.1 | 3 | -10 | 24 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 90.0 | 6 | -47.1 | 3 | -10 | 27 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 38.0 | 0 | -39.6 | 3 | -10 | 38 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 66.0 | 0 | -44.4 | 3 | -10 | 34 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 42 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cow1 will be installed as appropriate to achieve the required SWL.

Annex B3-2a Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 41.0 | 0 | -40.2 | 3 | -10 | 44 |
| 2 | | | 91 | 1 | 61.0 | 0 | -43.7 | 3 | -10 | 40 |
| 3 | | | 91 | 1 | 66.0 | 0 | -44.4 | 3 | 0 | 50 |
| 4 | | | 91 | 1 | 81.0 | 0 | -46.2 | 3 | 0 | 48 |
| 5 | PA system | Upper courtyard | 86 | 1 | 122.0 | 0 | -49.7 | 3 | -10 | 29 |
| 6 | | | 86 | 1 | 138.0 | 0 | -50.8 | 3 | 0 | 38 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 53 |

Notes:

- [1] Correction for quantity = 10*log(Quantity)
- [2] Distance correction for SWL = -10*log(2π(d2)²)
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door
- [4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$SPL = Max\ SWL - DC + FC - BC$$

where

- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2b Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N2 Ho Fook Building

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 107.0 | 5 | -48.6 | 3 | -10 | 21 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 107.0 | 5 | -48.6 | 3 | -10 | 21 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 120.0 | 5 | -49.6 | 3 | -10 | 28 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 131.0 | 5 | -50.3 | 3 | -10 | 22 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 40.5 | 0 | -40.1 | 3 | -10 | 37 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 22.0 | 3 | -34.8 | 3 | 0 | 46 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 31.0 | 6 | -37.8 | 3 | -10 | 36 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 33.0 | 0 | -38.4 | 3 | -10 | 40 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 83.0 | 0 | -46.4 | 3 | -10 | 32 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 48 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.

Annex B3-2b Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 43.0 | 0 | -40.7 | 3 | -10 | 43 |
| 2 | | | 91 | 1 | 71.0 | 0 | -45.0 | 3 | -10 | 39 |
| 3 | | | 91 | 1 | 32.5 | 0 | -38.2 | 3 | -10 | 46 |
| 4 | | | 91 | 1 | 67.5 | 0 | -44.6 | 3 | -10 | 39 |
| 5 | PA system | Upper courtyard | 86 | 1 | 66.5 | 0 | -44.4 | 3 | -10 | 35 |
| 6 | | | 86 | 1 | 93.0 | 0 | -47.4 | 3 | 0 | 42 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 50 |

Notes:

[1] Correction for quantity = 10*log(Quantity)

[2] Distance correction for SWL = -10*log(2π(d2)²)

[3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door

[4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$SPL = Max\ SWL - DC + FC - BC$$

where

SPL Sound Pressure Level, in dB(A)

Max. SWL Maximum Allowable Sound Power Level, in dB(A)

DC Distance Attenuation, in dB(A)

FC Façade Correction, in dB(A) (i.e. 3 dB(A))

BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2c Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N3 Old Bailey Street Police Married Quarters

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 97.0 | 5 | -47.7 | 3 | 0 | 32 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 97.0 | 5 | -47.7 | 3 | 0 | 32 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 111.0 | 5 | -48.9 | 3 | 0 | 39 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 124.0 | 5 | -49.9 | 3 | -10 | 23 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 27.5 | 0 | -36.8 | 3 | -10 | 40 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 20.0 | 3 | -34.0 | 3 | 0 | 47 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 31.0 | 6 | -37.8 | 3 | -10 | 36 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 69.0 | 0 | -44.8 | 3 | -10 | 33 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 109.5 | 0 | -48.8 | 3 | -10 | 29 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 49 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.

Annex B3-2c Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 76.0 | 0 | -45.6 | 3 | 0 | 48 |
| 2 | | | 91 | 1 | 97.0 | 0 | -47.7 | 3 | 0 | 46 |
| 3 | | | 91 | 1 | 55.0 | 0 | -42.8 | 3 | 0 | 51 |
| 4 | | | 91 | 1 | 84.5 | 0 | -46.5 | 3 | 0 | 47 |
| 5 | PA system | Upper courtyard | 86 | 1 | 50.0 | 0 | -42.0 | 3 | -10 | 37 |
| 6 | | | 86 | 1 | 88.0 | 0 | -46.9 | 3 | 0 | 42 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 55 |

Notes:

- [1] Correction for quantity = 10*log(Quantity)
- [2] Distance correction for SWL = -10*log(2π(d2)²)
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door
- [4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$SPL = Max\ SWL - DC + FC - BC$$

where

- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2d Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N4 Cambridge Villa

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 64.0 | 5 | -44.1 | 3 | 0 | 36 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 64.0 | 5 | -44.1 | 3 | 0 | 36 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 77.0 | 5 | -45.7 | 3 | 0 | 42 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 90.0 | 5 | -47.1 | 3 | -10 | 26 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 43.0 | 0 | -40.7 | 3 | -10 | 36 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 64.0 | 3 | -44.1 | 3 | -10 | 27 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 60.5 | 6 | -43.6 | 3 | -10 | 30 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 112.0 | 0 | -49.0 | 3 | -10 | 29 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 129.0 | 0 | -50.2 | 3 | -10 | 28 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 45 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cow1 will be installed as appropriate to achieve the required SWL.

Annex B3-2d Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 112.0 | 0 | -49.0 | 3 | -10 | 35 |
| 2 | | | 91 | 1 | 118.0 | 0 | -49.4 | 3 | -10 | 35 |
| 3 | | | 91 | 1 | 84.5 | 0 | -46.5 | 3 | -10 | 37 |
| 4 | | | 91 | 1 | 96.0 | 0 | -47.6 | 3 | -10 | 36 |
| 5 | PA system | Upper courtyard | 86 | 1 | 34.0 | 0 | -38.6 | 3 | 0 | 50 |
| 6 | | | 86 | 1 | 60.0 | 0 | -43.5 | 3 | 0 | 45 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 52 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance correction for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door
- [4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$

where

- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2e Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N5 Chancery House

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 33.0 | 5 | -38.4 | 3 | 0 | 41 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 33.0 | 5 | -38.4 | 3 | 0 | 41 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 42.5 | 5 | -40.5 | 3 | 0 | 47 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 54.0 | 5 | -42.6 | 3 | -10 | 30 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 67.0 | 0 | -44.5 | 3 | -10 | 32 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 90.0 | 3 | -47.1 | 3 | -10 | 24 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 80.5 | 6 | -46.1 | 3 | -10 | 28 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 126.0 | 0 | -50.0 | 3 | -10 | 28 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 125.5 | 0 | -50.0 | 3 | -10 | 28 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 49 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.

Annex B3-2e Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 123.0 | 0 | -49.8 | 3 | -10 | 34 |
| 2 | | | 91 | 1 | 118.0 | 0 | -49.4 | 3 | -10 | 35 |
| 3 | | | 91 | 1 | 91.0 | 0 | -47.2 | 3 | -10 | 37 |
| 4 | | | 91 | 1 | 93.0 | 0 | -47.4 | 3 | -10 | 37 |
| 5 | PA system | Upper courtyard | 86 | 1 | 44.5 | 0 | -40.9 | 3 | 0 | 48 |
| 6 | | | 86 | 1 | 33.0 | 0 | -38.4 | 3 | 0 | 51 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 53 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance correction for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door
- [4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$

where

- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-2f Operational Noise Impact Assessment - Fixed Plant (During Day-time & Evening Time Periods)

NSR: N6 Chancery House

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|---|----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 3 | 33.0 | 5 | -38.4 | 3 | 0 | 41 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 3 | 33.0 | 5 | -38.4 | 3 | 0 | 41 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 3 | 35.0 | 5 | -38.9 | 3 | 0 | 49 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 3 | 40.0 | 5 | -40.0 | 3 | -10 | 33 |
| 5 | Genset | G/F plant room of Old Bailey Wing | 84 | 1 | 86.0 | 0 | -46.7 | 3 | -10 | 30 |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 109.0 | 3 | -48.7 | 3 | -10 | 22 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 95.0 | 6 | -47.5 | 3 | -10 | 26 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 143.0 | 0 | -51.1 | 3 | -10 | 27 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 134.0 | 0 | -50.5 | 3 | -10 | 27 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 50 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage.
The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable
- $$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cow1 will be installed as appropriate to achieve the required SWL.

Annex B3-2f Operational Noise Impact Assessment - PA system

| No. | Item | Location | Max. Allowable SPL, dB(A) ^[3] | Quantity | Maximum Distance from site boundary to NSR (d2),m ^[4] | Corrections For | | | | Predicted Noise Level (dB(A) L _{eq} 30min) |
|---|-----------|-----------------|--|----------|--|-------------------------------|-------------------------------|--------------|---------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) | |
| Day-time & Evening Time Periods (between 0700 to 2300 hours) | | | | | | | | | | |
| 1 | PA system | Lower courtyard | 91 | 1 | 135.0 | 0 | -50.6 | 3 | -10 | 33 |
| 2 | | | 91 | 1 | 126.0 | 0 | -50.0 | 3 | -10 | 34 |
| 3 | | | 91 | 1 | 111.0 | 0 | -48.9 | 3 | -10 | 35 |
| 4 | | | 91 | 1 | 100.0 | 0 | -48.0 | 3 | -10 | 36 |
| 5 | PA system | Upper courtyard | 86 | 1 | 62.0 | 0 | -43.8 | 3 | 0 | 45 |
| 6 | | | 86 | 1 | 40.0 | 0 | -40.0 | 3 | 0 | 49 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 51 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance correction for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door
- [4] Detailed design of the PA system is not yet available at this stage. The speaker clusters are expected to be operated during some special occasions during daytime and evening time periods only (until 23:00 hours).

The maximum allowable SWLs of the PA system were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SWLs:

$$\text{SPL} = \text{Max SWL} - \text{DC} + \text{FC} - \text{BC}$$

where

- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-3 : Summary of Predicted Fixed Plant Noise Levels due to the Operation of the Proposed Development (During Night-time Period)

| NSRs | Predicted Fixed Plant Noise Level (dB(A)) | Noise Criteria (dB(A)) |
|--|--|------------------------|
| | Night-time Period | Night-time Period |
| N1 Amber Lodge | 42 | 50 |
| N2 Ho Fook Building | 48 | 50 |
| N3 Old Bailey Street Police Married Quarters | 48 | 50 |
| N4 Cambridge Villa | 43 | 49 |
| N5 Chancery House | 48 | 49 |
| N6 Chancery Mansion | 49 | 49 |

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4a Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N1 Amber Lodge

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 148.0 | 3 | -51.4 | 3 | 0 | 27 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 148.0 | 3 | -51.4 | 3 | 0 | 27 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 155.5 | 3 | -51.8 | 3 | 0 | 34 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 164.0 | 3 | -52.3 | 3 | -10 | 19 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 90.0 | 3 | -47.1 | 3 | -10 | 24 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 90.0 | 6 | -47.1 | 3 | -10 | 27 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 38.0 | 0 | -39.6 | 3 | -10 | 38 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 66.0 | 0 | -44.4 | 3 | -10 | 34 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 41 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
 where
 SPL Sound Pressure Level, in dB(A)
 Max. SWL Maximum Allowable Sound Power Level, in dB(A)
 DC Distance Attenuation, in dB(A)
 FC Façade Correction, in dB(A) (i.e. 3 dB(A))
 BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4b Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N2 Ho Fook Building

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 107.0 | 3 | -48.6 | 3 | -10 | 19 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 107.0 | 3 | -48.6 | 3 | -10 | 19 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 120.0 | 3 | -49.6 | 3 | -10 | 26 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 131.0 | 3 | -50.3 | 3 | -10 | 21 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 22.0 | 3 | -34.8 | 3 | 0 | 46 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 31.0 | 6 | -37.8 | 3 | -10 | 36 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 33.0 | 0 | -38.4 | 3 | -10 | 40 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 83.0 | 0 | -46.4 | 3 | -10 | 32 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 48 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
 where
 SPL Sound Pressure Level, in dB(A)
 Max. SWL Maximum Allowable Sound Power Level, in dB(A)
 DC Distance Attenuation, in dB(A)
 FC Façade Correction, in dB(A) (i.e. 3 dB(A))
 BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4c Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N3 Old Bailey Street Police Married Quarters

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 97.0 | 3 | -47.7 | 3 | 0 | 30 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 97.0 | 3 | -47.7 | 3 | 0 | 30 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 111.0 | 3 | -48.9 | 3 | 0 | 37 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 124.0 | 3 | -49.9 | 3 | -10 | 21 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 20.0 | 3 | -34.0 | 3 | 0 | 47 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 31.0 | 6 | -37.8 | 3 | -10 | 36 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 69.0 | 0 | -44.8 | 3 | -10 | 33 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 109.5 | 0 | -48.8 | 3 | -10 | 29 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 48 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4d Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N4 Cambridge Villa

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 64.0 | 3 | -44.1 | 3 | 0 | 34 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 64.0 | 3 | -44.1 | 3 | 0 | 34 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 77.0 | 3 | -45.7 | 3 | 0 | 40 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 90.0 | 3 | -47.1 | 3 | -10 | 24 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 64.0 | 3 | -44.1 | 3 | -10 | 27 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 60.5 | 6 | -43.6 | 3 | -10 | 30 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 112.0 | 0 | -49.0 | 3 | -10 | 29 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 129.0 | 0 | -50.2 | 3 | -10 | 28 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 43 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
 where
 SPL Sound Pressure Level, in dB(A)
 Max. SWL Maximum Allowable Sound Power Level, in dB(A)
 DC Distance Attenuation, in dB(A)
 FC Façade Correction, in dB(A) (i.e. 3 dB(A))
 BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cow1 will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4e Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N5 Chancery House

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 33.0 | 3 | -38.4 | 3 | 0 | 40 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 33.0 | 3 | -38.4 | 3 | 0 | 40 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 42.5 | 3 | -40.5 | 3 | 0 | 45 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 54.0 | 3 | -42.6 | 3 | -10 | 28 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 90.0 | 3 | -47.1 | 3 | -10 | 24 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 80.5 | 6 | -46.1 | 3 | -10 | 28 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 126.0 | 0 | -50.0 | 3 | -10 | 28 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 125.5 | 0 | -50.0 | 3 | -10 | 28 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 48 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
- where
- SPL Sound Pressure Level, in dB(A)
- Max. SWL Maximum Allowable Sound Power Level, in dB(A)
- DC Distance Attenuation, in dB(A)
- FC Façade Correction, in dB(A) (i.e. 3 dB(A))
- BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B3-4f Operational Noise Impact Assessment - Fixed Plant (During Night-time Period)

NSR: N6 Chancery House

| No. | Item | Location | Max. Allowable SWL, dB(A) ^[5] | Quantity | Distance from source to NSR (d2),m | Corrections For | | | | Predicted Noise Level (dB(A) $L_{eq, 30min}$) ^[4] |
|--|-----------------------|---|--|----------|------------------------------------|-------------------------------|-------------------------------|--------------|------------------------------|---|
| | | | | | | Quantity dB(A) ^[1] | Distance dB(A) ^[2] | Façade dB(A) | Barrier dB(A) ^[3] | |
| Night-time Periods (between 2300 to 0700 hours) | | | | | | | | | | |
| 1 | Chilled Water Pumps | West louvre of chilled water pump room on the roof of Arbuthnot Wing | 72 | 2 | 33.0 | 3 | -38.4 | 3 | 0 | 40 |
| 2 | Condenser Water Pump | West louvre of condenser water pump room on the roof of Arbuthnot Wing | 72 | 2 | 33.0 | 3 | -38.4 | 3 | 0 | 40 |
| 3 | Cooling Tower | Cooling towers on the roof of Arbuthnot Wing | 80 | 2 | 35.0 | 3 | -38.9 | 3 | 0 | 47 |
| 4 | Chiller | East louvre of chiller room on the roof of Arbuthnot Wing | 75 | 2 | 40.0 | 3 | -40.0 | 3 | -10 | 31 |
| 5 | Genset ^[6] | G/F plant room of Old Bailey Wing | - | - | - | - | - | - | - | - |
| 6 | Transformer | West louvre of transformer room of Ablution Block | 75 | 2 | 109.0 | 3 | -48.7 | 3 | -10 | 22 |
| 7 | | South louvre of exhaust air duct for transformer room of Ablution Block | 75 | 4 | 95.0 | 6 | -47.5 | 3 | -10 | 26 |
| 8 | Fan | West louvre of Police Headquarters at lower courtyard | 85 | 1 | 143.0 | 0 | -51.1 | 3 | -10 | 27 |
| 9 | | East louvre of Police Headquarters at lower courtyard | 85 | 1 | 134.0 | 0 | -50.5 | 3 | -10 | 27 |
| Predicted Façade Noise Level (dB(A)) = | | | | | | | | | | 49 |

Notes:

- [1] Correction for quantity = $10 \cdot \log(\text{Quantity})$
- [2] Distance attenuation for SWL = $-10 \cdot \log(2\pi(d2)^2)$
- [3] Reference was made from IND-TM, a negative correction of 10dB(A) will be applied for noise source totally screened by barrier or building such that none will be visible when viewed from any window, door or other opening of the NSR.
- [4] Detailed design of the plant rooms is not yet available at this stage. Only 2 cooling towers, associated chillers, condensed water pumps and chilled water pumps are expected to be operated during the night-time period between 2300 and 0700 hours. Transformer and fan are expected to be operated for 24 hours daily.
- The maximum allowable SWLs of the plant room louvers/equipment were determined by adopting standard acoustics principles. The following formula was used for calculating the maximum allowable SPL = Max SWL – DC + FC - BC
 where
 SPL Sound Pressure Level, in dB(A)
 Max. SWL Maximum Allowable Sound Power Level, in dB(A)
 DC Distance Attenuation, in dB(A)
 FC Façade Correction, in dB(A) (i.e. 3 dB(A))
 BC Barrier Correction, in dB(A)
- [5] The sound power level (SWL) of the equipment shall not exceed the specified Maximum Allowable SWL in order to archive the noise criteria. Acoustic treatment, such as intake & discharge silencers, acoustic enclosure, acoustic louver and discharge cowl will be installed as appropriate to achieve the required SWL.
- [6] Genset will be only operated during the day-time and evening time period.

Key

- Representative Noise Sensitive Receiver
- Project Site
- Louvres of Plant Rooms
- PA System
- Cooling Towers

| NSR | Description |
|-----|---|
| N1 | Amber Lodge |
| N2 | Ho Fook Building |
| N3 | Old Bailey Street Police Married Quarters |
| N4 | Cambridge Villa |
| N5 | Chancery House |
| N6 | Chancery Mansion |

| Building Index | |
|----------------|--|
| 01 | Police Headquarters |
| 02 | Armoury |
| 03 | Barrack Block |
| 04 | Married Inspector's Quarters and Deputy Superin Tendents House |
| 06 | Married Sergeants' Quarters |
| 07 | Single Inspectors' Quarters |
| 08 | Ablutions Block |
| 09 | Central Magistracy |
| 10 | Superintendent's House |
| 11 | A Hall |
| 12 | B Hall |
| 13 | C Hall |
| 14 | D Hall |
| 15 | E Hall |
| 17 | F Hall |
| 19 | Bauhinia House |
| OBW | Old Bailey Wing |
| AW | Arbuthnot Wing |




Figure B3-1

Locations of Fixed Plant Noise Sources

File: 0095646_fixed plant noise sources.mxd
Date: 19/11/210

Environmental Resources Management

賽馬會文物保育有限公司
The Jockey Club CPS Limited






Figure B3-2

Roof Layout Plan of Arbutnot Wing

FILE: 00956461
DATE: 19/11/2010

Environmental
Resources
Management



賽馬會文物保育有限公司
The Jockey Club CPS Limited

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-1 : Construction Plant Inventory - Mitigated

| No. | Activities Plant | TM / EPD ^[1] / BS 5228 ref. | No. of PME | On- time % | Type of Noise Control (Barrier/Enclosure) ^[3] | Noise reduction, dB(A) | Unit SWL, dB(A) | SWL, dB(A) | Total SWL, dB(A) ^[2] | Groups ^[4] |
|--|--|---|---------------|---------------|---|------------------------------|-----------------------|---------------|---------------------------------------|-----------------------|
| I) Existing Buildings | | | | | | | | | | |
| 1 Phase 1 & Site Wide Structure | | | | | | | | | | |
| Sub-total SWL for Phase 1 & Site Wide Structure = 107 | | | | | | | | | | |
| Demolition | | | | | | | | | | |
| | Breaker, hand-held, mass < 10kg | CNP 023 | 4 | 50% | Noise Barrier | -5 | 108 | 106 | 107 | A 107 |
| | Hydraulic breaker, excavator mounted | BS D8 12 | 1 | 75% | Noise Barrier | -5 | 106 | 100 | | A |
| | Dump truck | BS D9 39 | 2 | 50% | | | 103 | 103 | | B 103 |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | | A |
| Excavation and Lateral Support (ELS) | | | | | | | | | | |
| | Tracked Excavator/loader | BS D3 97 | 2 | 75% | Noise Barrier | -5 | 105 | 102 | 106 | A 106 |
| | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | Noise Insulation Sheet | -10 | 110 | 102 | | A |
| | Air Compressor, air flow > 30m3/min | CNP 003 | 2 | 75% | Enclosure | -10 | 104 | 96 | | A |
| | Water pump (electric) | CNP 281 | 3 | 50% | | | 88 | 90 | | A |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | | A |
| | Compactor, vibratory | CNP 050 | 2 | 50% | | | 105 | 105 | | B 105 |
| | Mobile crane (62kW) | BS D7 114 | 2 | 50% | | | 101 | 101 | | C 102 |
| | Grout mixer | EPD/PME/14 | 1 | 75% | Noise Barrier | -10 | 90 | 79 | | C |
| | Grout pump | EPD/PME/15 | 1 | 75% | Noise Barrier | -10 | 105 | 94 | | C |
| II) New Building | | | | | | | | | | |
| 2 Foundation | | | | | | | | | | |
| Sub-total SWL for Foundation = 106 | | | | | | | | | | |
| Piling | | | | | | | | | | |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | 103 | A 103 |
| | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | Noise Insulation Sheet | -10 | 110 | 102 | | A |
| | Air Compressor, air flow > 30m3/min | CNP 003 | 2 | 75% | Enclosure | -10 | 104 | 96 | | A |
| | Grout mixer | EPD/PME/14 | 1 | 75% | Noise Barrier | -10 | 90 | 79 | | B 94 |
| | Grout pump | EPD/PME/15 | 1 | 75% | Noise Barrier | -10 | 105 | 94 | | B |
| | Mobile crane (62kW) | BS D7 114 | 2 | 50% | | | 101 | 101 | | C 102 |
| | Crane, tower (electric) | CNP 049 | 1 | 75% | | | 95 | 94 | | C |
| CAP | | | | | | | | | | |
| | Tracked Excavator/loader | BS D3 97 | 2 | 75% | Noise Barrier | -5 | 105 | 102 | 106 | A 106 |
| | Saw, circular, wood | CNP 201 | 2 | 50% | Noise Barrier | -10 | 108 | 98 | | A |
| | Bar bender and cutter (electric) | CNP 021 | 2 | 75% | Noise Barrier | -10 | 90 | 82 | | A |
| | Breaker, hand-held, mass > 20kg and < 35kg | CNP 025 | 1 | 50% | Noise Barrier | -5 | 111 | 103 | | A |
| | Concrete lorry mixer | CNP 044 | 2 | 50% | Noise Barrier | -5 | 109 | 104 | | B 106 |
| | Concrete pump, stationary/lorry mounted | BS D6 36 | 2 | 50% | Noise Barrier | -5 | 106 | 101 | | B |
| | Poker, vibratory, hand-held | BS D6 40 | 4 | 50% | Noise Barrier | -5 | 98 | 96 | | B |
| | Compactor, vibratory | CNP 050 | 2 | 40% | | | 105 | 104 | | C 105 |
| | Water pump (electric) | CNP 281 | 2 | 50% | | | 88 | 88 | | C |
| | Air Compressor, air flow > 30m3/min | CNP 003 | 1 | 75% | Enclosure | -10 | 104 | 93 | | C |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | | C |
| | Crane, tower (electric) | CNP 049 | 1 | 75% | | | 95 | 94 | | D 103 |
| | Mobile crane (62kW) | BS D7 114 | 1 | 50% | | | 101 | 98 | | D |
| | Dump truck | BS D9 39 | 1 | 50% | | | 103 | 100 | | D |
| 3 Excavation and Lateral Support (ELS) | | | | | | | | | | |
| Sub-total SWL for ELS = 106 | | | | | | | | | | |
| | Tracked Excavator/loader | BS D3 97 | 2 | 75% | Noise Barrier | -5 | 105 | 102 | 106 | A 106 |
| | Drill rig, rotary type (diesel) | EPD/PME/12 | 2 | 75% | Noise Insulation Sheet | -10 | 110 | 102 | | A |
| | Air Compressor, air flow > 30m3/min | CNP 003 | 2 | 75% | Enclosure | -10 | 104 | 96 | | A |
| | Water pump (electric) | CNP 281 | 3 | 50% | | | 88 | 90 | | A |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | | A |
| | Compactor, vibratory | CNP 050 | 2 | 50% | | | 105 | 105 | | B 105 |
| | Mobile crane (62kW) | BS D7 114 | 2 | 50% | | | 101 | 101 | | C 102 |
| | Grout mixer | EPD/PME/14 | 1 | 75% | Noise Barrier | -10 | 90 | 79 | | C |
| | Grout pump | EPD/PME/15 | 1 | 75% | Noise Barrier | -10 | 105 | 94 | | C |
| 4 Basement / Superstructure Construction | | | | | | | | | | |
| Sub-total SWL for Basement / Superstructure Works = 106 | | | | | | | | | | |
| | Tracked Excavator/loader | BS D3 97 | 2 | 75% | Noise Barrier | -5 | 105 | 102 | 106 | A 106 |
| | Saw, circular, wood | CNP 201 | 2 | 50% | Noise Barrier | -10 | 108 | 98 | | A |
| | Bar bender and cutter (electric) | CNP 021 | 2 | 75% | Noise Barrier | -10 | 90 | 82 | | A |
| | Breaker, hand-held, mass > 20kg and < 35kg | CNP 025 | 1 | 50% | Noise Barrier | -5 | 111 | 103 | | A |
| | Concrete lorry mixer | CNP 044 | 2 | 50% | Noise Barrier | -5 | 109 | 104 | | B 106 |
| | Concrete pump, stationary/lorry mounted | BS D6 36 | 2 | 50% | Noise Barrier | -5 | 106 | 101 | | B |

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-1 : Construction Plant Inventory - Mitigated

| No. | Activities Plant | TM / EPD ^[1] / BS 5228 ref. | No. of PME | On- time % | Type of Noise Control (Barrier/Enclosure) ^[3] | Noise reduction, dB(A) | Unit SWL, dB(A) | SWL, dB(A) | Total SWL, dB(A) ^[2] | Groups ^[4] |
|-----|--|---|---------------|---------------|---|------------------------------|-----------------------|---------------|---------------------------------------|-----------------------|
| | Poker, vibratory, hand-held | BS D6 40 | 4 | 50% | Noise Barrier | -5 | 98 | 96 | | B |
| | Compactor, vibratory | CNP 050 | 2 | 40% | | | 105 | 104 | | C |
| | Water pump (electric) | CNP 281 | 2 | 50% | | | 88 | 88 | | C |
| | Air Compressor, air flow > 30m ³ /min | CNP 003 | 1 | 75% | Enclosure | -10 | 104 | 93 | | C |
| | Generator, super silenced, 70dB(A) at 7m | CNP 103 | 1 | 100% | | | 95 | 95 | | C |
| | Crane, tower (electric) | CNP 049 | 1 | 75% | | | 95 | 94 | | D |
| | Mobile crane (62kW) | BS D7 114 | 1 | 50% | | | 101 | 98 | | D |
| | Dump truck | BS D9 39 | 1 | 50% | | | 103 | 100 | | D |

Notes:

- [1] SWLs of EPD/PME items refer to the document prepared by the Noise Control Authority (http://www.epd.gov.hk/epd/english/application_for_licences/guidance/files/OtherSWLe.pdf)
BS - British Standard BS 5228:2009, Part 1 Noise and Vibration Control on Construction and Open Sites
- [2] The figures are rounded-up to a whole number.
- [3] Noise barrier for mobile PME -5dB(A)
Noise barrier for stationary PME -10dB(A)
Noise enclosure -10dB(A)
Noise Insulation Sheet -10dB(A)
- [4] Either Group A, B, C or D will be undertaken at any one time.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3a Construction Airborne Noise Impact Assessment - Mitigated

NSR: N1

Amber Lodge

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 44 | -41 | 3 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 50 | -42 | 3 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 50 | -42 | 3 | | | | | | | | 67 | 67 | 67 | 67 | 67 | 67 | | | | | | | | |
| 4 | Basement / Superstructure Construction | 106 | 50 | -42 | 3 | | | | | | | | | | | | | | 67 | 67 | 67 | 67 | 67 | 67 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 71 | |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3b Construction Airborne Noise Impact Assessment - Mitigated

NSR: N2

Ho Fook Building

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 38 | -40 | 3 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | 71 | | | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 46 | -41 | 3 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 46 | -41 | 3 | | | | | | | | 67 | 67 | 67 | 67 | 67 | | | | | | | | | |
| 4 | Basement / Superstructure Construction | 106 | 46 | -41 | 3 | | | | | | | | | | | | | 68 | 68 | 68 | 68 | 68 | 68 | 68 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 67 | 67 | 67 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | 72 |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3c Construction Airborne Noise Impact Assessment - Mitigated

NSR: N3

Old Bailey Street Police Married Quarters

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 52 | -42 | 3 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | 68 | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 40 | -40 | 3 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 40 | -40 | 3 | | | | | | | | 69 | 69 | 69 | 69 | 69 | 69 | | | | | | | |
| 4 | Basement / Superstructure Construction | 106 | 40 | -40 | 3 | | | | | | | | | | | | | | 69 | 69 | 69 | 69 | 69 | 69 | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 72 | 72 | 72 | 72 | 72 | 72 | 72 | 71 | 71 | 71 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 72 |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3d Construction Airborne Noise Impact Assessment - Mitigated

NSR: N4

Cambridge Villa

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 57 | -43 | 3 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 30 | -37 | 3 | 72 | 72 | 72 | 72 | 72 | 72 | 72 | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 30 | -37 | 3 | | | | | | | | 71 | 71 | 71 | 71 | 71 | 71 | 71 | | | | | | |
| 4 | Basement / Superstructure Construction | 106 | 30 | -37 | 3 | | | | | | | | | | | | | | | 72 | 72 | 72 | 72 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 71 | 71 | 71 | 72 | 72 | 72 | 72 | 73 | |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3e Construction Airborne Noise Impact Assessment - Mitigated

NSR: N5

Chancery House

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 57 | -43 | 3 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | | | | | | | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 23 | -35 | 3 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 23 | -35 | 3 | | | | | | | | 73 | 73 | 73 | 73 | 73 | 73 | 73 | | | | | | |
| 4 | Basement / Superstructure Construction | 106 | 23 | -35 | 3 | | | | | | | | | | | | | 74 | 74 | 74 | 74 | 74 | 74 | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 75 | 75 | 75 | 75 | 75 | 75 | 75 | 74 | 74 | 74 | 73 | 73 | 73 | 74 | 74 | 74 | 74 | 74 | 75 | |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.

Conservation and Revitalization of the Central Police Station Compound (CPS)

Annex B4-3f Construction Airborne Noise Impact Assessment - Mitigated

NSR: N6

Chancery House

| No. | Activity Description | SWL dB(A) ^[2] | Distance m | Corr. for distance dB(A) ^{[1][2]} | Corr. for façade dB(A) | Predicted Construction Noise Level (dB(A)) | | | | | | | | | | | | | | | | Max. CNL dB(A) | | | | |
|--|--|-----------------------------|---------------|--|------------------------------|--|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|----------------------|-----|-----|-----|-----|
| | | | | | | 2012 | | | | | | | | | | | | 2013 | | | | | | | | |
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Jan | Feb | Mar | Apr | | May | Jun | Jul | Aug |
| I | Existing Buildings | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Phase 1 & Site Wide Structure | 107 | 57 | -43 | 3 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | 67 | | | |
| II | New Building | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Foundation | 106 | 23 | -35 | 3 | 74 | 74 | 74 | 74 | 74 | 74 | 74 | | | | | | | | | | | | | | |
| 3 | Excavation and Lateral Support (ELS) | 106 | 23 | -35 | 3 | | | | | | | | | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | 73 | | | |
| 4 | Basement / Superstructure Construction | 106 | 23 | -35 | 3 | | | | | | | | | | | | | | | | | | | | | |
| Predicted Noise Level during Daytime Period, dB(A) | | | | | | 75 | 75 | 75 | 75 | 75 | 75 | 75 | 75 | 74 | 74 | 74 | 74 | 73 | 73 | 73 | 74 | 74 | 74 | 74 | 75 | |

Notes:

- [1] Distance Correction for PMEs = $10 \cdot \log(2 \cdot \pi \cdot r^2)$
- [2] The figures are rounded-up to a whole number.