



Scenario B1 (2030s without I-PARK2)

The background seawater intakes and outfall discharges considered under Scenario B1 (2030s without I-PARK2) are shown in the figure below and described in **Table B1**.




Table B1 Intakes and Outfalls Considered in Scenario B1

| ID | Site | Activity | Operating hours per day | Parameters Considered in Modelling |
|-----|--------|--|-------------------------|--|
| S1 | T-Park | Seawater intake for desalination plant | 24 | Intake flow |
| O1 | | Effluent outfall of desalination plant | 24 | Effluent flow, salinity, temperature and TRC |
| S2a | BBPS | Seawater intake for original cooling water system | 24 | Intake flow |
| S2b | BBPS | Seawater intake for Additional Combined Cycle Gas Turbine (CCGT) | 24 | Intake flow |
| | | Seawater intake for cooling water blowdown | 24 | Intake flow |
| O2 | BBPS | Effluent outfall of original cooling water system | 24 | Effluent flow, temperature and TRC |
| | | Effluent outfall of Additional CCGT | 24 | Effluent flow, temperature and TRC |
| | | Outfall of cooling water blowdown effluent | 24 | Effluent flow, temperature and TRC |
| S3 | CPPS | Seawater Intake for cooling water and compressor cooling | 24 | Intake flow |
| O3a | CPPS | Outfall of cooling water effluent | 24 | Effluent flow, temperature and TRC |
| O3b | CPPS | Outfall of cooling water effluent | 24 | Effluent flow, temperature and TRC |
| | | Outfall of compressor cooling effluent | 24 | Effluent flow, temperature and TRC |



The flow and load of these background intakes and outfalls adopted in the modelling are based on actual monitoring data obtained from the intake operators. For any site or specific parameter where no monitoring data are available, the design values provided by the operators or the discharge limits in the WPCO discharge licenses are adopted.

Scenario B2, Scenario B3 and Scenario B4 (2030s with I-PARK2)

The background seawater intakes and outfall discharges as described in **Table B1** above are also considered under Scenario B2, Scenario B3 and Scenario B4 (2030s with I-PARK2). Scenario B2, Scenario B3 and Scenario B4 also incorporates the intake and effluent of I-PARK2 as tabulated in **Table B2** and their locations are shown in **Exhibit 5.3**.

Table B2 Modelling Assumptions for Intake and Outfall of I-PARK2

| ID | Activity | Period | Design Flow (m ³ /day), see Notes below | Operating hours per day | Design Salinity Level (ppt) | Design Temperature Elevation (°C) | Design TRC Limit (mg/L) | SMBS Limit (mg/L) | |
|---|----------------------------------|------------------|--|-------------------------|-----------------------------|-----------------------------------|-------------------------|-------------------|-----|
| Modelling Scenario B2 for Option A – Air-cooled System (see Note 3) | | | | | | | | | |
| I-PARK2- Seawater Intake | Seawater Intake of Desalination | Annual | -4,000 | 24 | - | - | - | - | |
| I-PARK2 - Outfall Option 1 | Effluent Outfall of Desalination | Annual | +2,400 | 24 | 60 | - | 0.2 | 0.5 | |
| Modelling for Scenarios B3 and B4 for Option B – Once-through Seawater Cooling System (see Note 3) | | | | | | | | | |
| I-PARK2- Seawater Intake | Seawater Intake | Desalination | Annual | -4,000 | 24 | - | - | - | - |
| | | Seawater cooling | Dry Season (November to April) | -1.12M | 24 | - | - | - | - |
| | | | Wet Season (May to October) | -1.15M | 24 | - | - | - | - |
| I-PARK2 - Outfall Option 2 (Scenario B3) or Outfall Option 3 (Scenario B4) | Effluent Outfall | Desalination | Annual | +2,400 | 24 | 60 | - | 0.2 | 0.5 |
| | | Seawater cooling | Dry Season (November to April) | +1.12M | 24 | - | + 10 | 0.2 | 0.5 |
| | | | Wet Season (May to October) | +1.15M | 24 | - | + 10 | 0.2 | 0.5 |

- Notes:
1. -ve sign in the table denote intake of seawater.
 2. +ve sign in the table denote outflow of Project discharge.
 3. With reference to **Exhibit 5-3**, Outfall Options 1, 2 and 3 are assumed under Scenarios B2, B3 and B4 respectively.