



5 Water Quality Impact

5.1 Introduction

This section presents an assessment of the potential water quality impacts associated with the construction and operation of the Integrated Waste Management Facilities Phase 2 (I-PARK2 or the Project). Suitable measures have been recommended, where necessary, to avoid/minimize/ mitigate the potential impacts.

5.2 Assessment Area and Water Sensitive Receivers

5.2.1 Assessment Area

In accordance with the EIA Study Brief, the water quality impact assessment shall cover area within 500 m from the boundary of the Project. It will also cover Deep Bay Water Control Zone (WCZ) and North Western WCZ defined under the Water Pollution Control Ordinance (WPCO) as well as Water Sensitive Receivers (WSRs) in the vicinity of the Project. The water quality impact assessment area shall be reviewed and extended to include other areas, if they are found also being affected by the Project during the course of this EIA study.

5.2.2 Water Sensitive Receivers

5.2.2.1 Inland Watercourses

Three major inland watercourses are identified within 500 m from the Project boundary, namely Water Channel (W1), Tsang Kok Stream (W2), Tsang Tsui Stream (W3). These inland watercourses are listed in **Table 5-1** and their locations are shown in **Figure 5.1**.

Table 5-1 Inland Watercourses

Name	ID	Description
Water Channel	W1	Man-made, tidally influenced channel with concrete bed
Tsang Kok Stream	W2	Fully channelized by concrete
Tsang Tsui Stream	W3	Partially disturbed natural stream

Tsang Tsui Stream (W3) is located to the south of the Project site. It has a natural stream bed but its banks have been disturbed and lined with geo-textile matting. Tsang Tsui Stream (W3) would discharge into Water Channel (W1), which is a man-made, tidally influenced concrete channel running along the southern Project site boundary.



The downstream section of Tsang Kok Stream is within the water quality impact assessment area of this Project. This section of Tsang Kok Stream (W2) is flowing through the existing West New Territories (WENT) Landfill site and is entirely channelized with concrete.

Both the Water Channel (W1) and Tsang Kok Stream (W2) would eventually drain into the tidal channel located to the east of T-Park.

5.2.3 Marine Water Sensitive Receivers and Observation Points

Key marine WSRs that would potentially be affected by the Project and observation points in the area of interest are summarized in **Table 5-2**. Their locations are shown in **Figure 5.2**.

Table 5-2 Marine Water Sensitive Receivers and Observation Points in the Vicinity of the Project

Description	Name / Location	ID	Beneficial Use / Type of WSR	Easting	Northing
Water Sensitive Receivers					
Seawater Intakes	T-Park	S1	Water supply for desalination plant	810475	831598
	Black Point Power Station	S2a	Cooling water supply	808133	830203
		S2b	Cooling water supply	808407	830288
	Castle Peak Power Station	S3	Cooling water supply	809429	826080
Mudflat / Seagrass / Horseshoe Crab	Ha Pak Nai	E1	Ecological sensitive receiver	812231	832329
	Sheung Pak Nai	E2	Ecological sensitive receiver	813179	833760
Marine Park	Sha Chau and Lung Kwu Chau (SCLKC)	E3 (see Note below)	Ecological sensitive receiver	806046	827890
Special Scientific Interest (SSSI)	Pak Nai	E4	Ecological sensitive receiver	813102	834120
Traditional Oyster Production Area	Tsim Bei Tsui to Pak Nai	F1	Fisheries sensitive receiver	812668	833808
Mariculture Subzone	Tsim Bei Tsui to Ha Pak Nai	F2	Fisheries sensitive receiver	811698	833323
Important Spawning Ground of Commercial Fisheries Resources	North Lantau	F3	Fisheries sensitive receiver	807036	827047
Secondary Contact Recreation Subzone	Coastal water of outer Deep Bay and North Western water	-	Secondary contact recreational water	Not Applicable	Not Applicable
Observation Points					
Oyster Culture Activities	North of Tsang Tsui	O1	Mariculture	810512	832411
Outside Mariculture		O2	Mariculture	809868	831720
Subzone		O3	Mariculture	810603	831927

Note: Indirect water quality impact on artificial reefs located in SCLKC Marine Park is assessed in the Fisheries Impact Assessment (**Section 8**) by making reference to the water quality impact assessment results for E3.



The observation points (O1 to O3) represent the area of oyster activities granted or to be granted in Deep Bay (which overlaps with the traditional oyster production area and the mariculture subzone).

Recent dive surveys conducted under this EIA in 2023 and 2024 and another study in 2021¹ showed the absence or very low coverage of common and widespread corals along the artificial shores of Outer Deep Bay. Isolated patches of one single species of gorgonian coral *Guaiaorgia sp.* were found along the artificial seawall of Tsang Tsui Ash Lagoons (TTAL) with very low coverage (<1%). These isolated patches of small and unhealthy coral colonies are regarded as of low ecological value and are not considered as sensitive coral site. They are therefore not covered in this water quality impact assessment. Descriptions of ecological and fisheries sensitive receivers are separately presented in the Ecological Impact Assessment and Fisheries Impact Assessment of this EIA report.

Locations of the seawater intakes (S1, S2a, S2b and S3) have been confirmed with the corresponding seawater intake operators.

5.3 Legislation, Standards, Guidelines and Criteria

5.3.1 Environmental Impact Assessment Ordinance

The new Technical Memorandum on Environmental Impact Assessment Process (EIAO-TM) has been effective since 30 June 2023. It specifies the assessment method and criteria that need to be followed in EIA. The reference sections in EIAO-TM that are relevant to the water quality impact assessment include:

- Annex 6 Criteria for Evaluating Water Pollution.
- Annex 14 Guidelines for Assessment of Water Pollution.

5.3.2 Water Pollution Control Ordinance (WPCO)

The Water Pollution Control Ordinance (WPCO) provides the major statutory framework for the protection and control of water quality in Hong Kong. According to the WPCO and its subsidiary legislation, Hong Kong waters are divided into ten Water Control Zones (WCZ). Corresponding statements of Water Quality Objectives (WQO) are stipulated for different water regimes (marine waters, inland waters, bathing beaches subzones, secondary contact recreation subzones and fish culture subzones) in the WCZ based on their beneficial uses. With reference to the EIA Study Brief, the Study Area for this water quality impact assessment covers Deep Bay and North Western WCZs (see **Figure 5.2**). Their corresponding WQOs as extracted from the WPCO are presented in **Table 5-3** and **Table 5-4**.

¹ Agreement CE 29/2010 (EP) Integrated Waste Management Facilities Phase 1 – Design and Construction. Additional Service – Conducting Marine Ecological Survey for Middle Ash Lagoon In Tsang Tsui, Tuen Mun. Dive Survey Report. September 2021



Table 5-3 Water Quality Objectives for Deep Bay Water Control Zone

Parameters	Water Quality Objectives	Part or Parts of Zone
A. Aesthetic Appearance	(a) Waste discharges shall cause no objectionable odours or discolouration of the water.	Whole Zone
	(b) Tarry residues, floating wood, articles made of glass, plastic, rubber or of any other substances should be absent.	Whole Zone
	(c) Mineral oil should not be visible on the surface. Surfactants should not give rise to a lasting foam.	Whole Zone
	(d) There should be no recognisable sewage-derived debris.	Whole Zone
	(e) Floating, submerged and semi-submerged objects of a size likely to interfere with the free movement of vessels, or cause damage to vessels, should be absent.	Whole Zone
	(f) Waste discharges shall not cause the water to contain substances which settle to form objectionable deposits.	Whole Zone
B. Bacteria	(a) The level of <i>Escherichia coli</i> (<i>E. coli</i>) should not exceed 610 per 100 millilitre (mL), calculated as the geometric mean of all samples collected in one calendar year.	Secondary Contact Recreation Subzones and Mariculture Subzones
	(b) The level of <i>E. coli</i> should be zero per 100 mL, calculated as the running median of the most recent 5 consecutive samples taken at intervals of between 7 and 21 days.	Yuen Long & Kam Tin (Upper) Subzone, Beas Subzone, Indus Subzone, Ganges Subzone and Water Gathering Ground Subzones
	(c) The level of <i>E. coli</i> should not exceed 1 000 per 100 mL, calculated as the running median of the most recent 5 consecutive samples taken at intervals of between 7 and 21 days.	Yuen Long & Kam Tin (Lower) Subzone and other inland waters
	(d) The level of <i>E. coli</i> should not exceed 180 per 100 mL, calculated as the geometric mean of all samples collected from March to October inclusive in one calendar year. Samples should be taken at least 3 times in a calendar month at intervals of between 3 and 14 days.	Yung Long Bathing Beach Subzone
C. Colour	(a) Waste discharges shall not cause the colour of water to exceed 30 Hazen units.	Yuen Long & Kam Tin (Upper) Subzone, Beas Subzone, Indus Subzone, Ganges Subzone and Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the colour of water to exceed 50 Hazen units.	Yuen Long & Kam Tin (Lower) Subzone and other inland waters
D. Dissolved Oxygen (DO)	(a) Waste discharges shall not cause the level of DO to fall below 4 milligrams per litre (mg/L) for 90% of the sampling occasions during the year; values should be taken at 1 metre (m) below surface.	Inner Marine Subzone excepting Mariculture Subzone
	(b) Waste discharges shall not cause the level of DO to fall below 4 mg/L for 90% of the sampling occasions during the year; values should be calculated as water column average (arithmetic mean of at least 2 measurements at 1 m below surface and 1 m above seabed). In addition, the concentration of DO should not be less than 2 mg/L within 2 m of the seabed for 90% of the sampling occasions during the year.	Outer Marine Subzone excepting Mariculture Subzone



Parameters	Water Quality Objectives	Part or Parts of Zone
	(c) The DO level should not be less than 5 mg/L for 90% of the sampling occasions during the year; values should be taken at 1 m below surface.	Mariculture Subzone
	(d) Waste discharges shall not cause the level of DO to be less than 4 mg/L.	Yuen Long & Kam Tin (Upper and Lower) Subzones, Beas Subzone, Indus Subzone, Ganges Subzone, Water Gathering Ground Subzones and other inland waters of the Zone
E. pH	(a) The pH of the water should be within the range of 6.5–8.5 units. In addition, waste discharges shall not cause the natural pH range to be extended by more than 0.2 units.	Marine waters excepting Yung Long Bathing Beach Subzone
	(b) Waste discharges shall not cause the pH of the water to exceed the range of 6.5–8.5 units.	Yuen Long & Kam Tin (Upper and Lower) Subzones, Beas Subzone, Indus Subzone, Ganges Subzone and Water Gathering Ground Subzones
	(c) The pH of the water should be within the range of 6.0–9.0 units.	Other inland waters
	(d) The pH of the water should be within the range of 6.0–9.0 units for 95% of samples. In addition, waste discharges shall not cause the natural pH range to be extended by more than 0.5 units.	Yung Long Bathing Beach Subzone
F. Temperature	Waste discharges shall not cause the natural daily temperature range to change by more than 2.0 °C.	Whole Zone
G. Salinity	Waste discharges shall not cause the natural ambient salinity level to change by more than 10%.	Whole Zone
H. Suspended Solids (SS)	(a) Waste discharges shall neither cause the natural ambient level to be raised by 30% nor give rise to accumulation of SS which may adversely affect aquatic communities.	Marine waters
	(b) Waste discharges shall not cause the annual median of SS to exceed 20 mg/L	Yuen Long & Kam Tin (Upper and Lower) Subzones, Beas Subzone, Ganges Subzone, Indus Subzone, Water Gathering Ground Subzones and other inland waters
I. Ammonia	The un-ionized ammoniacal nitrogen level should not be more than 0.021 mg/L, calculated as the annual average (arithmetic mean).	Whole Zone
J. Nutrients	(a) Nutrients shall not be present in quantities sufficient to cause excessive or nuisance growth of algae or other aquatic plants.	Inner and Outer Marine Subzones
	(b) Without limiting the generality of objective (a) above, the level of inorganic nitrogen should not exceed 0.7 mg/L, expressed as annual mean.	Inner Marine Subzone
	(c) Without limiting the generality of objective (a) above, the level of inorganic nitrogen should not exceed 0.5 mg/L, expressed as annual water column average (arithmetic mean of at least 2 measurements at 1 m below surface and 1 m above seabed).	Outer Marine Subzone
K. 5-Day Biochemical	(a) Waste discharges shall not cause the BOD ₅ to exceed 3 mg/L	Yuen Long & Kam Tin (Upper Subzone, Beas Subzone, Indus Subzone, Ganges Subzone and



Parameters	Water Quality Objectives	Part or Parts of Zone
Oxygen Demand (BOD ₅)		Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the BOD ₅ to exceed 5 mg/L	Yuen Long & Kam Tin (Lower) Subzone and other inland waters
L. Chemical Oxygen Demand (COD)	(a) Waste discharges shall not cause the COD to exceed 15 mg/L	Yuen Long & Kam Tin (Upper) Subzone, Beas Subzone, Indus Subzone, Ganges Subzone and Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the COD to exceed 30 mg/L	Yuen Long & Kam Tin (Lower) Subzone and other inland waters
M. Toxins	(a) Waste discharges shall not cause the toxins in water to attain such levels as to produce significant toxic, carcinogenic, mutagenic or teratogenic effects in humans, fish or any other aquatic organisms, with due regard to biologically cumulative effects in food chains and to toxicant interactions with each other	Whole Zone
	(b) Waste discharges shall not cause a risk to any beneficial use of the aquatic environment	Whole Zone
N. Phenol	Phenols shall not to be present in such quantities as to produce a specific odour, or in concentration greater than 0.05 mg/L as C ₆ H ₅ OH	Yung Long Bathing Beach Subzone
O. Turbidity	Waste discharges shall no reduce light transmission substantially from the normal level	Yung Long Bathing Beach Subzone

Source: Statement of Water Quality Objectives (Deep Bay Water Control Zone)

Table 5-4 Water Quality Objectives for North Western Water Control Zone

Parameters	Objectives	Part or Parts of Zone
A. Aesthetic Appearance	(a) Waste discharges shall cause no objectionable odours or discolouration of the water.	Whole Zone
	(b) Tarry residues, floating wood, articles made of glass, plastic, rubber or of any other substances should be absent.	Whole Zone
	(c) Mineral oil should not be visible on the surface. Surfactants should not give rise to a lasting foam.	Whole Zone
	(d) There should be no recognisable sewage-derived debris.	Whole Zone
	(e) Floating, submerged and semi-submerged objects of a size likely to interfere with the free movement of vessels, or cause damage to vessels, should be absent.	Whole Zone
	(f) Waste discharges shall not cause the water to contain substances which settle to form objectionable deposits.	Whole Zone
B. Bacteria	(a) The level of <i>Escherichia coli</i> (<i>E. coli</i>) should not exceed 610 per 100 millilitre (mL), calculated as the geometric mean of all samples collected in a calendar year.	Secondary Contact Recreation Subzones
	(b) The level of <i>E. coli</i> should be less than 1 per 100 mL, calculated as the running median of the most recent	Tuen Mun (A) and Tuen Mun (B) Subzones and Water Gathering Ground Subzones



Parameters	Objectives	Part or Parts of Zone
	5 consecutive samples taken at intervals of between 7 and 21 days.	
	(c) The level of <i>E. coli</i> should not exceed 1 000 per 100 mL, calculated as the running median of the most recent 5 consecutive samples taken at intervals of between 7 and 21 days.	Tuen Mun (C) Subzone and other inland waters
	(d) The level of <i>E. coli</i> should not exceed 180 per 100 mL, calculated as the geometric mean of all samples collected from March to October inclusive. Samples should be taken at least 3 times in one calendar month at intervals of between 3 and 14 days.	Bathing Beach Subzones
C. Colour	(a) Waste discharges shall not cause the colour of water to exceed 30 Hazen units.	Tuen Mun (A) and Tuen Mun (B) Subzones and Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the colour of water to exceed 50 Hazen units.	Tuen Mun (C) Subzone and other inland waters
D. Dissolved Oxygen (DO)	(a) Waste discharges shall not cause the level of DO to fall below 4 milligrams per litre (mg/L) for 90% of the sampling occasions during the whole year; values should be calculated as water column average (arithmetic mean of at least 3 measurements at 1 m below surface and 1 m above seabed). In addition, the concentration of DO should not be less than 2 mg/L within 2 m of the seabed for 90% of the sampling occasions during the whole year.	Marine waters
	(b) Waste discharges shall not cause the level of DO to fall below 4 mg/L.	Tuen Mun (A), Tuen Mun (B) and Tuen Mun (C) Subzones, Water Gathering Ground Subzones and other inland waters
E. pH	(a) The pH of the water should be within the range of 6.5–8.5 units. In addition, waste discharges shall not cause the natural pH range to be extended by more than 0.2 unit.	Marine waters excepting Bathing Beach Subzones
	(b) Waste discharges shall not cause the pH of the water to exceed the range of 6.5–8.5 units.	Tuen Mun (A), Tuen Mun (B) and Tuen Mun (C) Subzones and Water Gathering Ground Subzones
	(c) The pH of the water should be within the range of 6.0–9.0 units.	Other inland waters
	(d) The pH of the water should be within the range of 6.0–9.0 units for 95% of samples collected during the whole year. In addition, waste discharges shall not cause the natural pH range to be extended by more than 0.5 unit.	Bathing Beach Subzones
F. Temperature	Waste discharges shall not cause the natural daily temperature range to change by more than 2 °C	Whole Zone
G. Salinity	Waste discharges shall not cause the natural ambient salinity level to change by more than 10%	Whole Zone
H. Suspended Solids (SS)	(a) Waste discharges shall neither cause the natural ambient level to be raised by more than 30% nor give rise to accumulation of suspended solids which may adversely affect aquatic communities.	Marine waters



Parameters	Objectives	Part or Parts of Zone
	(b) Waste discharges shall not cause the annual median of SS to exceed 20 mg/L.	Tuen Mun (A), Tuen Mun (B) and Tuen Mun (C) Subzones and Water Gathering Ground Subzones
	(c) Waste discharges shall not cause the annual median of SS to exceed 25 mg/L.	Other inland waters
I. Ammonia	The un-ionized ammoniacal nitrogen level should not be more than 0.021 mg/L, calculated as the annual average (arithmetic mean).	Whole Zone
J. Nutrients	(a) Nutrients shall not be present in quantities sufficient to cause excessive or nuisance growth of algae or other aquatic plants.	Marine waters
	(b) Without limiting the generality of objective (a) above, the level of inorganic nitrogen should not exceed 0.3 mg/L, expressed as annual water column average (arithmetic mean of at least 3 measurements at 1 m below surface, mid-depth and 1 m above seabed).	Castle Peak Bay Subzone
	(c) Without limiting the generality of objective (a) above, the level of inorganic nitrogen should not exceed 0.5 mg/L, expressed as annual water column average (arithmetic mean of at least 3 measurements at 1 m below surface and 1 m above seabed).	Marine waters excepting Castle Peak Bay Subzone
K. 5-Day Biochemical Oxygen Demand (BOD ₅)	(a) Waste discharges shall not cause the BOD ₅ to exceed 3 mg/L	Tuen Mun (A), Tuen Mun (B) and Tuen Mun (C) Subzones and Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the BOD ₅ to exceed 5 mg/L	Other inland waters
L. Chemical Oxygen Demand (COD)	(a) Waste discharges shall not cause the COD to exceed 15 mg/L.	Tuen Mun (A), Tuen Mun (B) and Tuen Mun (C) Subzones and Water Gathering Ground Subzones
	(b) Waste discharges shall not cause the COD to exceed 30 mg/L.	Other inland waters
M. Toxins	(a) Waste discharges shall not cause the toxins in water to attain such levels as to produce significant toxic, carcinogenic, mutagenic or teratogenic effects in humans, fish or any other aquatic organisms, with due regard to biologically cumulative effects in food chains and to toxicant interactions with each other.	Whole Zone
	(b) Waste discharges shall not cause a risk to any beneficial use of the aquatic environment.	Whole Zone
N. Phenol	Phenols shall not be present in such quantities as to produce a specific odour, or in concentration greater than 0.05 mg/L as C ₆ H ₅ OH	Bathing Beach Subzones
O. Turbidity	Waste discharges shall not reduce light transmission substantially from the normal level	Bathing Beach Subzones

Source: Statement of Water Quality Objectives (North Western Water Control Zone)

5.3.3 Technical Memorandum on Effluent Discharge Standard

Besides setting the WQOs, the WPCO controls effluent discharging into the WCZs through a licensing system. Guidance on the permissible effluent discharges based on the type of



receiving waters (foul sewers, stormwater drains, inland and coastal waters) is provided in the Technical Memorandum on Standards for Effluents Discharged into Drainage and Sewerage Systems, Inland and Coastal Waters (TM-DSS). The limits given in the TM-DSS cover the physical, chemical and microbial quality of effluents. Any effluent discharge during the construction and operational stages should comply with the relevant standards as stipulated in the TM-DSS. According to Section 9 of the TM-DSS, no new effluent will be allowed: (1) within 200m of the seaward boundaries of a marine fish culture zone or a site of special scientific interest (SSSI), and within 100m of the landward boundaries; and (2) within 100m of a seawater intake point.

5.3.4 Professional Persons Environmental Consultative Committee Practice Notes

The Professional Persons Environmental Consultative Committee Practice Note on Construction Site Drainage (ProPECC PN 2/23) provides good practice guidelines for dealing with various types of discharge from a construction site. These include surface runoff, groundwater, boring and drilling water, bentonite slurry, water for testing and sterilisation of water retaining structures and water pipes, wastewater from building construction, acid cleaning, etching and pickling wastewater, and wastewater from site facilities. Practices outlined in the ProPECC PN 2/23 should be followed where applicable during the construction phase to minimize the water quality impact due to construction site drainage.

The Professional Persons Environmental Consultative Committee Practice Note on Drainage Plans subject to Comments by Environmental Protection Department (ProPECC PN 1/23) provides guidelines and practices for handling, treatment and disposal of various effluent discharges to stormwater drains and foul sewers during the operation phase.

The relevant practices outlined in ProPECC PN 2/23 and ProPECC PN 1/23 should be implemented as far as practicable during construction phase and operational phase respectively to ensure proper handling, treatment and disposal of various discharges from the Project.

5.3.5 Sediment Deposition Criterion for Benthic Ecology

Potential impacts on benthic organisms (e.g. seagrass) may arise through excessive sediment deposition. The magnitude of the potential impacts is assessed based on the predicted sedimentation rate.

Deep Bay and North Western WCZs are located in the Pearl River Estuary where the sediment regime is more dynamic than in other parts of Hong Kong's coastal waters. Typical benthic communities in the estuarine environment of Deep Bay and North Western WCZs are expected



to be more tolerant to sediment deposition. The sediment deposition criterion of 100 g/m²/day is adopted for this EIA study, following the approach used in other recent EIA projects such as the EIA for Route 11 (Section between Yuen Long and North Lantau) (AEIAR-255/2023).

5.3.6 Total Residual Chlorine Criterion

Chlorine is commonly used as an anti-fouling agent for seawater intake and outfall systems. Residual chlorine discharging to the receiving water is potentially harmful to marine organisms. Environmental Protection Department (EPD) had commissioned an ecotoxicity study² on Total Residual Chlorine (TRC) using local species. The lowest No Observable Effect Concentration (NOEC) value from that study (based on a 4-day average chronic toxicity exposure) was 0.02 mg/L.

The United States Environmental Protection Agency (USEPA) derived a chronic TRC limit of 0.0075 mg/L (as 4-day average) and an acute TRC limit of 0.013 mg/L (as one-hour average) to protect saltwater aquatic life. The USEPA saltwater TRC limits are considered to be more applicable to the actual aquatic environment in the areas and therefore adopted as the assessment criteria for this EIA study.

5.3.7 Seawater Intake Water Quality Criteria

5.3.7.1 T-Park

The design water quality for the seawater intake of T-Park has been obtained from T-Park. Selected parameters that are relevant to this EIA are tabulated in **Table 5-5**.

Table 5-5 Design Intake Water Quality for T-Park

Parameters	Unit	Upper Bound of Design Water Quality
Temperature	°C	31
Total Suspended Solids (TSS)	mg / L	130

Remark: The design water quality for seawater intake of T-Park includes around 20 parameters, e.g. temperature, TSS, and some metals like iron, magnesium and calcium. The Project would mainly affect 2 design parameters, namely temperature and TSS, which are therefore considered in the assessment. The effect on the remaining design parameters of concern induced by the Project is expected to be negligible.

5.3.7.2 Power Stations

Based on the latest information obtained from the intake operators under this EIA study, the absolute Suspended Solids (SS) limit for the seawater intakes of Black Point Power Station (BBPS) is 764 mg/L whereas the tolerance SS increase at the intake points is 700 mg/L. On the

² Tender Ref. WP 98-567 Provision of Service for Ecotoxicity Testing of Marine Antifoulant – Chlorine in Hong Kong Final Report January 2000. Submitted to Environmental Protection Department by the Centre for Coastal Pollution and Conservation, City University of Hong Kong.



other hand, no specific water quality criteria are available for the seawater intake of Castle Peak Power Station (CPPS) as advised by the intake operator (see **Appendix 5A**).

5.3.8 Water Quality Criteria for Ecological and Fisheries Sensitive Receivers

The existing ecological and fisheries resources in the assessment area are subject to the influences of the Pearl River discharges with relatively high Suspended Solids (SS). They are expected to tolerate a wider range of environmental conditions as compared to those receivers located outside the Pearl River Estuary. The WQOs established under the WPCO for SS, temperature and salinity; the sediment deposition criterion for benthic ecology; and the water quality criteria for TRC as presented in the sub-sections above are considered sufficient for protection of the identified ecological and fisheries resources including the traditional oyster production area.

5.4 Baseline Conditions

5.4.1 Inland Water

There is one EPD's routine river water quality monitoring station (DB8) located at Tsang Kok Stream. Location of monitoring station (DB8) is shown in **Figure 5.1**. A summary of the monitoring data as extracted from the EPD's publication "River Water quality in Hong Kong in 2022" is presented in **Table 5-6**.

Table 5-6 River Water Quality Monitoring Data Collected by EPD in 2022

Parameter	Unit	Tsang Kok Stream (DB8)	Summary of WPCO WQOs
Dissolved Oxygen (DO)	mg/L	8.7 (7.2 – 10.5)	≥4 (minimum value)
pH	pH unit	7.4 (7.2 – 7.9)	6-9
Suspended Solids (SS)	mg/L	4.7 (1.5 – 24.0)	≤20 (annual median)
5-day Biochemical Oxygen Demand (BOD ₅)	mg/L	0.5 (<0.1 – 4.1)	≤5 (maximum value)
Chemical Oxygen Demand (COD)	mg/L	5 (<2– 25)	≤30 (maximum value)
Oil & Grease	mg/L	<0.5 (<0.5 – <0.5)	N/A
Faecal coliforms	cfu/100mL	4 000 (400 – 31 000)	N/A
<i>E. coli</i>	cfu/100mL	340 (120 – 3 700)	≤1 000 (median of 5 consecutive samples)
Ammonia-nitrogen (NH ₃ -N)	mg/L	0.069 (0.031– 8.700)	N/A
Nitrate-nitrogen (NO ₃ -N)	mg/L	1.800 (0.520 – 2.900)	N/A
Total Kjeldahl Nitrogen (TKN)	mg/L	0.34 (0.17 – 12.00)	N/A
Orthophosphate (PO ₄ -P)	mg/L	0.008 (<0.002– 0.019)	N/A
Total phosphorus (TP)	mg/L	<0.02 (<0.02 – 0.06)	N/A
Sulphide	mg/L	<0.02 (<0.02 – 0.02)	N/A
Aluminium	µg/L	<50 (<50 – <50)	N/A
Cadmium	µg/L	<0.1 (<0.1 – <0.1)	N/A
Chromium	µg/L	<1 (<1 – <1)	N/A
Copper	µg/L	<1 (<1 – 4)	N/A



Parameter	Unit	Tsang Kok Stream (DB8)	Summary of WPCO WQOs
Lead	µg/L	<1 (<1 – <1)	N/A
Zinc	µg/L	<10 (<10 – 10)	N/A
Flow	m ³ /s	0.018 (0.002 – 0.142)	N/A

Notes:

1. Data source: River Water Quality in Hong Kong in 2022.
2. Data presented are in annual medians of monthly samples, except those for faecal coliforms and *E. coli* which are in annual geometric means.
3. Figures in brackets are annual ranges.
4. N/A: Not available

Tsang Kok Stream had a “Excellent” grading in 2022. The WQO compliance rate for the monitoring station at Tsang Kok Stream was 100% in 2022.

There are no available water quality monitoring data for Tsang Tsui Stream (W3) and Water Channel (W1) as shown in **Figure 5.1**. The catchment areas of these two watercourses are mainly rural in nature. Majority of their catchment areas comprises natural topography with no significant water pollution source.

5.4.2 Marine Water

5.4.2.1 EPD Monitoring Data

The EPD water quality monitoring stations in the Outer Deep Bay WCZ (DM4 and DM5) and Urmston Road of the North Western WCZ (NM5) are the nearest monitoring stations to the Project site (see **Figure 5.2**). A summary of the relevant monitoring data as extracted from the EPD’s publication “Marine Water quality in Hong Kong in 2022” is presented in **Table 5-7**.

Table 5-7 Marine Water Quality Monitoring Data Collected by EPD in 2022

Parameter		Outer Deep Bay		Urmston Road	Summary of WPCO WQOs
		DM4	DM5	NM5	
Temperature (°C)		25.0 (18.5 – 30.6)	24.5 (18.4 – 29.9)	24.5 (15.9 – 29.4)	≤ 2 °C change from natural daily range
Salinity		23.2 (8.0 – 31.2)	25.2 (9.0 – 32.7)	27.3 (19.7 – 33.1)	±10% change from natural ambient level
Dissolved Oxygen (DO) (mg/L)	Depth average	5.9 (4.7 – 7.0)	5.8 (5.0 – 6.7)	5.5 (4.1 – 6.8)	≥4 mg/L for 90% of the samples during the year
	Bottom	5.7 (4.1 – 7.4)	5.8 (4.7 – 7.2)	5.2 (3.5 – 7.0)	≥2 mg/L for 90% of the samples during the year
Dissolved Oxygen (DO) (% Saturation)	Depth average	80 (67 – 94)	80 (71 – 90)	77 (56 – 86)	N/A
	Bottom	79 (57 – 99)	80 (67 – 92)	73 (51 – 87)	N/A
pH		7.5 (7.1 – 7.9)	7.6 (7.1 – 8.0)	7.6 (7.1 – 8.0)	6.5 – 8.5 (± 0.2 change from natural range)
Secchi disc Depth (m)		1.9 (1.2 – 2.9)	1.9 (1.7 – 2.7)	1.9 (1.2 – 2.7)	N/A
Turbidity (NTU)		32.3 (5.4 – 144.0)	23.4 (4.0 – 78.1)	32.8 (4.1 – 120.0)	N/A



Parameter	Outer Deep Bay		Urmston Road	Summary of WPCO WQOs
	DM4	DM5	NM5	
Suspended Solids (mg/L)	7.4 (3.2 – 14.0)	5.2 (3.3 – 9.7)	10.4 (2.6 – 30.0)	≤ 30% increase from natural ambient level
5-day Biochemical Oxygen Demand (BOD ₅) (mg/L)	0.7 (<0.1 – 3.3)	0.9 (0.1 – 2.9)	0.5 (<0.1 – 0.9)	N/A
Ammonia Nitrogen (NH ₃ -N) (mg/L)	0.127 (0.038 – 0.200)	0.098 (0.009 – 0.190)	0.094 (0.034 – 0.177)	N/A
Unionised Ammonia (UIA) (mg/L)	0.002 (<0.001 – 0.007)	0.002 (<0.001 – 0.006)	0.002 (<0.001 – 0.005)	≤0.021 mg/L (annual mean)
Nitrite Nitrogen (NO ₂ -N) (mg/L)	0.061 (0.033 – 0.130)	0.057 (0.020 – 0.137)	0.057 (0.011 – 0.120)	N/A
Nitrate Nitrogen (NO ₃ -N) (mg/L)	0.630 (0.300 – 1.200)	0.558 (0.140 – 1.270)	0.356 (0.066 – 0.917)	N/A
Total Inorganic Nitrogen (TIN) (mg/L)	0.82 (0.43 – 1.43)	0.71 (0.28 – 1.41)	0.51 (0.20 – 1.02)	≤0.5 mg/L (annual mean)
Total Kjeldahl Nitrogen (TKN) (mg/L)	0.35 (0.18 – 0.64)	0.31 (0.12 – 0.88)	0.39 (0.13 – 1.15)	N/A
Total Nitrogen (TN) (mg/L)	1.04 (0.56 – 1.61)	0.93 (0.44 – 1.56)	0.81 (0.42 – 1.23)	N/A
Orthophosphate Phosphorus (PO ₄ -P) (mg/L)	0.029 (<0.002 – 0.073)	0.016 (<0.002 – 0.038)	0.016 (0.005 - 0.038)	N/A
Total Phosphorus (TP) (mg/L)	0.09 (0.04 - 0.13)	0.06 (0.03 - 0.10)	0.06 (0.04 - 0.10)	N/A
Silica (as SiO ₂) (mg/L)	3.57 (0.99 – 7.50)	3.00 (0.86 – 8.10)	2.24 (0.72 – 5.47)	N/A
Chlorophyll- <i>a</i> (µg/L)	1.9 (0.5 – 5.2)	2.0 (0.5 – 5.9)	1.4 (0.5 – 3.4)	N/A
<i>E. coli</i> (cfu/100 mL)	17 (<1 – 250)	20 (2 – 940)	41 (4 - 770)	N/A
Faecal Coliforms (cfu/100 mL)	35 (1 – 760)	43 (2 – 1900)	89 (8 - 1400)	N/A

Notes:

1. Data source: Marine Water Quality in Hong Kong in 2022
2. Except as specified, data presented are depth-averaged values calculated by taking the means of three depths: Surface, mid-depth, bottom.
3. Data presented are annual arithmetic means of depth-averaged results except for *E. coli* and faecal coliforms that are annual geometric means.
4. Data in brackets indicate the ranges.
5. N/A: Not available.

In 2022, the water quality in outer Deep Bay and Urmston Road complied with the WQOs for Dissolved Oxygen (DO), pH and Unionized Ammonia (UIA) but exceeded the WQO for Total Inorganic Nitrogen (TIN) due to the influence of high background level in the Pearl River Estuary.

The long-term water quality monitoring data collected in outer Deep Bay and North Western waters ³ also showed exceedances of the TIN WQOs. The measured TIN levels in outer Deep Bay and North Western waters steadily increased over the period from 1986 to early 2000s. A noticeable decreasing trends of measured TIN levels from mid-2000s to 2022 has been seen.

³ EPD Marine Water Quality Data (<https://cd.epic.epd.gov.hk/EPICRIVER/marine/?lang=en>)



5.4.2.2 Decommissioning of West Portion of the Middle Ash Lagoon

Decommissioning of West Portion of the Middle Ash Lagoon was completed on 24 May 2017. A post-construction marine water monitoring programme was conducted for a 4-week period from 29 May to 23 June 2017⁴. Heavy metals including aluminium, chromium and cadmium, which have the greatest tendency to leach from the pulverised fuel ash (PFA) into the seawater solution from past laboratory leaching trials^{5,6}, were monitored. Monitoring locations include two impact stations located in the vicinity of the TTAL and two control stations in the outer marine water of Deep Bay. During the post-construction monitoring period, there were no construction works undertaken at the ash lagoons with no disturbance to the PFA. These monitoring data are best available information to represent the baseline metal concentrations near the Project site. The relevant monitoring data are summarized in **Table 5-8**. Locations of the monitoring stations (M1, M2, C2 and C3) are shown in **Figure 5.1**.

Table 5-8 Metal Concentrations Measured Near the Project Site in 2017

Date	Cadmium (µg/L)		Chromium (µg/L)		Aluminium (µg/L)	
	M1 and M2 in Vicinity of TTAL	C2 and C3 in Outer Marine Water	M1 and M2 in Vicinity of TTAL	C2 and C3 in Outer Marine Water	M1 and M2 in Vicinity of TTAL	C2 and C3 in Outer Marine Water
29 May 2017	<0.5	<0.5	<1	<1	<20	<20
31 May 2017	<0.5	<0.5	<1	<1	<20	<20
2 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
5 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
7 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
9 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
12 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
14 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
16 Jun 2017	0.63 – 2.45	0.85 – 2.85	<1	<1	<20	<20
19 Jun 2017	<0.5	<0.5	<1	<1	<20	<20
21 Jun 2017	1.40 – 2.95	1.75 - 2.80	<1	<1	<20	<20
23 Jun 2017	<0.5	<0.5	<1	<1	<20	<20

Note: Bolded values – measured concentrations are above the detection limit.

Most of the metal concentrations measured near the ash lagoons were below the detection limits. The measured cadmium concentrations were above the detection limit at two locations (M1 and M2) near the ash lagoons on two monitoring dates. The same degree of cadmium concentrations was also observed in the outer marine water (C2 and C3) on the same dates. The increase in cadmium concentrations on the two monitoring dates could be due to other background sources in Deep Bay. The monitoring data showed no evidence of PFA leachate

⁴ Decommissioning of West Portion of the Middle Ash Lagoon at Tsang Tsui, Tuen Mun. Final EM&A Review Report.

⁵ EIA for Decommissioning of West Portion of the Middle Ash Lagoon at Tsang Tsui, Tuen Mun (AEIAR-186/2015)

⁶ EIA for Development of Integrated Waste Management Facilities Phase 1 (AEIAR-163-2012)



release from the ash lagoons. Dispersion of the PFA leachate across the Deep Bay water was also not observed.

5.5 Identification of Potential Impacts

5.5.1 Construction Phase

5.5.1.1 Introduction

Potential sources of water quality impact associated with the Project during the construction phase include:

- Construction site runoff and dust suppression sprays.
- Wastewater from general land-based construction activities.
- General refuse.
- Accidental chemical spillage.
- Sewage effluent from construction workforce.
- Seawall Modification and Construction of permanent berthing facility.
- Construction of seawater intake and outfall.
- Release of Pulverized Fuel Ash (PFA) leachate from ash lagoon.

5.5.1.2 Construction Site Runoff and Dust Suppression Sprays

Runoff and erosion from exposed soil surfaces and stockpiles of the construction site may contain increased loads of sediments. Water spraying would be an effective measure for dust suppression but the spent water could be high in Suspended Solids (SS) and turbidity. Uncontrolled discharge of construction site runoff and spent effluent generated from dust suppression spraying would potentially increase the SS and turbidity level in the nearby water environment.

Wastewater may also be generated from the rain washing down of cement and other grouting materials. These wash waters are turbid and alkaline materials. Uncontrolled release of these materials may increase the SS levels and raise the pH level in the nearby water bodies.

5.5.1.3 Wastewater from General Land-based Construction Activities

Wastewater from cleaning and polishing, effluent from foundation piling as well as the equipment / wheel washing water may contain high levels of SS. Uncontrolled release of these types of wastewater may increase the SS level in WSRs.



5.5.1.4 General Refuse

Construction works would generate debris and rubbish such as packaging and refuse. Improper rubbish and refuse disposal could lead to degradation of aesthetic appearance and water quality of the receiving waters.

5.5.1.5 Accidental Chemical Spillage

Variety of chemicals would be used for carrying out construction activities. These chemicals may include petroleum products, spent lubrication oil, grease, mineral oil and solvent. Fuel, oil and lubricants may be used for maintenance of construction vehicles, machinery and equipment. Accidental leakage or spillage of these chemicals may infiltrate into the surface soil layer, or runoff into nearby water bodies, increasing their hydrocarbon levels.

5.5.1.6 Sewage Effluent from Construction Workforce

Domestic sewage would be generated from the workforce during the construction phase. Discharge of sewage effluent may increase the organic pollution, ammonia and bacterial levels in the receiving waters.

5.5.1.7 Seawall Modification and Construction of Permanent Berthing Facility

The existing artificial seawall to the north and west of the Project site will be modified for construction of berthing facility and / or seawater outfall to support operation of I-PARK2. The berthing facility for I-PARK2 are proposed for marine delivery of municipal solid waste (MSW) and incinerator ash. Modification of the existing seawall would also be required for the proposed seawater outfalls and the associated pipeworks associated with the once-through seawall cooling system as described in **Section 5.5.2.2**.


Marine construction will be carried out for seawall modification /construction of the proposed berthing facility. The non-dredged method, namely Deep Cement Mixing (DCM), will be adopted for construction of the foundation for the proposed seawall modification /berthing facility. The DCM involves injecting controlled volumes of cement into the underlying materials whilst simultaneously mixing the cement with the *in-situ* materials to improve their strength. Prior to installation of the DCM columns, the existing rock fill on the outer seawall would be removed. Sand blanket would then be laid across the DCM works area before commencement of the DCM operation. After completion of the DCM operation, precast concrete blocks would be placed on top of the DCM columns to form a new seawall along the Middle and West Ash Lagoons. Any further filling work for the proposed seawall modification / berthing facility would be land-based and conducted behind the modified seawall.



Exhibit 5-1 Typical Arrangement of Berthing Facility / Seawall Modification Work


Existing Seawall (Section View):

Not to Scale



Proposed Seawall Modification / Berthing Facility (Section View):

Not to Scale



Potential water quality impact associated with the DCM works may include sediment loss and accidental discharge of cement slurry during the DCM operation, which may increase the SS and pH levels in the marine water. Thermal impact may also be induced from the possible heat dissipation from the exothermic process of DCM.

Release of fines may also occur during the sand blanket laying works, which would increase the SS levels in the receiving marine waters. A single layer of silt curtain shall be deployed throughout the whole marine sand blanket laying works and the whole DCM works to minimize the associated potential water quality impact. A single layer of silt curtain would reduce the dispersion of SS by a factor of 4 (or about 75%). This efficiency value was developed under the EPD's Contaminated Spoil Management Study and has been proven and adopted in all past relevant EIA projects involving a single layer silt curtain system.

The content of fines in the rock fill of the existing seawall and in the precast concrete blocks of the modified seawall would be negligible. No loss of fines and contaminants would be expected during the removal of the outer section of the existing seawall and placement of new precast concrete blocks on the DCM columns.

5.5.1.8 Construction of Seawater Intake and Outfall

The proposed desalination plant and seawater cooling system would involve new seawater




intake and outfall. The proposed intake and outfall would be located at the seawall. No submarine intake nor submarine outfall would be constructed under the Project. Installation of the intake and outfall pipes would not disturb the seabed or sediments. The pipe installation works will be incorporated into the land-based construction works of the Project. The intake and outfall piping work would not create additional water quality impact. No further assessment is required for the intake and outfall construction.

5.5.1.9 Release of PFA Leachate from Ash Lagoon

The Middle Ash Lagoon area is underlain by marine deposits which consist of fine-grained clay material. Based on available information^{7, 8}, the thickness of marine deposits may vary from 3.5 to 5 m. Alluvium is present underneath the marine deposits. Depths of alluvium may vary from approximately 4.0 to 19.0 m. The layer of alluvium is underlain by completely decomposed granite (CDG) with possible depths ranging from approximately 3.5 to 15.2 m. The Middle Ash Lagoon area is also bounded by the existing sloping seawall at the north. Filter layers (in the form of geotextile materials and a layer of injected bentonite) are laid on the inner face of the existing seawall⁵. The low permeability values of the marine deposits and alluvium at the base of the ash lagoon as well as the filter layers of the existing seawall would limit the seepage of PFA leachate into the marine water.

Exhibit 5-2 Typical Section View of Rubble Mound Sloping Seawall



During the I-PARK2 construction, piling would be applied for foundation construction. The piles would penetrate through the base of the Middle Ash Lagoon to the hard CDG bedrock to support the facility. The piling activities would only involve localized displacement of the PFA / fill material layer. The present of piles would restrict the movement of groundwater across the lagoon site. Seawall modification works / construction of new berthing facility would involve removal of the amour stones on the outer face of the seawall and would not disturb the inner core materials and filter layers. The design level of the proposed pipeline in West Ash Lagoon would be above PFA surface and the filter layer. Installation of the outfall structure would be incorporated into the seawall modification works. The opening of the outfall structure would be sealed prior to the connection of the seawall pipeline. The

⁷ EIA for Decommissioning of West Portion of the Middle Ash Lagoon at Tsang Tsui, Tuen Mun (AEIAR-186/2015)

⁸ EIA for Development of Integrated Waste Management Facilities Phase 1 (AEIAR-163-2012)



subsequent connection work would be land-based and undertaken behind the precast concrete block of the modified seawall such that there would be no release of construction material into the sea. There will be no change to the permeability of the geological structures of the Middle and West Ash Lagoons during and after the Project construction. PFA leachate is unlikely to be released from the ash lagoon into the marine environment. PFA leachate seepage from the ash lagoon, if any, would not be much different from the existing baseline condition.

The PFA would remain in the lagoon and would not be disposed of into the marine environment under the Project. Further evaluation of the water quality impact by PFA leaching trials and ecotoxicity test is considered not necessary. No PFA release is anticipated with reference to the proposed construction design and therefore further assessment on PFA leachate release is not required.

5.5.2 Operational Phase

5.5.2.1 Introduction

Potential sources of water quality impacts generated from the operation of the Project include:

- Discharge of saline water from the proposed desalination plant.
- Discharge of spent cooling effluent from the proposed seawater cooling system.
- Changes of hydrodynamics due to the Project discharges and the proposed seawall modification / formation of the permanent berthing facility, which may affect the water quality in Deep Bay.
- Domestic sewage and process wastewater.
- Non-point source surface runoff.
- Maintenance dredging.
- Accidental leakage from delivery of waste and ash to I-PARK2.

5.5.2.2 Discharge from Desalination Plant and Cooling System

5.5.2.2.1 Option A - Air Cooling System

Air Cooling System

Both air-cooled system and once-through seawater cooling system are considered as feasible options in the reference design as discussed in **Section 2**. If air-cooled system is adopted, there would be no effluent discharge from the cooling system of I-PARK2.

Desalination Plant



Desalination plant will be provided in I-PARK2 for freshwater supply. Under Option A without any spent cooling effluent discharge, the seawall outfall for discharge of brine from the proposed desalination plant would be located at Middle Ash Lagoon (namely Outfall Option 1 as shown in in **Exhibit 5-3** below). The brine water drained from the desalination plant is concentrated seawater. Chlorine would be added to the seawater intake of the desalination system for bio-growth control. The brine water together with the Total Residual Chlorine (TRC) would be continuously discharged into the sea at a design effluent flow of about 2,400 m³ per day. Chlorine agent (e.g. sodium hypochlorite etc.) had been considered as suitable antifoulant in the EIA Report of Liquefied Natural Gas (LNG) Receiving Terminal and Associated Facilities (AEIAR-106/2007), which is also considered as a preferable option for this Project. The potential water quality impact arising from the effluent discharge from the proposed desalination plant would include the increase of the salinity and TRC levels in the receiving marine water of Deep Bay.

5.5.2.2 Option B – Once-through Seawater Cooling System

Seawater Cooling System

Once-through seawater cooling system is one of the possible options considered for I-PARK2 as discussed in **Section 2**. The proposed seawater cooling system would discharge spent cooling water with a maximum temperature elevation of 10°C. Chlorine would be used as an anti-fouling agent for the cooling system. Chlorine agent (e.g. sodium hypochlorite etc.) had been considered as suitable antifoulant in the EIA Report of Liquefied Natural Gas (LNG) Receiving Terminal and Associated Facilities (AEIAR-106/2007), which is also considered as a preferable option for this Project.

The proposed seawater intake of I-PARK2 would be the same under both Option A and Option B. The seawater cooling system would utilize the same seawater intake of the proposed desalination plant. The intake would be located at seawall of Middle Ash Lagoon. Two alternative seawall outfall options (namely Outfall Option 2 and Outfall Option 3 as shown in **Exhibit 5-3** below) located at West Ash Lagoon (WAL) are considered for discharge of the spent cooling water. There would be seasonal variation of the daily effluent flow of the proposed seawater cooling system as detailed in **Appendix 5F**. The annual average effluent flow would be about 1.1M m³ per day. The potential water quality impact arising from the spent cooling effluent discharge from the proposed seawater cooling system would include the temperature rise and TRC increase in the receiving water.

Desalination Plant

Under Option B, the proposed desalination plant would utilize the same intake and outfall of the once-through seawater cooling system. Following the same arrangement of the once-through seawater cooling system, two alternative seawall outfall options located at WAL are




considered for discharge of the brine water. Indicative locations of the two seawall outfall options (namely Outfall Option 2 and Outfall Option 3) are shown in **Exhibit 5-3** below.

5.5.2.2.3 Buffer Distances from Seawater Intakes

Under all the proposed options, the Project would only involve seawall intake and seawall outfall only. No submarine outfall and submarine intake would be constructed under the Project. The buffer distances between the new effluent outfall of I-PARK2 and the nearby seawater intakes under the three outfall options are summarized in **Table 5-9**. The shortest distance between the new effluent outfall of I-PARK2 and the closest seawater intake is 300 m, which complied with requirement of >100 m as stipulated in Section 9 of the TM-DSS.

Exhibit 5-3 Alternative Effluent Outfall Options for I-PARK2 and Nearby Seawater Intakes



**Table 5-9 Buffer Distances from Nearby Seawater Intakes**

Alternative Outfall Options of I-PARK2 (see Exhibit 5-3)	Approximate Separation Distances from Effluent Outfall of I-PARK2 (m), see Exhibit 5-3		
	Seawater Intake of I-PARK2	S1 – Existing Seawater Intake of T-PARK	S2b – Existing Seawater Intake of Black Point Power Station
Outfall Option 1	300	750	1790
Outfall Option 2	870	1310	1290
Outfall Option 3	930	1360	1180

5.5.2.2.4 Dechlorination Process

Sodium Metabisulphite (SMBS) may be dosed into the units of desalination and seawater cooling systems for dechlorination as required. SMBS is decayable and non-toxic to aquatic life, and thus, there is no water quality criterion available for SMBS⁹. SMBS is a reducing agent and therefore the key concern would be its potential contribution to an increase in Chemical Oxygen Demand (COD) and possible Dissolved Oxygen (DO) depletion in the water column.

5.5.2.3 Changes of Hydrodynamics and Water Quality

The seawall modification / permanent berthing facility for I-PARK2 would slightly change the coastline configuration of TTAL. Together with the proposed brine and heated cooling water discharges, the Project may change the hydrodynamic regime in Outer Deep Bay. Significant changes of the hydrodynamic conditions may affect the dispersion of pollutants and the water quality in the assessment area.

5.5.2.4 Wastewater Generation

5.5.2.4.1 Introduction

Generally, three types of wastewater would be generated from the Project operation as described below.

5.5.2.4.2 Type 1 Wastewater

Type 1 wastewater would include bunker and ash leachate, wastewater generated from laboratory, vehicle and container washing, washing down from the waste reception facilities (e.g. ramp, unloading platform, weighbridge) as well as the first-flush as described in **Section 5.5.2.5**. In general, Type 1 wastewater would be highly contaminated and are typically very high in organic and ammonia loading. This wastewater stream may contain SS, BOD₅, COD, ammonia, organic contaminants, heavy metals and other toxic contaminants. The estimated quantity of process wastewater with high organic loading (Type 1 wastewater) generated during operation would be approximately 1,250 m³/day.

⁹ EIA for Tseung Kwan O Desalination Plant (AEIAR-192/2015)



5.5.2.4.3 Type 2 Wastewater

Type 2 wastewater, including domestic sewage and wastewater generated from the workshop washing, is considered less polluted.

Domestic sewage includes wastewater generated from the staff and visitors, canteen, and community facilities. It is typically characterized by high levels of organic load, ammonia and *E. coli* counts.

At the workshop area, chemical wastes would be properly removed and stored in chemical cabinet. Wastewater generated from washing the workshop may contain grits, dirt and debris.

It is estimated that approximately 80 m³/day of Type 2 wastewater would be generated during operation phase.

5.5.2.4.4 Type 3 Wastewater

The other type of process wastewater, such as wastewater generated from dehumidification, flue gas washing and blowdown water from plant machinery of the incineration process, may contain trace amount of SS, minerals and metals with low/negligible amount of organic loading. The estimated quantity of process wastewater with low/negligible amount of organic loading (Type 3 wastewater) generated during operation would be approximately 1,670 m³/day.

5.5.2.4.5 Wastewater Management

Introduction

Two options for wastewater treatment and reuse/disposal are proposed as follows:

- **Option 1:** all wastewater generated from the operation of I-PARK2 will be directly-reused / treated and re-used on site with no effluent discharge into the nearby water environment.
- **Option 2:** discharge of treated effluent from I-PARK2 to the marine waters of North Western Water Control Zone (NW WCZ) via Urmston Road Submarine Outfall.

The process flow diagram for wastewater treatment and management of I-PARK2 is presented in **Appendix 5B** and also described as follows (subject to detailed design to be carried out by the future I-PARK2 contractor).

Wastewater Management - Option 1

Type 1 Wastewater

The Type 1 wastewater would be treated by the high strength wastewater treatment facility provided on-site. The tentative design treatment capacity of the high strength wastewater



treatment facility would be 1500 m³/day. The treated effluent from the on-site wastewater treatment facility would meet the tertiary treatment level and all the treated effluent would be reused on-site in the waste treatment process (such as for ash stabilization, flue gas cooling, slag cooling etc.) with no human contact.

Type 2 Wastewater

The domestic sewage and the workshop washing wastewater would be tertiary treated by the low strength wastewater treatment facility provided on-site. The tentative design treatment capacity of the low strength wastewater treatment facility would be 100 m³/day. The treated effluent shall meet the water quality standards specified in the "Technical Specifications on Grey Water Reuse and Rainwater Harvesting" issued by the Water Supplies Department (WSD), as presented in **Table 5-10**, and would be used on-site for beneficial reuse with possible human contact, such as irrigation, toilet flushing and washing (e.g. road washing).

Table 5-10 Water Quality Standards for Treated Grey Water and Rainwater Effluent

Parameters	Unit	Recommended Water Quality Standards
<i>E. coli</i>	cfu /100 ml	Non detectable
Total residual chlorine	mg/l	≥ 1 exiting treatment system; ≥ 0.2 at user end
Dissolved oxygen in reclaimed water	mg/l	≥ 2
Total suspended solids (TSS)	mg/l	≤ 5
Colour	Hazen unit	≤ 20
Turbidity	NTU	≤ 5
pH		6 - 9
Threshold Odour Number (TON)		≤ 100
5-day Biochemical oxygen demand (BOD ₅)	mg/l	≤ 10
Ammoniacal nitrogen (NH ₃ -N)	mg/l as N	≤ 1
Synthetic detergents	mg/l	≤ 5

Notes:

1. Apart from total residual chlorine which has been specified, the water quality standards for all parameters shall be applied at the point-of-use of the system.
2. Where recycled water is treated for immediate usage, the level of total residual chlorine may be lower than the one specified in this table.
3. Immediate usage means the collected grey water/ rainwater is drawn into the treatment process immediate before a particular round of usage and the treated water will be depleted after that round of usage is completed.

Rainwater Harvesting

The harvested roofing rainwater described in **Section 5.5.2.5** would be treated by multimedia filtration, with the design treatment capacity of 100 m³/day, and reused on-site for vehicle and



container washing with possible human contact. The treated roofing rainwater shall meet the water quality standards presented in **Table 5-10**.

Type 3 Wastewater

On the other hand, Type 3 wastewater (e.g. boiler blowdown water) is generated in separate system that is isolated from any MSW or leachate. This type of wastewater would have a low / negligible organic loading, and would be reused directly in the waste treatment processes (such as for ash stabilization, flue gas cooling, slag cooling etc.) with no human contact. Since the raw quality of Type 3 wastewater is considered suitable for reuse in the waste treatment process from the design point of view and the wastewater reuse process will not have any human contact and will not induce any health concern, pre-treatment of Type 3 wastewater prior to the reuse is not proposed.

Wastewater Management - Option 2

Apart from reuse of treated wastewater for non-potable purposes, the option of discharge of treated wastewater outside Deep Bay Water Control Zone has been considered. Near the south boundary of the I-PARK2 site, there is a sewerage system connecting to the DSD Lung Kwu Sheung Tan (LKST) Outfall Chamber, and then the Urmston Road Submarine Outfall, which is located at the North Western Water Control Zone (NW WCZ). It is proposed to make use of the spare capacity of this sewerage system for discharge of treated wastewater from I-PARK2 into NW WCZ via the Urmston Road Submarine Outfall. The quantity of effluent discharge from I-PARK2 to NW WCZ would be about 3,000 m³/day¹⁰. A discharge licence for discharge of effluent from I-PARK2 shall be applied under the WPCO. The quality of effluent discharged from I-PARK2 shall meet the requirements specified in the discharge licence. With reference to the requirements stipulated in Annex 6 of EIAO-TM for effluent discharge into the NW WCZ, secondary treatment plus nitrogen removal and disinfection shall be adopted for the on-site wastewater treatment system under Option 2.

5.5.2.4.6 Identification of Potential Impacts

General

Reuse of treated effluent and treated roofing rainwater generated from the Project will only be applied within the I-PARK2 site and will not be used by general public. Backup power supply in the form of dual power supply or ring main supply or emergency generator(s) would be provided for all on-site wastewater treatment facilities to secure electricity supply. Provision of stand-by power and equipment for the on-site wastewater treatment facilities would prevent

¹⁰ The total quantity of effluent discharge is based on the estimated wastewater generation quantities for Type 1 wastewater (80 m³/day), Type 2 wastewater (1250 m³/day) and Type 3 wastewater (1670 m³ per day) in Sections 5.5.2.4.2 to 5.5.2.4.4 and **Appendix 5B**.



the breaking down of the facilities. Regular maintenance and checking of all on-site wastewater treatment facilities as well as conveying facilities would also be carried out to prevent equipment and pipe failure.

Wastewater Management - Option 1

There will be no discharge of treated or untreated process waters, domestic sewage and first flush into the environment from the I-PARK2 site. The proposed waste reception / treatment related processes and wastewater generation from I-PARK2 would not cause any adverse water quality impact.

Wastewater Management - Option 2

Discharge of effluent via the Urmston Road Submarine Outfall would potentially affect the water quality in the NW WCZ. The effluent discharge flow rate of I-PARK2 would be, on average, less than 0.04 m³/s. The effluent would be discharged to the marine waters of NW WCZ via the Urmston Road Submarine Outfall. The water depth at the Urmston Road Outfall is at least 19 m. The large volume of the receiving marine water and moving tidal current in Urmston Road would continuously dilute and disperse the effluent. Provision of the secondary treatment plus nitrogen removal and disinfection for the effluent discharge would minimize the residual pollutants. Thus, changes of water quality in NW WCZ caused by the Project discharge are expected to be minimal. The potential water quality impacts associated with the treated effluent discharge are further evaluated in **Section 5.7.2.4**.

5.5.2.5 Non-point Source Surface Runoff

Surface runoff to be generated from the Project is known as non-point source pollution. The stormwater that initially runs off the area is called the "first-flush", which contains most of the pollution loads, if any. MSW and leachate could be deposited on the surfaces of the waste reception and treatment facilities within the I-PARK2 site. Most of the waste reception and treatment facilities of this Project have been designed to be covered or located within buildings. The roofing rainwater is generally uncontaminated, and will be harvested and treated for beneficial reuse with possible human contact (see **Section 5.5.2.4.5**). For uncovered paved areas within the Project site for handling / delivery of MSW containers (including the new berthing facility and elevated platform along the northern Project boundary and open vehicular access for MSW delivery trucks), a low flow interceptor drainage system will be provided to intercept the first flush and convey it to the on-site wastewater treatment facility for treatment as a precautionary measure (see **Section 5.5.2.4.5**). As such, pollutants on the uncovered paved areas, if any, would not be washed into the nearby stormwater and inland/marine water systems.



On the other hand, other road runoff within the I-PARK2 site may contain a small amount of oil, grease and grit deposited from vehicles. Surface runoff generated from other paved or developed areas within the I-PARK2 site may also contain debris, refuse, dust. These non-point source surface runoffs may affect the quality of the nearby receiving water environment, if uncontrolled.

5.5.2.6 Maintenance Dredging

Under the current operation, most of the MSW is delivered to the WENT Landfill via marine route. This marine route runs along the shore of TTAL and passes through the seafront of the I-PARK2 site. During the operational phase of I-PARK2, MSW will be delivered to I-PARK2 using the same marine route. Maintenance dredging of the existing marine route to facilitate navigation of waste delivery vessels to and from the proposed berthing facility may be required on an as-needed basis subject to the seabed level, which would be similar to the current operation associated with the WENT Landfill. As only very infrequent maintenance dredging is required to maintain the water depth along the existing marine route, the associated water quality impact would be insignificant. Since the maintenance dredging work is an existing operation, any future maintenance dredging during the I-PARK2 operation would not create any additional water quality impact. The water quality impacts would be similar to those under the existing baseline scenario and therefore, no further assessment on maintenance dredging is considered necessary.

5.5.2.7 Accidental Leakage During Delivery of Waste and Ash

The waste / ash will be placed in containers that are sealed to prevent spillage of the contents during transportation.

The containers shall be in good condition and free from damage or any other defects. Similar to the existing baseline situation, spillage or leakage during the waste / ash delivery is not expected during the operational phase, and further assessment is not required.

5.6 Assessment Methodology

5.6.1 Modelling Tools

5.6.1.1 Modelling Platforms

Mathematical modelling was performed using the hydrodynamic and water quality modelling platforms, namely the D-Flow Flexible Mesh and D-Water Quality of Delft3D Flexible Mesh Suite, developed by Deltares.



The D-Flow Flexible Mesh was applied to simulate the hydrodynamics effects such as the changes of salinity and temperature due to the proposed desalination plant and seawater cooling system of I-PARK2. The cumulative hydrodynamic effects due to the seawall modification / formation of the permanent berthing facility for I-PARK2 were incorporated and assessed using the D-Flow Flexible Mesh.

The D-Water Quality module was used to simulate the dispersion and transportation of sediment plumes, TRC and Sodium Metabisulphite (SMBS) based on the relevant flow fields determined by the D-Flow Flexible Mesh.

5.6.1.2 Model Selection and Development

The Regional Delft3D Flexible Mesh Hong Kong (HK-DFM) Model provided by EPD was employed for this EIA. The HK-DFM Model was developed and verified under the EPD's study "Provision of Consultancy Services for HATS 2A Post Project Monitoring" in 2021. The HK-DFM Model covers Pearl River Estuary, Macau, Ma Wan Channel, Cheung Chau, East Lamma Channel, Victoria Harbour, Tathong Channel, Nine Pin Islands, Po Toi Island, etc. Major influences on hydrodynamics (including the Pearl River discharge, spatio-temporal variations of meteorological forcing and oceanic current in the South China Sea) are incorporated into the HK-DFM Model.

For the purpose of this EIA study, the grid layout of the HK-DFM Model has been refined in the outer Deep Bay to give better representation of the coastline configuration near the Project site. Plots 01 to 03 of **Appendix 5C** shows the grid layout and properties of the refined HK-DFM Model. The refined model has a grid resolution of no greater than 75 m by 75 m at or in the vicinity of the proposed Project works. Additional model grids have been added to cover the Tsang Kok Stream Outfall.

The performance of the refined HK-DFM Model has been verified to be consistent with the performance of the original HK-DFM Model as shown in Plots No. 5 to 14 of **Appendix 5C**. The main purpose of the model performance verification or comparison is to illustrate that the model settings of the refined model were carried out correctly. The same model set-up such as the model bathymetry of the original HK-DFM Model was applied in the refined model for performance verification.

The salinity levels predicted by the refined HK-DFM Model are also compared against the field data collected by EPD at two closest stations (DM4 and DM5) and the comparison results are included in Plot No. 15 to 17 of **Appendix 5C**. For the purpose of checking the model performance, the salinity levels predicted by the refined model are compared with the salinity data measured by EPD in 2021 and 2022 as presented in **Appendix 5C**.



5.6.1.3 Simulation Periods

The hydrodynamics and water quality simulations were conducted using D-Flow Flexible Mesh and D-Water Quality respectively.

For studying the construction phase impact (due to the sand blanket laying) and operational phase impact (due to the thermal and brine discharges), the simulations cover at least one 15-day full spring-neap cycle (excluding the spin-up period) for each of the dry and wet seasons.

A spin-up period of 1 complete calendar year was provided for each simulation for both construction and operational stages.

Spin-up test was conducted by repeating the same on one-year simulation in sequence for three times. The model results for the second year and the third year are compared in **Appendix 5D** for two 15-day spring-neap periods in dry and wet seasons respectively. The comparison showed that the results for the two consecutive years are consistent with each other. Therefore, the spin-up period of 1 complete calendar year is considered sufficient.

The hydrodynamic results generated from the D-Flow Flexible Mesh simulations were used to drive the D-Water Quality simulations.

5.6.1.4 General Model Settings

The general settings of the refined model such as the approach to the setup of boundary and initial conditions as well as the model coefficients and parameters follow those adopted in the original HK-DFM Model provided by EPD.

5.6.1.5 Coastline Configurations

The existing coastline configurations have incorporated all completed or on-going coastal projects such as the Tuen Mun - Chek Lap Kok Link (TM-CLKL), Expansion of Hong Kong International Airport into a Three-Runway System (3RS) and Tung Chung New Town Extension (TCNTE). Additional planned projects that would affect the coastline configurations have also been included in the construction and operational stage modelling as summarized in **Table 5-11**.

Table 5-11 Planned Projects Affecting Coastline Configuration

Modelling Scenario	Year Horizon	Planned Projects Affecting the Coastline	Layout Reference
Construction stage impact scenario	2026	Tsang Kok Stream Outfall Modification for WENTX	Figure 2.2
Operational stage baseline scenario without this Project	2030s	Tsang Kok Stream Outfall Modification for WENTX	Figure 2.2
		Reclamation for Kau Yi Chau Artificial Islands	LC Paper No. CB(1)930/2022(01)



Modelling Scenario	Year Horizon	Planned Projects Affecting the Coastline	Layout Reference
		Reclamation for Road P1	EIA study brief No. ESB-337/2020
		Reclamation for Route 11	EIA Study Brief No. ESB-352/2022
		Lung Kwu Tan Reclamation	EIA Study Brief No. ESB-367/2024
		Tsing Yi - Lantau Link	EIA Study Brief No. ESB-359/2023
Operational stage impact scenario with this Project	2030s	Tsang Kok Stream Outfall Modification for WENTX	Figure 2.2
		Reclamation for Kau Yi Chau Artificial Islands	LC Paper No. CB(1)930/2022(01)
		Reclamation for Road P1	EIA study brief No. ESB-337/2020
		Reclamation for Route 11	EIA Study Brief No. ESB-352/2022
		Lung Kwu Tan Reclamation	LC Paper No. CB(1)141/2023(03)
		Tsing Yi-Lantau Link	EIA Study Brief No. ESB-359/2023
		Proposed Seawall Modification / Berthing Facility for I-PARK2	Figure 5.1

Hydrodynamics effect of existing and planned link road / bridge projects would be minor. Their bridge pier effect on hydrodynamics is not considered in the modelling.

Any further reclamation in the Tseung Kwan O water is over 40 km away from the I-PARK2 site and their effect on the hydrodynamics in Deep Bay is expected to be negligible and are therefore not considered in this modelling exercise.

5.6.1.6 Model Bathymetry

Under this EIA study, the model bathymetry schematization has been updated in accordance with the latest marine charts issued by the Hydrographic Office of Marine Department in 2021. No capital dredging is proposed under this Project. Therefore, the updated model bathymetry representing the existing conditions was adopted for both construction and operational phase modelling.

5.6.2 Construction Phase

5.6.2.1 General Construction Activities

The water quality impacts due to construction site runoff, spent effluent from dust suppression sprays, wastewater generation from land-based construction activities, general refuse, accidental chemical spillage and sewage from construction workforce were assessed using



qualitative approach. Potential sources of water quality impact that may arise during the construction of the Project are described. All the identified sources of potential water quality impact were then evaluated, and their impact significance determined. Mitigation measures to reduce any identified impacts on water quality have been recommended.

5.6.2.2 Seawall Modification / Construction of Permanent Berthing Facility

5.6.2.2.1 Introduction

The possible sediment loss and accidental discharge of cement slurry as well as the possible thermal impact associated with the DCM operation were assessed using qualitative approach with the support of past relevant water quality monitoring data collected for a large-scale DCM project.

Loss of fines from the sand blanket laying to be carried out prior to the DCM operation were assessed quantitatively using the refined HK-DFM Model. The mathematical modelling approach is described in **Section 5.6.2.2.2** to **Section 5.6.2.2.6** below.

5.6.2.2.2 Assessment Criteria

Introduction

The ambient values and tolerance limits for SS, DO and the sediment deposition limit that are relevant to the sand blanket laying work are tabulated for each WSR in **Table 5-12**.

Table 5-12 Assessment Criteria for Construction Phase

Description	ID	Nearest EPD Station	Assessment Water Depth	SS (mg/L)				DO (mg/L)			Sediment Deposition Rate (g/m ² /day)
				Ambient (3)		Allowable Increase		Ambient (3)	WQO (6)	Allowable Depletion	
				Dry Season	Wet Season	Dry Season	Wet Season				
Water Sensitive Receivers											
Seawater Intake of T-Park	S1	DM5	Depth average	12.9	13.5	117.1 ⁽⁴⁾	116.5 ⁽⁴⁾	NA	NA	NA	NA
Seawater Intakes of BBPS	S2a	DM5	Depth average	12.9	13.5	700 ⁽⁵⁾	700 ⁽⁵⁾	NA	NA	NA	NA
	S2b	DM5	Depth average	12.9	13.5	700 ⁽⁵⁾	700 ⁽⁵⁾	NA	NA	NA	NA
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	DM4	Bottom	19	16.7	5.7	5.0	4.33	NA	NA	100
			Surface	15.2	15.0	4.6	4.5	4.73	5	Note (8)	NA
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	DM4	Bottom	19	16.7	5.7	5.0	4.33	NA	NA	100
			Surface	15.2	15.0	4.6	4.5	4.73	5	Note (8)	NA
Sha Chau and Lung Kwu Chau Marine Park	E3	NM5	Depth average	14.7	20.1	4.4	6.0	4.29	4	0.29	NA
Pak Nai SSSI	E4	DM4	Depth average	17.1	14.7	5.1	4.4	4.56	NA	NA	NA
			Surface	15.2	15.0	4.6	4.5	4.73	5	Note (8)	NA



Description	ID	Nearest EPD Station	Assessment Water Depth	SS (mg/L)				DO (mg/L)			Sediment Deposition Rate (g/m ² /day)
				Ambient (3)		Allowable Increase		Ambient (3)	WQO (6)	Allowable Depletion	
				Dry Season	Wet Season	Dry Season	Wet Season				
Traditional Oyster Production Area	F1	DM4	Depth average	17.1	14.7	5.1	4.4	4.56	NA	NA	NA
			Surface	15.2	15.0	4.6	4.5	4.73	5	Note (8)	NA
Mariculture Subzone	F2	DM4	Depth average	17.1	14.7	5.1	4.4	4.56	NA	NA	NA
			Surface	15.2	15.0	4.6	4.5	4.73	5	Note (8)	NA
Important Spawning Ground of Commercial Fisheries Resources	F3	NM5	Depth average	14.7	20.1	4.4	6.0	4.29	4	0.29	NA
Observation Points											
Oyster Culture Activities Outside Mariculture Subzone	O1	DM4	Depth average	17.1	14.7	5.1	4.4	4.56	4	0.56	NA
	O2	DM5	Depth average	12.9	13.5	3.9	4.1	4.47	4	0.47	NA
	O3	DM4	Depth average	17.1	14.7	5.1	4.4	4.56	4	0.56	NA

Notes:

- (1) Details of assessment criteria are also presented in **Section 5.3**.
- (2) Shaded cells represent the proposed assessment criteria for construction phase.
- (3) Ambient level for SS is defined as 90th percentile of monitoring data collected by EPD from 2018 to 2022. The ambient data were analysed and derived for both dry season (November to March) and wet season (April to October). Ambient level for DO is defined as 10th percentile of monitoring data collected by EPD from 2018 to 2022.
- (4) Allowable increase is derived from the subtraction of design water quality of intake specified in **Section 5.3.7.1** by the ambient level.
- (5) Allowable SS increase is specified by the intake operator (see **Appendix 5A**).
- (6) The WQO for DO under the WPCO is a 10%ile value.
- (7) NA: Not applicable.
- (8) Five WSRs (E1, E2, E4, F1 and F2) are located within Mariculture Subzone where the WQO for DO is defined for surface water layer only. No WQO for depth average DO is available. The ambient 10th percentile surface DO level at these WSRs exceeded the WQO. Further DO depletion should be minimized as far as possible.

Suspended Solids Criteria for Ecological and Fisheries Sensitive Receivers

The ambient Suspended Solids (SS) levels are derived using the concentrations measured by EPD during the period from 2018 to 2022 at the stations nearest to the WSRs. With reference to the WQO, any sediment plume generated from the Project shall not cause the ambient SS concentrations to be elevated by more than 30% at any time. It is proposed to analyse the ambient data for both dry season and wet season and define the ambient values for each season as 90th percentile (%ile) of the measured SS levels. The allowable SS increase at the receivers is calculated as 30% of these ambient values.

Suspended Solids Criteria for Seawater Intakes

For the seawater intakes of BBPS, the absolute SS limit of 764 mg/L and a tolerance SS increase of 700 mg/L as specified by their operators are used.

The upper design SS level of 130 mg/L is adopted for the seawater intake of T-Park.



For the seawater intake of CPPS, no SS criteria are specified by the intake operator. The CPPS intake is a distant receiver. This intake is not further considered in the assessment.

Oxygen Depletion at Ecological and Fisheries Sensitive Receivers

According to the WQOs for DO, the measured DO levels can be less than the numerical objective value of 5 mg/L for 10% of samples collected during the whole year. The ambient levels are thus presented as 10%ile of the DO concentrations measured by EPD at the relevant stations during the period from 2018 to 2022, which is a conservative approach. The allowable DO depletion is calculated by subtracting the WQO from the ambient DO level except for the WSRs within Mariculture Subzone (E1, E2, E4, F1 and F2).

The ambient 10%ile level of surface DO for E1, E2, E4, F1 and F2 (4.73 mg/L) as shown in **Table 5-12** is less than the WQO of ≥ 5 mg/L for mariculture subzone. Further DO depletion at these WSRs should be minimized as far as possible.

Oxygen Depletion at Seawater Intakes

The identified seawater intakes within the assessment area are not sensitive to DO depletion. No assessment criterion on DO is available for the intake points.

Sediment Deposition Rate

The absolute sediment deposition criterion of 100 g/m²/day are only applicable to the benthic communities (see **Section 5.3.5**).

5.6.2.2.3 Sediment Loss Rates

Sand Blanket Laying

Sand blanket laying would be carried out to cover the DCM works areas prior to the commencement of the DCM works to prevent loss of sediment and contaminants during the DCM operation. It is assumed that 5% of the fine content in the sand fill would be lost during the sand laying as adopted in all past EIA studies involving sand filling^{11, 12, 13, 14, 15}. The typical fine content and dry density of sand fill is 5% of the bulk and 1680 kg/m³ respectively. All quoted past EIA studies involve either bottom dumping of sand fill or filling by trailer suction hopper dredger (TSHD) discharging sand at a much higher rate. The scale of sand laying for seawall modification / construction of the berthing facility for I-PARK2 is much smaller as

¹¹ EIA for Expansion of Hong Kong International Airport into a Three-Runway System (AEIAR-185/2014)

¹² EIA for Development of Integrated Waste Management Facilities Phase 1 (AEIAR-163-2012)

¹³ EIA for Tuen Mun - Chek Lap Kok Link (AEIAR-146/2009)

¹⁴ EIA for Hong Kong - Zhuhai - Macao Bridge Hong Kong Boundary Crossing Facilities (AEIAR-145/2009)

¹⁵ EIA for Further Development of Tseung Kwan O Feasibility Study (AEIAR-092/2005)



compared to those proposed under the past EIA studies. The sand laying for I-PARK2 would be undertaken at a much smaller rate of 3,000 m³/day by using a closed grab. The closed grab can release the sand at a point near the seabed in a controlled manner. Thus, the proposed spill rate for sand laying is considered appropriate. Assuming a working period of 16 hour per day, the resulted sediment loss rate would be 12,614 kg/day.

DCM Column Installation

During the course of DCM column installation, no sediment loss is anticipated as supported by the recent full-scale DCM monitoring results as discussed in **Section 5.7.1.6.1** below. It is conservatively assumed that 5% of the fine content of the sand blanket within the working area of the DCM rigs would be released into the water environment during the insertion and withdrawal of the piling pile of mixing treatment equipment. In reality, the sand material would only be laterally displaced and would not be significantly disturbed. The marine works area of this Project is minor in scale. A typical working area for each DCM rig with "square four" cluster of DCM columns would be 2.2 m x 2.2 m = 4.84 m², whilst the thickness of sand blanket would be 1 m. Considering that the fines content and density of sand fill is 5% of the bulk and 1680 kg/m³ respectively, the estimated amount of fines to be released during the insertion or withdrawal of piling piles would be 20.328 kg = 4.84 m² (works area) x 1 m (sand thickness) x 1 680 kg/m³ (sand density) x 5% (fines content of sand fill) x 5% (spill rate).

Each DCM installation cycle would typically last for about 80 minutes. Within the daily working period of 16 hours, there would be 12 DCM installation cycles. Each DCM installation cycle would involve 1 insertion and 1 withdrawal of the piling pile. Assuming there would be 10 DCM rigs working concurrently on-site, the sediment loss rate due to insertion and withdrawal of piling piles would be about 4,879 kg/day (=20.328 kg x 24 times per day x 10 DCM rigs).

5.6.2.2.4 Modelling Scenarios

The indicative sequence and phasing of key sediment generating activities are summarized in **Table 5-13**. Sand blanket laying is identified as the key source of sediment release during the marine construction period of the Project. The sediment release for DCM operation is only included for illustration purpose. In reality, no sediment release would be anticipated from the DCM works.



Table 5-13 Indicative Construction Sequence of Key Sediment Generating Marine Activities

Works Area	Marine Construction Activities	Assumption of Concurrent Operating Equipment	Sediment Release Rate (kg/day)											
			Month											
			1	2	3	4	5	6	7	8	9	10	11	12
Middle Ash Lagoon	Sand blanket laying	1 closed grab dredger	12,614											
	DCM Column Installation	10 DCM rigs				4,879								
West Ash Lagoon	Sand blanket laying	1 closed grab dredger						12,614						
	DCM Column Installation	10 DCM rigs									4,879			

Two sediment modelling scenarios, namely Scenario A1 and Scenario A2 respectively, were undertaken. Under Scenario A1, one closed grab (Source ID: G1) is assumed to be working at the shore of Middle Ash Lagoon for sand laying in 2026. Under Scenario A2, one closed grab (Source ID: G2) is assumed to be working at the shore of West Ash Lagoon for sand laying in 2027. The sediment release points and the calculation of sediment loss rates are shown in **Appendix 5E**.

5.6.2.2.5 Modelling Parameters

The general parameters adopted for sediment plume modelling are as follows:

- Settling velocity – 0.5 mm/s
- Critical shear stress for deposition – 0.2 N/m²
- Critical shear stress for erosion – 0.3 N/m²
- Minimum depth where deposition allowed – 0.1 m
- Resuspension rate – 30 g/m²/d

The above parameters including the settling velocity of 0.5 mm/s have been adopted in numerous past studies in Hong Kong.^{16, 17, 18, 19, 20, 21, 22} With reference to these past studies, the critical shear stress values for erosion and deposition were determined by laboratory testing of a large sample of marine mud from Hong Kong as part of the WAHMO²³ studies associated with the new airport at Chek Lap Kok.

¹⁶ Environmental Assessment (EA) Study for Backfilling of Marine Borrow Pits at North of the Brothers. EA Report, 2002.

¹⁷ Permanent Aviation Fuel Facility. EIA Report, 2002 (for Environmental Permit EP-139/2002)

¹⁸ EIA for Hong Kong Offshore Wind Farm in Southeastern Water (AEIAR-140/2009)

¹⁹ EIA for Development of a 100MW Offshore Wind Farm in Hong Kong (AEIAR-152/2010)

²⁰ EIA for Additional Gas-fired Generation Units Project (AEIAR-197/2016)

²¹ EIA for Hong Kong Offshore LNG Terminal (AEIAR-218/2018)

²² EIA for New Contaminated Sediment Disposal Facility to the West of Lamma Island (AEIAR-241/2022)

²³ Water Quality and Hydraulic Mathematical Models (WAHMO) - the first set of comprehensive mathematical models for simulation of hydrodynamics, water quality, waves, and sediment movement in Hong Kong waters.



5.6.2.2.6 Consideration of Concurrent Projects

The Modification of Tsang Kok Stream Outfall under the proposed WENT Landfill Extension would be commenced tentatively in 2024. The marine construction work under the proposed WENT Landfill Extension is anticipated to be substantially completed before the commencement of the marine construction work of I-PARK2, therefore no adverse cumulative water quality impact arising from marine construction work is predicted.

5.6.3 Operational Phase

5.6.3.1 Discharges from Desalination Plant and Seawater Cooling System / Changes of Coastline Due to Proposed Seawall Modification / Berthing Facility

5.6.3.1.1 Assessment Criteria

The WQOs for temperature and salinity as well as the USEPA standards for TRC are adopted as the assessment criteria for ecological and fisheries receivers.

The design temperature range provided by the intake operator is adopted for the seawater intake of T-Park. No TRC and salinity criteria are specified for the seawater intakes of T-Park and therefore, this intake is not further considered in the salinity and TRC assessment.

No intake criteria on temperature, salinity and TRC are available for the seawater intakes of BPPS and CPPS as specified by their intake operators. These intakes are therefore not further considered in the operational phase assessment.

The assessment criteria for operational phase are summarized in **Table 5-14**.

.



Table 5-14 Assessment Criteria for Operational Phase

Description	ID	Assessment Water Depth	Temperature (°C)	Salinity (%)	TRC (mg/L)	
					Chronic Criterion (4-day average)	Acute Criterion (1-hour average)
Water Sensitive Receivers						
Intake of T-Park	S1	Mid-depth	31	NA	NA	NA
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	Change ≤ 2	Change ≤ 10	0.0075	0.013
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	Change ≤ 2	Change ≤ 10	0.0075	0.013
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
Pai Nai SSSI	E4	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
Traditional Oyster Production Area	F1	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
Mariculture Subzone	F2	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
Observation Points						
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
	O2	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013
	O3	Depth average	Change ≤ 2	Change ≤ 10	0.0075	0.013

Notes:

Details of the assessment criteria are presented in **Section 5.3**.

NA – Not available

The possible DO depletion caused by the SMBS (if any) in the discharges of the Project are evaluated with reference to the allowable DO depletion adopted for the construction phase as shown in **Table 5-27**.

5.6.3.1.2 Modelling Scenarios

Three modelling scenarios were simulated to predict the changes of hydrodynamics and water quality as follows.

Scenario B1: Baseline scenario without I-PARK2 in 2030s.

Scenario B2: Impact scenario with I-PARK2 in 2030s using Outfall Option 1.

Scenario B3: Impact scenario with I-PARK2 in 2030s using Outfall Option 2.

Scenario B4: Impact scenario with I-PARK2 in 2030s using Outfall Option 3.

Major seawater intakes and outfalls of other industrial establishments including T-Park, BPPS and CPPS are included in all the four scenarios for cumulative impact assessment. Scenarios B2, B3 and B4 have also incorporated the effect of seawater intake and outfall systems of



I-PARK2 as well as the change of coastline configuration due to the proposed seawall modification / berthing facility.

Under Scenario B2, air-cooled system is assumed to be adopted for I-PARK2 and therefore only brine discharge at the seawall of Middle Ash Lagoon (Outfall Option 1) would be involved during the Project operation.

If once-through seawater cooling system is selected for I-PARK2, two alternative seawall outfall locations at the West Ash Lagoon (Outfall Option 2 and Outfall Option 3) are considered under Scenario B3 and Scenario B4 respectively. The desalination plant and seawater cooling system of I-PARK2 will share the same intake and outfall locations. The design seawater intake rate and effluent flow of the desalination plant would be approximately 4,000 m³/day and 2,400 m³/day respectively. The design discharge rates of the seawater cooling system would be equal to the design intake flow rates of the cooling system, which would vary seasonally.

The intake and outfall assumptions adopted in the modelling exercise are described in **Appendix 5F**.

The TRC was modelled as decayable tracer with decay value $T_{90} = 8289s$. The same TRC decay rate was adopted in other past EIAs with similar discharges^{24, 25, 26, 27, 28}.

The model results are compared between Scenario B1, Scenario B2, Scenario B3 and Scenario B4 to predict the changes of salinity and temperature and TRC increase due to this Project. Changes of permanent flow regime are assessed by comparing the model results between the scenarios in terms of the tidal flow rates across the Outer Deep Bay as well as the flow vectors and current speeds in the assessment area.

5.6.3.2 Other Water Pollution Sources

Other potential sources of water quality impacts that may arise during the operational phase (including wastewater generation and non-point source surface runoff) were qualitatively evaluated and their impact significance determined (see **Section 5.7.2.3**, **Section 5.7.2.5** and **Appendix 5J**). Mitigation and design measures to reduce any identified water quality impacts was also determined and recommended.

²⁴ EIA for Tai Po Sewage Treatment Works Stage V (AEIAR-081/2004)

²⁵ EIA for Harbour Area Treatment Scheme Stage 2A (AEIAR-121/2008)

²⁶ EIA for Kai Tak Development (AEIAR-130/2009)

²⁷ EIA for Hong Kong Section of Guangzhou - Shenzhen - Hong Kong Express Rail Link (AEIAR-143/2009)

²⁸ EIA for Additional Gas-fired Generation Units Project (AEIAR-197/2016)



5.7 Evaluation of Potential Impacts

5.7.1 Construction Phase

5.7.1.1 Construction Site Runoff and Dust Suppression Sprays

Runoff would be generated from the construction works area. The potential sources of pollution include runoff and erosion from exposed soil/PFA surfaces, earth working areas and stockpiles; as well as wash water from dust suppression sprays. All temporarily exposed surfaces, dusty stockpiles and earth working areas should be securely covered immediately after the works have been completed to prevent soil/PFA erosion. Earthwork final surfaces should be well compacted and subsequent permanent work or surface protection should be immediately performed.

Relevant mitigation measures outlined in ProPECC PN 2/23 "Construction Site Drainage" should be implemented to control construction site runoff and drainage from the works areas, and to prevent runoff and drainage water with high levels of SS from entering the nearby water bodies. The construction site runoff and spent dust suppression sprays should be collected by the temporary drainage system installed by the Contractor and then treated on-site before discharging into the storm drains via silt removal facilities. The treated discharges shall meet the respective effluent standards applicable to the receiving waters as set out in the TM-DSS. No adverse water quality impact would be anticipated provided that all mitigation measures recommended in **Section 5.8.1.1** and **Section 5.8.1.4** are properly implemented.

5.7.1.2 Wastewater from General Land-based Construction Activities

Land-based construction activities may generate wastewater such as boring and drilling effluent and wheel washing water. Their impacts are likely to be minimal, provided that good construction practices and proper site management would be observed and implemented. Effluent discharge from temporary site facilities should be controlled to prevent direct discharge to the neighbouring water environment. It is anticipated that water quality impacts caused by wastewater generation from land-based construction activities would be insignificant with adequate implementation of recommended mitigation measures in **Section 5.8.1.2** and **Section 5.8.1.4**.

5.7.1.3 General Refuse

Good housekeeping measures and regular refuse collection programme should be adopted to mitigate the potential water quality impact associated with the refuse generation in construction site. With proper implementation of the recommended mitigation measures and good site practices in **Section 5.8.1.3**, there would be no adverse water quality impacts due to refuse generation.



5.7.1.4 Accidental Chemical Spillage

All chemicals should be handled, stored and disposed properly to avoid and contain spillage. Good construction practices should be implemented to prevent accidental spillage from maintenance activities. With proper implementation of all mitigation measures recommended in **Section 5.8.1.5**, no adverse water quality impacts would arise.

5.7.1.5 Sewage Effluent from Construction Workforce

Based on the Drainage Services Department (DSD) Sewerage Manual, the sewage production rate for construction workers is estimated at 0.35 m³ per worker per day. For every 100 construction workers working simultaneously at the construction site, about 35 m³ of sewage would be generated per day. Sewage generated from construction workforce can be adequately treated by interim sewage treatment facilities, such as portable chemical toilets, which can be installed within the construction site. No discharge of sewage effluent into the environment will be allowed under this Project.

Provided that sewage is not discharged directly into storm drains or inland/marine waters adjacent to the construction site, and temporary sanitary facilities are serviced and properly maintained by a licensed waste collector as recommended in **Section 5.8.1.6**, sewage generated from the site would not cause any adverse water quality impact.

5.7.1.6 Seawall Modification / Construction of Permanent Berthing Facility

5.7.1.6.1 Deep Cement Mixing (DCM)

The DCM method enables *in-situ* stabilisation of the underlying materials of the proposed seawall modification / berthing facility. It is capable to treat sediment in deep layer without excavation, dredging, shoring or dewatering, and thus there is less exposure of wastes to the water environment.

By deployment of silt curtain and placing the sand blanket layer on top of the DCM works areas before the DCM treatment, release of fines and cement slurry from the DCM operation would be negligible.

The piling pipe of the DCM equipment would contact the longitudinal surface of the materials to be treated. Any heat dissipation from the exothermic process of DCM would largely occur within the materials immediately surrounding the DCM column, which is beneath the seabed. Any minor heat dissipation from the top of DCM columns will be absorbed by the sand blanket laid above the DCM columns. Thermal impact due to DCM would be negligible.

The DCM method has been proven and adopted in Hong Kong. Recent DCM applications include the foundation of breakwater and seawall around the artificial island for development



of Integrated Waste Management Facilities Phase 1 (I-PARK1) at Shek Kwu Chau. Marine water quality monitoring was conducted under the I-PARK1 during the DCM trials held in July, September, October and December 2018 and the full-scale DCM conducted within the period from February 2019 to October 2020²⁹. Salinity, pH, DO, turbidity, temperature, SS and total alkalinity were monitored in locations close to the artificial island, at representative WSRs and control stations further away. The monitoring has demonstrated that there were no adverse water quality impacts associated with the DCM. Elevated pollution levels due to the DCM works were not recorded.

According to approved EIA for Expansion of Hong Kong Airport into a Three-Runway System (3RS) (AEIAR-185/2014), overseas application and the local site trial of DCM held in February 2012 has demonstrated that there was no adverse water quality impact associated with the DCM installation works. This was further confirmed after the approval of the EIA for 3RS under both the intensive DCM water quality monitoring and regular DCM monitoring for full-scale DCM applications in 3RS between 2017 and 2019.

The scale of DCM works proposed under this Project is minimal as compared to the seawall construction for I-PARK1. Based on the past monitoring results, no adverse water quality impact is expected from the small-scale DCM works for I-PARK2.

5.7.1.6.2 Sand Blanket Laying

Elevation of SS and Sedimentation under Unmitigated Scenario

Loss of fines could arise from the proposed sand blanket laying work and the associated water quality impact was quantitatively assessed by mathematical modelling.

Two sediment dispersion modelling scenarios, namely Scenario A1 and Scenario A2, were simulated as defined in **Appendix 5E** and **Section 5.6.2.2.4**. The results for SS elevations and sedimentation rates predicted at the representative WSRs under the two unmitigated scenarios are presented in **Table 5-15** and **Table 5-16**. The distant intake of CPPS is not considered as no SS criteria are available for this intake.

²⁹ Website of EM&A data for FEP-01/429/2012/A / EP-429/2012/A - Development of the Integrated Waste Management Facilities Phase 1 (https://www.epd.gov.hk/eia/english/register/index7/fep1772017_content.html)



Table 5-15 Predicted SS Elevations and Sedimentation Rates – Unmitigated Scenario A1

Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Water Sensitive Receivers									
Intake of T-Park	S1	Depth average	117.1	6.8477	116.5	8.0821	-	-	-
Intakes of BBPS	S2a	Depth average	700	0.3548	700	0.4472	-	-	-
	S2b	Depth average	700	0.7390	700	0.5367	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	5.7	0.1894	5.0	0.3563	100	5.107	11.489
		Surface, Note 1	4.6	0.1036	4.5	0.3246	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	5.7	<0.0001	5.0	0.0092	100	<0.001	0.305
		Surface, Note 1	4.6	<0.0001	4.5	0.0082	-	-	-
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	4.4	0.0080	6.0	0.0036	-	-	-
Pai Nai SSSI	E4	Depth average	5.1	<0.0001	4.4	0.0080	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.0071	-	-	-
Traditional Oyster Production Area	F1	Depth average	5.1	<0.0001	4.4	0.0287	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.0245	-	-	-
Mariculture Subzone	F2	Depth average	5.1	0.0192	4.4	0.0508	-	-	-
		Surface, Note 1	4.6	0.0156	4.5	0.0440	-	-	-
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	4.4	0.0074	6.0	0.0155	-	-	-
Observation Points									
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	5.1	0.0660	4.4	0.0974	-	-	-
	O2	Depth average	3.9	0.9752	4.1	1.2952	-	-	-
	O3	Depth average	5.1	0.2282	4.4	0.9521	-	-	-

Note:

- Five WSRs (E1, E2, E4, F1 and F2) are located within the Mariculture Subzone where the WQO for DO is only available for surface water layer. Predicted SS elevations for surface layer are therefore included for these WSRs to provide information for the assessment of DO depletion at the surface water layer for comparison with the WQO for DO.
- Locations of WSRs are shown in **Figure 5.2** with corresponding ID.
- S3 is not included as there is no SS criteria specified by the intake operator as mentioned in **Section 5.6.2.2.2**.



Table 5-16 Predicted SS Elevations and Sedimentation Rates – Unmitigated Scenario A2

Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Water Sensitive Receivers									
Intake of T-Park	S1	Depth average	117.1	2.0232	116.5	2.2962	-	-	-
Intakes of BBPS	S2a	Depth average	700	0.7956	700	0.6590	-	-	-
	S2b	Depth average	700	1.2561	700	1.0020	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	5.7	0.0411	5.0	0.3063	100	1.133	9.977
		Surface, Note 1	4.6	0.0186	4.5	0.2796	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	5.7	<0.0001	5.0	0.0048	100	<0.001	0.156
		Surface, Note 1	4.6	<0.0001	4.5	0.0042	-	-	-
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	4.4	0.0127	6.0	0.0050	-	-	-
Pai Nai SSSI	E4	Depth average	5.1	<0.0001	4.4	0.0039	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.0035	-	-	-
Traditional Oyster Production Area	F1	Depth average	5.1	<0.0001	4.4	0.0133	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.0116	-	-	-
Mariculture Subzone	F2	Depth average	5.1	0.0552	4.4	0.0659	-	-	-
		Surface, Note 1	4.6	0.0458	4.5	0.0530	-	-	-
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	4.4	0.0147	6.0	0.0140	-	-	-
Observation Points									
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	5.1	0.3770	4.4	0.4100	-	-	-
	O2	Depth average	3.9	2.3998	4.1	2.1606	-	-	-
	O3	Depth average	5.1	1.2693	4.4	1.1616	-	-	-

Note:

- Five WSRs (E1, E2, E4, F1 and F2) are located within the Mariculture Subzone where the WQO for DO is only available for surface water layer. Predicted SS elevations for surface layer are therefore included for these WSRs to provide information for the assessment of DO depletion at the surface water layer for comparison with the WQO for DO.
- Locations of WSRs are shown in **Figure 5.2** with corresponding ID.
- S3 is not included as there is no SS criteria specified by the intake operator as mentioned in **Section 5.6.2.2.2**.

Full compliances for SS elevations and sedimentation rates are predicted at the WSRs and observation points under the unmitigated scenarios. The contour maps of SS elevations and sedimentation rates under the unmitigated scenarios are presented in **Appendix 5G**, which



showed that the sediment plume would be localized. The SS elevations and sedimentation caused by the small-scale sand blanket laying work are considered insignificant and transient.

The contour maps in **Appendix 5G** illustrate that the sediment plume generated under Scenario A2 (due to sediment release at WAL) would disperse more towards the observation points (O1 to O3) as compared to the release at MAL under Scenario A1. Under Scenario A1, the sediment plume would disperse more to the east and to the west. Less sediment is therefore diffused towards the nearest observation points (O1 to O3) in the north.

Secondary contact recreation subzone is located within the assessment area and could involve water sports activities such as boating and sailing. These activities may involve direct water contact but the chance of swallowing the water is unlikely. Significant water quality impact upon the users of the secondary contact recreation subzone due to the transient SS increases is not anticipated.

Elevation of SS and Sedimentation under Mitigated Scenarios

As a precautionary measure, a single layer of silt curtain is recommended to be deployed around the DCM and sand blanket laying works of this Project. As discussed in **Section 5.5.1.7**, a single layer of silt curtain would have a SS removal efficiency of 75%. The mitigated SS elevations and sedimentation rates with consideration of the silt curtain deployment would be further minimized as presented in **Table 5-17** and **Table 5-18**.

Table 5-17 Predicted SS Elevations and Sedimentation Rates – Mitigated Scenario A1

Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Water Sensitive Receivers									
Intake of T-Park	S1	Depth average	117.1	1.711925	116.5	2.020525	-	-	-
Intakes of BBPS	S2a	Depth average	700	0.0887	700	0.1118	-	-	-
	S2b	Depth average	700	0.18475	700	0.134175	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	5.7	0.04735	5.0	0.089075	100	1.277	2.872
		Surface, Note 1	4.6	0.0259	4.5	0.08115	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	5.7	<0.0001	5.0	0.0023	100	<0.001	0.076
		Surface, Note 1	4.6	<0.0001	4.5	0.00205	-	-	-
Sha Chau and Lung Kwu	E3	Depth average	4.4	0.002	6.0	0.0009	-	-	-



Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Chau Marine Park									
Pai Nai SSSI	E4	Depth average	5.1	<0.0001	4.4	0.002	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.001775	-	-	-
Traditional Oyster Production Area	F1	Depth average	5.1	<0.0001	4.4	0.007175	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.006125	-	-	-
Mariculture Subzone	F2	Depth average	5.1	0.0048	4.4	0.0127	-	-	-
		Surface, Note 1	4.6	0.0039	4.5	0.011	-	-	-
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	4.4	0.00185	6.0	0.003875	-	-	-
Observation Points									
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	5.1	0.0165	4.4	0.02435	-	-	-
	O2	Depth average	3.9	0.2438	4.1	0.3238	-	-	-
	O3	Depth average	5.1	0.05705	4.4	0.238025	-	-	-

Note:

- Five WSRs (E1, E2, E4, F1 and F2) are located within the Mariculture Subzone where the WQO for DO is only available for surface water layer. Predicted SS elevations for surface layer are therefore included for these WSRs to provide information for the assessment of DO depletion at the surface water layer for comparison with the WQO for DO.
- Locations of WSRs are shown in **Figure 5.2** with corresponding ID.
- S3 is not included as there is no SS criteria specified by the intake operator as mentioned in **Section 5.6.2.2.2**.

Table 5-18 Predicted SS Elevations and Sedimentation Rates – Mitigated Scenario A2

Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Water Sensitive Receivers									
Intake of T-Park	S1	Depth average	117.1	0.5058	116.5	0.57405	-	-	-
Intakes of BBPS	S2a	Depth average	700	0.1989	700	0.16475	-	-	-
	S2b	Depth average	700	0.314025	700	0.2505	-	-	-
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	5.7	0.010275	5.0	0.076575	100	0.283	2.494
		Surface, Note 1	4.6	0.00465	4.5	0.0699	-	-	-
Mudflat / Seagrass / Horseshoe	E2	Bottom	5.7	<0.0001	5.0	0.0012	100	<0.001	0.039



Description	ID	Water Depth	Maximum SS Elevation (mg/L)				Maximum Sediment Deposition (g/m ² /day)		
			Dry Season		Wet Season		Criteria	Dry Season	Wet Season
			Criteria	Predicted Level	Criteria	Predicted Level			
Crab at Sheung Pak Nai		Surface, Note 1	4.6	<0.0001	4.5	0.00105	-	-	-
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	4.4	0.003175	6.0	0.00125	-	-	-
Pai Nai SSSI	E4	Depth average	5.1	<0.0001	4.4	0.000975	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.000875	-	-	-
Traditional Oyster Production Area	F1	Depth average	5.1	<0.0001	4.4	0.003325	-	-	-
		Surface, Note 1	4.6	<0.0001	4.5	0.0029	-	-	-
Mariculture Subzone	F2	Depth average	5.1	0.0138	4.4	0.016475	-	-	-
		Surface, Note 1	4.6	0.01145	4.5	0.01325	-	-	-
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	4.4	0.003675	6.0	0.0035	-	-	-
Observation Points									
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	5.1	0.09425	4.4	0.1025	-	-	-
	O2	Depth average	3.9	0.59995	4.1	0.54015	-	-	-
	O3	Depth average	5.1	0.317325	4.4	0.2904	-	-	-

Note:

- Five WSRs (E1, E2, E4, F1 and F2) are located within the Mariculture Subzone where the WQO for DO is only available for surface water layer. Predicted SS elevations for surface layer are therefore included for these WSRs to provide information for the assessment of DO depletion at the surface water layer for comparison with the WQO for DO.
- Locations of WSRs are shown in **Figure 5.2** with corresponding ID.
- S3 is not included as there is no SS criteria specified by the intake operator as mentioned in **Section 5.6.2.2.2**.

Oxygen Depletion

The maximum Chemical Oxygen Demand (COD) of the sediment samples collected by EPD in 2022 at the outer Deep Bay (DS3 and DS4 as shown in **Figure 5.2**) was used to determine the reductions in Dissolved Oxygen (DO) concentration, based on the predicted increases in SS concentrations at the WSRs and observation points in accordance with the following equation:

$$DO_{DEP} = C * COD_{sed} * K * 10^{-6}$$

where DO_{DEP} = DO depletion (mg/L)



C = Predicted maximum SS concentration under mitigated scenario in **Table 5-17** and **Table 5-18**

COD_{sed} = Maximum COD in sediment (18,000 mg/kg) measured by EPD in 2022 at outer Deep Bay

K = Daily oxygen uptake factor (set as 1)

This approach is a highly conservative prediction since the sand material to be laid under the Project is uncontaminated. The daily oxygen uptake factor, K, is set to be 1, which implies instantaneous oxidation of the COD. This is also a very adverse prediction of DO depletion since oxygen depletion is not instantaneous. It is worth noting that the above equation does not account for re-aeration which tends to reduce the SS impacts on the DO concentrations.

The predicted DO results for ecological sensitive receivers (E1 to E4), fisheries sensitive receivers (F1 to F3) and observation points (O1 to O3) are tabulated in **Table 5-19** and **Table 5-20**. The seawater intakes (S1, S2a, S2b and S3) identified in the assessment area are not sensitive to DO depletion and therefore not considered. The maximum DO depletions predicted at all WSRs are <0.01 mg/L, which is considered minimal. The maximum DO depletion amongst the observation points is about 0.01 mg/L, and the resulted DO levels fully complied with the WQO. No adverse DO impact would arise from the Project construction.



Table 5-19 Predicted DO Levels – Mitigated Scenario A1

Description	ID	Water Depth	DO mg/L			
			WQO (10%ile)	Ambient Level (10%ile)	Predicted Maximum Depletion	Resulted Level
			(A)	(B)	(C)	(D)
Water Sensitive Receivers						
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	NA	4.33	0.0016	4.33
		Surface	≥ 5	4.73	0.0015	4.73
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	NA	4.33	<0.0001	4.33
		Surface	≥ 5	4.73	<0.0001	4.73
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	≥ 4	4.29	<0.0001	4.29
Pai Nai SSSI	E4	Depth average	NA	4.56	<0.0001	4.56
		Surface	≥ 5	4.73	<0.0001	4.73
Traditional Oyster Production Area	F1	Depth average	NA	4.56	0.0001	4.56
		Surface	≥ 5	4.73	0.0001	4.73
Mariculture Subzone	F2	Depth average	NA	4.56	0.0002	4.56
		Surface	≥ 5	4.73	0.0002	4.73
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	≥ 4	4.29	<0.0001	4.29
Observation Points						
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	≥ 4	4.56	0.0004	4.56
	O2	Depth average	≥ 4	4.47	0.0058	4.46
	O3	Depth average	≥ 4	4.56	0.0043	4.56

Notes:

- (A) The WQO for DO is a 10%ile value over the year. Five WSRs (E1, E2, E4, F1 and F2) are located within Mariculture Subzone where the WQO for DO is available for surface water layer only.
- (B) The ambient level is presented as 10%ile of the DO concentrations measured by EPD at the closest stations during the period from 2018 to 2022.
- (C) The DO depletion is calculated using the maximum SS elevation over the dry and wet season under the mitigated scenario in **Table 5-17**.
- (D) The resulted DO level = Column (B) – Column (C).

Table 5-20 Predicted DO Levels – Mitigated Scenario A2

Description	ID	Water Depth	DO mg/L			
			WQO (10%ile)	Ambient Level (10%ile)	Predicted Maximum Depletion	Resulted Level
			(A)	(B)	(C)	(D)
Water Sensitive Receivers						
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	NA	4.33	0.0014	4.33
		Surface	≥ 5	4.73	0.0013	4.73
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	NA	4.33	<0.0001	4.33
		Surface	≥ 5	4.73	<0.0001	4.73
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	≥ 4	4.29	<0.0001	4.29
Pai Nai SSSI	E4	Depth average	NA	4.56	<0.0001	4.56
		Surface	≥ 5	4.73	<0.0001	4.73
Traditional Oyster Production Area	F1	Depth average	NA	4.56	0.0001	4.56
		Surface	≥ 5	4.73	0.0001	4.73
Mariculture Subzone	F2	Depth average	NA	4.56	0.0003	4.56
		Surface	≥ 5	4.73	0.0002	4.73



Description	ID	Water Depth	DO mg/L			
			WQO (10%ile)	Ambient Level (10%ile)	Predicted Maximum Depletion	Resulted Level
			(A)	(B)	(C)	(D)
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	≥ 4	4.29	<0.0001	4.29
Observation Points						
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	≥ 4	4.56	0.0018	4.56
	O2	Depth average	≥ 4	4.47	0.0108	4.46
	O3	Depth average	≥ 4	4.56	0.0057	4.55

Notes:

- (E) The WQO for DO is a 10%ile value over the year. Five WSRs (E1, E2, E4, F1 and F2) are located within Mariculture Subzone where the WQO for DO is available for surface water layer only.
- (F) The ambient level is presented as 10%ile of the DO concentrations measured by EPD at the closest stations during the period from 2018 to 2022.
- (G) The DO depletion is calculated using the maximum SS elevation over the dry and wet season under the mitigated scenario in **Table 5-18**.
- (H) The resulted DO level = Column (B) – Column (C).

5.7.1.6.3 Summary

Provided that the good construction design measures and good site practices as recommended in **Section 5.8.1.7** and **Section 5.8.1.8** are properly followed, no adverse water quality impact is expected from the seawall modification / construction of berthing facility including the proposed DCM and sand blanket laying work.

5.7.2 Operational Phase

5.7.2.1 Discharges from Desalination Plant and Seawater Cooling System

5.7.2.1.1 Introduction

Four modelling scenarios, namely Scenario B1, Scenario B2, Scenario B3 and Scenario B4 were simulated to address the potential impacts due to the discharges of brine and spent cooling effluent as defined in **Section 5.6.3.1.2** and **Appendix 5F**. The parameters of concern include TRC, salinity and temperature. The concurrent discharges from T-PARK, BPPS and CPPS are also considered in the modelling for water quality impact assessment. To protect the health of the users of the secondary contact recreation subzone, an *E. coli* objective is specified for the subzone under the WPCO. Since the Project operation will not induce any *E. coli* or bacterial loading to the marine water and the transient users of the subzone are considered less sensitive to the TRC, salinity and water temperature increases, impact upon the secondary contact recreation subzone is not further assessed.



5.7.2.1.2 Total Residual Chlorine (TRC)

The predicted TRC levels for Scenarios B1, B2, B3 and B4 are tabulated in **Table 5-21** and **Table 5-22** for ecological and fisheries sensitive receivers (E1 to E4, F1 to F3) and observation points (O1 to O3). The seawater intakes (S1, S2a, S2b and S3) identified in the assessment area are not sensitive to the TRC increase and therefore not considered.

The maximum cumulative TRC levels predicted at the representative WSRs and observation points under all scenarios are 0.0016 mg/L (4-day average) and 0.0105 mg/L (1-hour average), which complied with the criteria of 0.0075 mg/L and 0.013 mg/L respectively. The model contour maps in **Appendix 5H-1** showed that the average TRC plume sizes due to the cumulative effect of this Project and other concurrent projects under both alternative outfall options are localized. The TRC impact is considered acceptable.

Table 5-21 Predicted Maximum 4-day Average TRC Levels

Description	ID	Water Depth	Maximum 4-day Average TRC (mg/L)							
			Scenario B1 Baseline Scenario without I-PARK2		Scenario B2 Impact Scenario with I-PARK2 – Outfall Option 1		Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
			Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season
Assessment Criterion:			0.0075							
Water Sensitive Receivers										
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Pak Nai SSSI	E4		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Traditional Oyster Production Area	F1		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Mariculture Subzone	F2		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Important Spawning Ground of Commercial Fisheries Resources	F3		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Observation Points										
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	<0.0001	0.0001	<0.0001	0.0001	0.0001	0.0002	0.0001	0.0002
	O2		0.0008	0.0008	0.0008	0.0008	0.0016	0.0015	0.0012	0.0013
	O3		0.0002	0.0003	0.0002	0.0003	0.0005	0.0006	0.0004	0.0005



Table 5-22 Predicted Maximum 1-hour Average TRC Levels

Description	ID	Water Depth	Maximum 1-hour Average TRC (mg/L)							
			Scenario B1 Baseline Scenario without I-PARK2		Scenario B2 Impact Scenario with I-PARK2 – Outfall Option 1		Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
			Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season
Assessment Criterion:			0.013							
Water Sensitive Receivers										
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	0.0002	<0.0001	0.0001
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Pak Nai SSSI	E4		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Traditional Oyster Production Area	F1		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Mariculture Subzone	F2		0.0001	0.0002	0.0001	0.0002	0.0002	0.0003	0.0002	0.0002
Important Spawning Ground of Commercial Fisheries Resources	F3		<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001
Observation Points										
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	0.0010	0.0014	0.0010	0.0014	0.0015	0.0023	0.0017	0.0023
	O2		0.0059	0.0055	0.0059	0.0054	0.0103	0.0105	0.0082	0.0090
	O3		0.0022	0.0028	0.0021	0.0026	0.0041	0.0043	0.0038	0.0042

5.7.2.1.3 Temperature

Ecological and Fisheries Sensitive Receivers

No thermal impact would arise under Scenario B2 with the use of air-cooled system. The predicted temperature elevations due to the once-through seawater cooling system under Scenarios B3 and B4 are tabulated in **Table 5-23** for ecological and fisheries sensitive receivers (E1 to E4, F1 to F3) and observation points (O1 to O3) for comparison with the WQO of no more than 2 °C. Full WQO compliances are predicted at all WSRs and observation points. The maximum temperature rise in dry and wet seasons predicted at these WSRs and observation points is 1.1 °C. The model contour maps given in **Appendix 5H-2** showed that the average thermal plume sizes induced by the Project would be localized. No adverse temperature impact is predicted.



Table 5-23 Predicted Temperature Elevations

Description	ID	Water Depth	Temperature Elevation (°C), Note (1)			
			Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
			Dry Season	Wet Season	Dry Season	Wet Season
WQO:			≤ 2			
Water Sensitive Receivers						
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	0.1	0.8	0.1	0.7
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2		<0.1	0.2	<0.1	0.2
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	0.1	<0.1	0.1	<0.1
Pai Nai SSSI	E4		<0.1	0.2	<0.1	0.2
Traditional Oyster Production Area	F1		<0.1	0.3	<0.1	0.2
Mariculture Subzone	F2		0.4	0.3	0.3	0.2
Important Spawning Ground of Commercial Fisheries Resources	F3		0.1	<0.1	0.1	0.1
Observation Points						
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	0.4	0.3	0.4	0.3
	O2		1.0	0.8	1.1	0.7
	O3		1.1	0.7	1.0	0.7

Note:

- (1) Temperature elevation represents the change in daily temperature range caused by this Project (i.e. Scenario B3 over Scenario B1 for Outfall Option 2; and Scenario B4 over Scenario B1 for Outfall Option 3). The maximum values of all predicted changes over the simulation periods are presented in the table.

Seawater Intake

The mean and maximum temperature levels predicted under Scenario B3 and Scenario B4 at the seawater intake of T-Park (S1) for dry and wet season are shown in **Table 5-24** for comparison with its target design level.

Table 5-24 Predicted Temperature Levels at Seawater Intake of T-Park

Season	Temperature Level (°C)					
	Scenario B1 Baseline Scenario without I-PARK2		Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
	Mean	Maximum	Mean	Maximum	Mean	Maximum
Target Design Level	19.2 to 31					
Dry Season	13.9	16.1	14.2	17.0	14.1	17.8
Wet Season	31.5	34.3	31.9	34.3	31.8	34.3

The maximum temperature predicted at the intake of T-Park (S1) exceeded the target design value under all the modelling scenarios including the baseline scenario without the Project. The maximum temperature of 34.3 °C is observed in the wet season for all three scenarios. The intake operation at T-Park is not expected to be significantly affected by the Project.



No temperature criteria are available for the seawater intakes of BBPS and CPBS and therefore, these intakes are not further considered.

5.7.2.1.4 Salinity

The predicted absolute and percentage (%) changes of salinity levels induced by the brine discharge of this Project for dry and wet seasons are tabulated in **Table 5-25** and **Table 5-26**. The model outputs showing the mean salinity changes in dry and wet seasons are provided in **Appendix 5H-3**.

Table 5-25 Predicted Salinity Changes

Description	ID	Water Depth	Maximum Salinity Change (ppt)					
			Scenario B2 Impact Scenario with I-PARK2 – Outfall Option 1		Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
			Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season
WQO		N/A						
Water Sensitive Receivers								
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	<0.01	0.06	0.01	0.16	0.02	0.25
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2		<0.01	0.05	<0.01	0.08	0.01	0.06
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	0.03	0.04	0.02	0.05	0.02	0.04
Pak Nai SSSI	E4		<0.01	0.03	<0.01	0.08	0.01	0.06
Traditional Oyster Production Area	F1		<0.01	0.05	0.08	0.13	0.09	0.08
Mariculture Subzone	F2		0.05	0.13	0.12	0.21	0.08	0.19
Important Spawning Ground of Commercial Fisheries Resources	F3		0.01	0.03	0.01	0.05	0.01	0.04
Observation Points								
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	0.06	0.15	0.29	0.16	0.15	0.32
	O2		0.12	0.26	0.50	0.52	0.39	0.42
	O3		0.05	0.10	0.32	0.35	0.22	0.27

Note: Salinity change represents the change in salinity level caused by this Project (i.e. Scenario B4 over Scenario B1 for Outfall Option 1; Scenario B3 over Scenario B1 for Outfall Option 2; and Scenario B4 over Scenario B1 for Outfall Option 3). The maximum values of all predicted changes over the simulation periods are presented in the table.



Table 5-26 Predicted Percentage Salinity Changes

Description	ID	Water Depth	Maximum Salinity Change (%)					
			Scenario B2 Impact Scenario with I-PARK2 – Outfall Option 1		Scenario B3 Impact Scenario with I-PARK2 – Outfall Option 2		Scenario B4 Impact Scenario with I-PARK2 – Outfall Option 3	
			Dry Season	Wet Season	Dry Season	Wet Season	Dry Season	Wet Season
		WQO	±10%					
Water Sensitive Receivers								
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	<1%	<1%	<1%	1%	<1%	2%
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2		<1%	<1%	<1%	<1%	<1%	<1%
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	<1%	<1%	<1%	<1%	<1%	<1%
Pak Nai SSSI	E4		<1%	<1%	<1%	<1%	<1%	<1%
Traditional Oyster Production Area	F1		<1%	<1%	<1%	<1%	<1%	<1%
Mariculture Subzone	F2		<1%	<1%	<1%	1%	<1%	1%
Important Spawning Ground of Commercial Fisheries Resources	F3		<1%	<1%	<1%	<1%	<1%	<1%
Observation Points								
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	<1%	<1%	<1%	1%	<1%	2%
	O2		<1%	2%	2%	3%	1%	3%
	O3		<1%	<1%	1%	2%	<1%	2%

Note: Salinity change represents the change in salinity level caused by this Project (i.e. Scenario B4 over Scenario B1 for Outfall Option 1; Scenario B3 over Scenario B1 for Outfall Option 2; and Scenario B4 over Scenario B1 for Outfall Option 3), i.e. (salinity of Scenario B2/B3/B4 - salinity of Scenario B1)/ salinity of Scenario B1 * 100%. The maximum values of all predicted changes over the simulation periods are presented in the table.

Full WQO compliances are predicted at all ecological and fisheries sensitive receivers (E1 to E4, F1 to F3). The maximum % increases predicted at the WSRs are no more than 3%, which compiled well with the WQO of no more than 10%. The seawater intakes (S1, S2a, S2b and S3) are not sensitive to the changes of salinity and therefore not considered.

With reference to the contour maps given in **Appendix 5H-3**, average salinity change induced by this Project is below 10% in the areas close to the Project site. Based on the model prediction, the salinity impact of this Project is insignificant and acceptable.

5.7.2.1.5 Sodium Metabisulphite and Associated Oxygen Depletion

Where necessary, Sodium Metabisulphite (SMBS) may be dosed in the desalination and seawater cooling systems. As a measure to avoid damage to the membrane of the reverse osmosis (RO) unit of the desalination plant, SMBS would be dosed in the seawater pre-treatment units before reaching the RO unit for dechlorination. Optimization of the dosage of TRC and SMBS would also be considered in the detailed design of the desalination and seawater cooling system to minimize the discharge of TRC and residual SMBS. The TRC and



SMBS level in the discharges of these systems is expected to be minimal. For conservative reason, the assessment of Dissolved Oxygen (DO) depletion is based on an adverse assumption that the residual level of SMBS in the effluent discharges would be 0.5 mg/L³⁰.

Tracer simulations were performed by introducing an inert, non-settling tracer (with zero decay rate) in the refined HK-DFM Model to represent the continuous release of SMBS. The predicted SMBS concentrations at WSRs and observation points covering dry and wet seasons under Scenarios B2 to B4 are tabulated in **Table 5-27**. The contour plots of mean SMBS concentrations are shown in **Appendix 5H-4**. Taken into account the molecular mass of SMBS and oxygen, 1 mg/L of SMBS would react with 0.16832 mg/L of DO (assuming complete reaction). The resulted DO depletions at the relevant WSRs are shown in **Table 5-27**. The predicted DO depletion would be <0.01 mg/L. The potential DO impact due to any discharge of SMBS would be minor. No adverse marine water quality impact would be anticipated.

Table 5-27 Predicted SMBS Concentrations and DO Levels

Description	ID	Water Depth	Predicted Mean SMBS Levels (mg/L)						DO (mg/L)			
			Dry Season			Wet Season			WQO (10%ile)	Ambient Level (10%ile)	Predicted Depletion	Resulted Level
			Scenario B2	Scenario B3	Scenario B4	Scenario B2	Scenario B3	Scenario B4				
			(i)	(ii)	(iii)	(iv)	(v)	(vi)	(A)	(B)	(C)	(D)
Water Sensitive Receivers												
Mudflat / Seagrass / Horseshoe Crab at Ha Pak Nai	E1	Bottom	<0.0001	0.0097	0.0087	0.0001	0.0215	0.0194	NA	4.33	0.0036189	4.33
		Surface, Note 1	<0.0001	0.0095	0.0087	0.0001	0.0215	0.0194	≥ 5	4.73	0.0036189	4.73
Mudflat / Seagrass / Horseshoe Crab at Sheung Pak Nai	E2	Bottom	<0.0001	0.0058	0.0059	<0.0001	0.0113	0.0111	NA	4.33	0.001902	4.33
		Surface, Note 1	<0.0001	0.0058	0.0059	<0.0001	0.0113	0.0111	≥ 5	4.73	0.001902	4.73
Sha Chau and Lung Kwu Chau Marine Park	E3	Depth average	<0.0001	0.0043	0.0043	<0.0001	0.0032	0.0032	≥ 4	4.29	0.0007238	4.29
Pai Nai SSSI	E4	Depth average	<0.0001	0.0058	0.0059	<0.0001	0.0105	0.0103	NA	4.56	0.0017674	4.56
		Surface, Note 1	<0.0001	0.0058	0.0059	<0.0001	0.0105	0.0103	≥ 5	4.73	0.0017674	4.73
Traditional Oyster Production Area	F1	Depth average	<0.0001	0.0063	0.0064	<0.0001	0.0118	0.0113	NA	4.56	0.0019862	4.56
		Surface, Note 1	<0.0001	0.0063	0.0063	<0.0001	0.0118	0.0114	≥ 5	4.73	0.0019862	4.73
Mariculture Subzone	F2	Depth average	<0.0001	0.0135	0.0132	<0.0001	0.0152	0.0150	NA	4.56	0.0025585	4.56
		Surface, Note 1	<0.0001	0.0126	0.0120	<0.0001	0.0141	0.0139	≥ 5	4.73	0.0023733	4.73
Important Spawning Ground of Commercial Fisheries Resources	F3	Depth average	<0.0001	0.0042	0.0043	<0.0001	0.0036	0.0036	≥ 4	4.29	0.0007238	4.29

³⁰ EIA for Tseung Kwan O Desalination Plant (AEIAR-192/2015)



Description	ID	Water Depth	Predicted Mean SMBS Levels (mg/L)						DO (mg/L)			
			Dry Season			Wet Season			WQO (10%ile)	Ambient Level (10%ile)	Predicted Depletion	Resulted Level
			Scenario B2	Scenario B3	Scenario B4	Scenario B2	Scenario B3	Scenario B4				
			(i)	(ii)	(iii)	(iv)	(v)	(vi)	(A)	(B)	(C)	(D)
Observation Points												
Oyster Culture Activities Outside Mariculture Subzone	O1	Depth average	<0.0001	0.0181	0.0183	<0.0001	0.0138	0.0143	≥ 4	4.56	0.0030803	4.56
	O2	Depth average	0.0001	0.0351	0.0295	0.0001	0.0243	0.0225	≥ 4	4.47	0.005908	4.46
	O3	Depth average	0.0001	0.0334	0.0305	0.0001	0.0275	0.0258	≥ 4	4.56	0.0056219	4.55

Note:

- Five WSRs (E1, E2, E4, F1 and F2) are located within the Mariculture Subzone where the WQO for DO is only available for surface water layer. Predicted SMBS concentrations for surface layer are therefore included for these WSRs to provide information for the assessment of DO depletion at the surface water layer for comparison with the WQO for DO.
- The locations of WSRs are shown in **Figure 5.2** with corresponding ID.
- The ambient DO level is presented as 10%ile of the DO concentrations measured by EPD at the closest stations during the period from 2018 to 2022.
- The DO depletion at each WSR is calculated using the maximum SMBS value over Column (i) to Column (vi) in the table.
- The resulted DO level = Column (B) – Column (C).

5.7.2.2 Changes of Hydrodynamics and Water Quality

The predicted tidal flow rates across the Outer Deep Bay during both dry and wet seasons are compared between the baseline scenario without I-PARK2 (Scenario B1) and impact scenario with I-PARK2 (Scenarios B2, B3 and B4) in **Appendix 5I-1**. The model plots showed that there are no obvious changes in the instantaneous tidal flow rates across the Deep Bay between the two scenarios.

The simulated surface flow vectors and depth-averaged flow speeds in the assessment area are also compared between the scenarios in **Appendix 5I-2** and **Appendix 5I-3**. These plots show the instantaneous water movements at mid-ebb and mid-flood tides during both dry and wet seasons. No obvious changes of the predicted flow vectors and flow speeds in the assessment area are identified between the two simulated scenarios.

Since the predicted flow regime are similar before and after the I-PARK2 implementation, no significant changes in the pollutant dispersion capacity and water quality in the assessment area is expected.

The Project would not cause any adverse hydrodynamics and water quality impact.

5.7.2.3 Wastewater Generation – Option 1

Domestic sewage and process wastewater are described in **Section 5.5.2.4** above. Under Option 1, I-PARK2 would be designed for reuse of these wastewater streams for non-potable purposes. As illustrated in **Appendix 5B**, two on-site wastewater treatment systems are



tentatively proposed in I-PARK2, namely high strength wastewater treatment system and low strength wastewater treatment system respectively.

5.7.2.3.1 High Strength Wastewater Treatment System for Type 1 Wastewater

About 1,250 m³ of Type 1 wastewater would be generated from MSW handling facilities and laboratory each day. All Type 1 wastewater would be diverted to the on-site high strength wastewater treatment system for proper treatment. The tentative average dry weather flow (ADWF) of the on-site high strength wastewater treatment system would be about 1,500 m³/day. All the treated effluent from the high strength wastewater system would be reused in the waste treatment processes with no human contact. There would be no discharge of effluent from the high strength wastewater treatment system into the environment under Option 1. The effluent quality and treatment standards for reuse within the waste treatment process would be subject to the detailed design.

5.7.2.3.2 Low Strength Wastewater Treatment System for Type 2 Wastewater

About 80 m³ of domestic sewage and washed water from workshop (i.e. Type 2 wastewater) would be generated from the Project each day. All Type 2 wastewater would be diverted to the on-site low strength wastewater treatment system for proper treatment. The on-site low strength wastewater treatment system would have a tentative ADWF of about 100 m³/day. All treated effluent from the low strength wastewater treatment system would meet the WSD's "Water Quality Standards for Treated Grey Water and Rainwater Effluent" and would be reused on-site (with possible human contact) such as toilet flushing and road washing. The relevant water quality standards of the treated effluent are presented in **Table 5-10**. There would be no discharge of effluent from the low strength wastewater treatment system into the environment under Option 1.

5.7.2.3.3 Type 3 Wastewater

The remaining wastewater generated from the treatment processes (i.e. Type 3 wastewater) such as boiler blowdown water would have low or nil pollution level. The estimated quantity of Type 3 wastewater is 1,670 m³/day. It would be reused directly within the treatment processes and would not be discharged into the environment. No treatment of Type 3 wastewater is proposed under Option 1.

5.7.2.3.1 Potential Water Quality Impact

No discharge of Type 1, Type 2 and Type 3 wastewater into the environment is proposed. The generation of Type 1, Type 2 and Type 3 wastewater would not cause any water quality impact.

Suitable mitigation and design measures would be implemented for the on-site wastewater treatment system to prevent emergency discharge. Backup power supply in the form of dual power supply or ring main supply or emergency generator(s) as well as standby main



treatment units and standby equipment parts / accessories would be provided for the on-site wastewater treatment facilities including the high strength wastewater treatment system and low strength wastewater treatment system. Regular maintenance and checking of all on-site wastewater treatment facilities as well as conveying facilities would be carried out to prevent equipment and pipe failure. No submarine emergency discharge outfall is proposed under this Project. The future plant operators will develop an Emergency Response Plan (ERP) to deal with emergency scenario. An outline of the ERP is presented in **Section 5.8.2.2**.

Any effluent discharges from the I-PARK2 should be pre-treated to comply with the WPCO requirements, and sited away from the natural water streams. Provided that the good practices outlined in **Section 5.8.2.2** for handling, treatment and disposal of operational stage effluent are properly observed and followed, no adverse water quality impact would arise from the sewage / wastewater generation.

5.7.2.4 Wastewater Generation – Option 2

The major point source discharges at Urmston Road Submarine Outfall include the Upgraded San Wai Sewage Treatment Works (Upgraded SWSTW), commissioned in 2021 with design capacity of 200,000 m³/day and the proposed Hung Shui Kiu Effluent Polishing Plant (HSKEPP), anticipated to commence by 2031, according to the approved EIA for HSKEPP (AEIAR-240/2022, Scenario 2). I-PARK2 is expected to be commissioned in early 2030s. For this option, the proposed wastewater treatment plant of I-PARK2 will be equipped with at least secondary treatment plus nitrogen removal and disinfection to achieve a very high level of pollution load reduction (including at least 99% reduction of BOD₅, ammonia and *E.coli*, 98% reduction of COD and 96% reduction of TN, etc.) such that the treated effluent would be suitable for discharge to the North-western waters via a submarine outfall. The discharge of 3,000 m³/day of treated effluent from I-PARK2 will be made to the Urmston Road Submarine Outfall, constituting only about 1% of the total effluent discharge flow of 293,000 m³/day from the outfall. The Project effluent would be effectively diluted and further dispersed by the large volume of receiving water and strong tidal current in Urmston Road Fairway, with an initial dilution factor of 131 according to approved EIA for HSKEPP (AEIAR-240/2022). For discharge of the treated effluent, the I-PARK2 contractor shall obtain a discharge licence under the WPCO and comply with the corresponding effluent quality requirements with reference to the TM-DSS..

With secondary treatment plus nitrogen removal and disinfection, the concentration of BOD₅ and ammonia of the I-PARK2 treated effluent will be much less than the upgraded SWSTW (which adopts chemically enhanced primary treatment) and comparable to the HSKEPP. Although the COD and TN concentration is higher than the upgraded SWSTW, the total pollution loading for BOD₅, COD and TN for the Urmston Road Outfall would still be lower than the original SWSTW base case, as detailed in **Table 5-28**. According to the model



prediction in the approved EIA for HSKEPP (AEIAR-240/2022), the bottom and depth averaged DO level at the nearest water quality monitoring stations (i.e. NM5 and DM5) would remain largely unchanged as shown in **Table 5-29** despite an 11% reduction in both BOD₅ and COD loads from Scenario 1 to Scenario 2 as shown in **Table 5-28**. Given the total BOD₅ and COD loads in the current scenario are within the range of those assessed in the approved EIA for HSKEPP, it is expected that the treated effluent from I-PARK2 in the current scenario would not cause notable DO depletion in the receiving water.

Similar observation can be made for TIN. Despite a reduction of 8% in the TN load from Scenario 1 to Scenario 2 assessed in the approved EIA for HSKEPP (**Table 5-28**), the TIN concentration at NM5 and DM5 in the receiving water remain largely unchanged (**Table 5-29**). Hence, with the current scenario of 6% reduction in the TN load which is within the range of those assessed in the approved EIA for HSKEPP, it is expected that the treated effluent from I-PARK2 in the current scenario would not cause notable change in TIN in the receiving water. Provided that the I-PARK2 Contractor complies with the WPCO licence requirements, no adverse water quality impact arising from treated effluent discharge from I-PARK2 at Urmston Road Submarine Outfall is expected.

Table 5-28 Major Point Source Discharges at Urmston Road Submarine Outfall

		HSKEPP EIA Study ^a		Current Scenario (Upgraded SWSTW under Proposed Design + HSKEPP + I-PARK2) ^e
		Scenario 1 (Base Case - Upgraded SWSTW under Original Design)	Scenario 2 (Upgraded SWSTW + HSKEPP under Proposed Design)	
Flow (m³/d)	SWSTW	246,000	200,000	200,000
	HSKEPP	0	90,000	90,000
	I Park 2	0	0	3,000
	Total	246,000	290,000	293,000
Load (kg/d) ^b	BOD ₅	24,600	21,800 (-11%)	21,950 (-11%)
	COD ^c	49,200	43,600 (-11%)	46,000 (-7%)
	TN	8,315	7,660 (-8%)	7,810 (-6%)

Notes:

- Hung Shui Kiu Effluent Polishing Plant EIA Report (AEIAR-240/2022) [Ref. Table 5.13, https://www.epd.gov.hk/eia/register/report/eiareport/eia_2812022/EIA%20Report/S5_Water_Quality.htm#_Toc102731946]
- The percentage changes of the loads compared to Scenario 1 are shown in brackets.
- COD concentration of the effluent from SWSTW and HSKEPP is assumed to be 2 times the BOD₅ concentration with reference to Table 3-16 Typical composition of untreated domestic wastewater in Metcalf & Eddy (1991) Wastewater Engineering (Third Edition).
- Both BOD₅ and TN concentration of the effluent from I-PARK2 are made reference to the TM-DSS.
- The inclusion of the pollution load from treated effluent discharge from the WENT Landfill and its extension (also via Urmston Road Submarine Outfall) into the Study Scenario is found to be within the maximum total load assessed in the Base Case Scenario 1 of the approved EIA of HSKEPP with no notable change in DO and TIN in the receiving waters

**Table 5-29 Predicted Water Quality at EPD’s Routine Monitoring Stations near Urmston Road Submarine Outfall (extracted from HSKEPP EIA Study)**

Parameter [WQO] ^a	Monitoring Station	HSKEPP EIA Study ^b		
		Scenario 1 (Base Case)	Scenario 2 (Upgraded SWSTW + HSKEPP)	Change (Scenario 2 – Scenario 1)
10%-tile Bottom DO [≥ 2] (mg/L)	NM5	4.23	4.25	0.02
	DM5	4.31	4.31	0
10%-tile Depth-averaged DO [≥ 4] (mg/L)	NM5	4.45	4.45	0
	DM5	4.59	4.59	0
TIN [≤ 0.5] (mg/L)	NM5	0.69	0.69	0
	DM5	0.80	0.79	-0.01

Notes:

a. Annual data is used in the calculation.

b. Hung Shui Kiu Effluent Polishing Plant EIA Report (AEIAR-240/2022) [Ref. Appendix 5.7, https://www.epd.gov.hk/eia/register/report/eiareport/eia_2812022/EIA%20Report/S5_Water_Quality.htm#_Toc102731946]

5.7.2.5 Non-point Source Surface Runoff

Potential water quality impact may arise from contaminated surface runoff during operational phase. The footprint of the I-PARK2 site is approximately 20.1 hectares (201,000 m²). Most of the MSW reception and treatment processes, and MSW related contaminating sources / activities of the Project will be either fully enclosed or covered within buildings. Rainwater generated on building roof top would be uncontaminated and harvested for beneficial uses on-site. For those uncovered areas as discussed in **Section 5.5.2.5** including the MSW container handling area and MSW truck delivery route, the first flush of potentially contaminated surface runoff would be intercepted and conveyed to the on-site wastewater treatment system. The remaining open site areas in I-PARK2 of approximately 8.7 hectares (87,000 m²) would be connected to the storm drains and would be considered in the assessment of non-point source surface runoff.

It is considered that only rainfall events of sufficient intensity and volume would give rise to runoff. The rainfall data obtained from the Hong Kong Observatory in the period from 2019 to 2023 were analysed to estimate the runoff percentage and average daily runoff value (mm / day) in each month over the year. The storm catchment area within I-PARK2 site is expected to comprise both paved and landscaped surface areas. It is conservatively assumed that the entire storm catchment area would be impermeable with a runoff coefficient of 1.0. The monthly average daily runoff values (mm / day) are then applied to the storm catchment area to give the average daily volumes of non-point source surface runoff. The highest daily runoff volume generated from I-PARK2 would occur in June / September with a monthly average value of 1,239 m³/day. Details of the calculations are presented in **Appendix 5J**. It is anticipated that with proper implementation of best management practices as recommended



in **Section 5.8.2.3**, no adverse water quality impact from non-point source surface runoff is expected.

5.8 Mitigation Measures

5.8.1 Construction Phase

5.8.1.1 Construction Site Runoff and Dust Suppression Sprays

The site practices outlined in ProPECC PN 2/23 “Construction Site Drainage” should be followed where applicable to minimize surface runoff and the chance of erosion. Surface runoff including the spent effluent from dust suppression from construction sites should be discharged into storm drains via adequately designed sand/silt removal facilities such as sand traps, silt traps and sedimentation basins. Channels or earth bunds or sandbag barriers should be provided on site to properly direct stormwater to such silt removal facilities. Perimeter channels at site boundaries should be provided on site boundaries where necessary to intercept storm runoff from outside the site so that it will not wash across the site. Catchpits and perimeter channels should be constructed in advance of construction and earthworks.

Silt removal facilities, channels and manholes should be maintained and the deposited silt and grit should be removed regularly, at the onset of and after each rainstorm to prevent local flooding. Before disposal at the public fill reception facilities, the deposited silt and grit should be solicited in such a way that it can be contained and delivered by dump truck instead of tanker truck. Any practical options for the diversion and re-alignment of drainage should comply with both engineering and environmental requirements in order to provide adequate hydraulic capacity of all drains. Minimum distance of 100m should be maintained between the discharge points of construction site runoff and the nearby seawater intakes.

Construction works should be programmed to minimize soil/PFA excavation works in rainy seasons (April to September). If excavation in soil/PFA cannot be avoided in these months or at any time of year when rainstorms are likely, for the purpose of preventing soil/PFA erosion, temporary exposed slope surfaces should be covered e.g. by tarpaulin, and temporary access roads should be protected by crushed stone or gravel, as excavation proceeds. Intercepting channels should be provided (e.g. along the crest / edge of excavation) to prevent storm runoff from washing across exposed soil/PFA surfaces. Arrangements should always be in place in such a way that adequate surface protection measures can be safely carried out well before the arrival of a rainstorm.

Earthworks final surfaces should be well compacted and the subsequent permanent work or surface protection should be carried out immediately after the final surfaces are formed to



prevent erosion caused by rainstorms. Appropriate drainage like intercepting channels should be provided where necessary.

Measures should be taken to minimize the ingress of rainwater into trenches. If excavation of trenches in wet seasons is necessary, they should be dug and backfilled in short sections. Rainwater pumped out from trenches or foundation excavations should be discharged into storm drains via silt removal facilities.

Construction materials (e.g. aggregates, sand and fill material) on sites should be covered with tarpaulin or similar fabric during rainstorms. Measures should be taken to prevent the washing away of construction materials, soil, silt or debris into any drainage system or nearby water environment. The excavated PFA should be backfilled as soon as possible, and stockpiles of the excavated PFA shall be covered with tarpaulin or similar fabric during rainstorms.

Manholes (including newly constructed ones) should always be adequately covered and temporarily sealed so as to prevent silt, construction materials or debris from getting into the drainage system.

5.8.1.2 Wastewater from General Land-based Construction Activities

5.8.1.2.1 General

The mitigation measures as outlined in ProPECC PN 2/23 "Construction Site Drainage" for control of various types of discharges and wastewater generated in the construction site should be observed and adopted where applicable.

5.8.1.2.2 Boring and Drilling Water

Water used in ground boring and drilling for site investigation or rock / soil anchoring should as far as practicable be re-circulated and reused after sedimentation. When there is a need for final disposal, the wastewater should be discharged into storm drains via silt removal facilities. The treated discharges shall meet the respective effluent standards applicable to the receiving waters as set out in the TM-DSS.

5.8.1.2.3 Wheel Washing Water

All vehicles and plant should be cleaned before they leave a construction site to minimize the deposition of earth, mud, debris on roads. A wheel washing bay should be provided at every site exit. Wash-water should have sand and silt settled out or removed for re-circulation or reuse as far as practicable. Any surplus treated wash-water should be discharged into storm drains. The treated discharges shall meet the respective effluent standards applicable to the receiving waters as set out in the TM-DSS. The section of construction road between the wheel



washing bay and the public road should be paved with backfall to reduce vehicle tracking of soil and to prevent site runoff from entering public road drains.

5.8.1.3 General Refuse

It is recommended to clean the construction sites on a regular basis. Good site practices should be adopted to remove rubbish, debris and litter from construction sites so as to prevent the rubbish and litter from spreading from the site area. All general refuse generated on-site should be stored in enclosed bins or compaction units separately from C&D material. A reputable waste collector should be employed to remove general refuse from the site, separately from C&D material, on a regular basis to an approved landfill. An enclosed and covered area should be provided to reduce the occurrence of “windblown” light material.

5.8.1.4 Licensing of Construction Site Discharge

There is a need to apply to EPD for a discharge license for discharge of effluent from the construction site under the WPCO. All the runoff and wastewater generated from the works areas should be treated and the effluent discharge quality should meet the requirements specified in the discharge license and follow the TM-DSS. The beneficial uses of the treated effluent for other on-site activities such as dust suppression, wheel washing and general cleaning etc., can minimize water consumption and reduce the effluent discharge volume. If monitoring of the treated effluent quality from the works areas is required during the construction phase of the Project, the monitoring should be carried out in accordance with the relevant WPCO license.

5.8.1.5 Accidental Chemical Spillage

Contractor must register as a chemical waste producer if chemical wastes would be produced from the construction activities. The Waste Disposal Ordinance (Cap 354) and its subsidiary regulations in particular the Waste Disposal (Chemical Waste) (General) Regulation, should be observed and complied with for control of chemical wastes.

Any service shop and maintenance facilities should be located on hard standings within a bunded area, and sumps and oil interceptors should be provided. Maintenance of vehicles and equipment involving activities with potential for leakage and spillage should only be undertaken within the areas appropriately equipped to control these discharges.

Disposal of chemical wastes should be carried out in compliance with the Waste Disposal Ordinance. The Code of Practice on the Packaging, Labelling and Storage of Chemical Wastes published under the Waste Disposal Ordinance details the requirements to deal with chemical wastes. General requirements are given as follows:



- Suitable containers should be used to hold the chemical wastes to avoid leakage or spillage during storage, handling and transport.
- Chemical waste containers should be suitably labelled, to notify and warn the personnel who are handling the wastes, to avoid accidents.
- Storage area should be selected at a safe location on site and adequate space should be allocated to the storage area.

5.8.1.6 Sewage Effluent from Construction Workforce

It is recommended to provide sufficient chemical toilets in the works areas. A licensed waste collector should be deployed to maintain the chemical toilets on a regular basis.

Notices should be posted at conspicuous locations to remind the workers not to discharge any sewage or wastewater into the surrounding environment. Regular environmental audit of the construction site should be undertaken to provide an effective control of any malpractices and to encourage continual improvement of environmental performance on site.

5.8.1.7 Seawall Modification and Construction of Permanent Berthing Facility

The following design and mitigation measures should be adopted for the seawall modification and construction of the berthing facility.

- Adopt non-dredged method (i.e. DCM treatment) for construction of the foundation for the proposed seawall modification / berthing facility.
- Place sand blanket of at least 1 m thick on top of the sediments prior to DCM treatment to avoid seabed sediment disturbance and release of fines.
- Carefully control the cement slurry injection pressure to prevent leaching out of cement slurry during the DCM operation.
- Control the production rate of the marine sand blanket laying to no more than 3,000 m³ per day.
- Silt curtain shall be deployed during the marine sand blanket laying and DCM operation.
- No open dumping method should be used for the sand blanket laying in marine water.
- Adopt a "controlled bottom placement" method for the sand blanket laying work by releasing the sand material at a point near the seabed (by closed grab dredger or other appropriate method) and at a controlled sand filling rate to prevent localized overloading of the seabed and potential instability, and to minimize loss of fines when placing the sand blanket in marine water.



5.8.1.8 Good Site Practices for Construction Vessels

The following good site practices should be implemented to minimize water pollution from construction vessels and marine transportation of construction materials.

- Barges or hoppers shall not be filled to a level which will cause overflow of materials or pollution of water during loading or transportation.
- Excess materials shall be cleaned from the decks and exposed fittings of barges before the vessels are moved.
- Plants should not be operated with leaking pipes and any pipe leakages shall be repaired quickly.
- Adequate freeboard shall be maintained on barges to reduce the likelihood of decks being washed by wave action.
- All vessels should be sized so that adequate clearance is maintained between vessels and the seabed in all tide conditions, to ensure that undue turbidity is not generated by turbulence from vessel movement or propeller wash.
- The works shall not cause foam, oil, grease, litter or other objectionable matter to be present in the water within and adjacent to the works site.

5.8.2 Operational Phase

5.8.2.1 Discharges from Desalination Plant and Seawater Cooling System and Changes of Hydrodynamics and Water Quality

No adverse hydrodynamics and water quality impact is predicted from the discharges of desalination plant and seawater cooling system as well as due to the operation of the new berthing facility along the shore of Middle Ash Lagoon. All the discharges from desalination plant and seawater cooling system shall be controlled by the discharge licence issued under the WPCO. The discharge quality must meet the requirements specified in the discharge license. No mitigation measures are therefore required.

5.8.2.2 Control of Other Operational Site Effluents

The practices outlined in ProPECC PN 1/23 "Drainage Plan subject to Comments by Environmental Protection Department" should be adopted where applicable for handling, treatment and disposal of operational stage effluent. Specific site effluent control measures for I-PARK2 are highlighted as follows for consideration in the detailed design stage.

5.8.2.2.1 Wastewater Management Measures – Option 1

- Type 1 wastewater such as leachate with high organic loading should be discharged to the on-site high strength wastewater treatment facility for treatment and the treated effluent shall be reused on-site as process water with no human contact.



- Type 2 wastewater such as domestic sewage should be discharged to the on-site low strength wastewater treatment facility for treatment and the treated effluent shall meet the water quality standards specified in the “Technical Specifications on Grey Water Reuse and Rainwater Harvesting” issued by the WSD for beneficial reuse with possible human contact, such as irrigation, toilet flushing and washing (e.g. road washing).
- Type 3 wastewater with low / negligible pollution loading (e.g. boiler blowdown water) should be directly reused on-site as process water with no human contact.

5.8.2.2.2 Wastewater Management Measures – Option 2

Wastewater generated from I-PARK2 shall be discharged to the on-site wastewater treatment system for proper treatment prior to discharging to the Urmston Road Submarine Outfall. A discharge licence for discharge of effluent from I-PARK2 shall be applied under the WPCO. The quality of effluent discharged from I-PARK2 shall meet the requirements specified in the discharge licence. With reference to the requirements stipulated in Annex 6 of EIAO-TM for effluent discharge into the NW WCZ, secondary treatment plus nitrogen removal and disinfection shall be adopted for the on-site wastewater treatment system under the Option 2.

5.8.2.2.3 Site Effluent Control Measures for Option 1 and Option 2

- MSW / ash handling and treatment areas should be located within buildings or covered areas to prevent the generation of contaminated rainwater runoff.
- All wastewater (e.g. washing down from the waste reception facilities) collected by drainage outlets provided in covered areas should be discharged to the on-site wastewater treatment facility for treatment.
- Backup power supply in the form of dual power supply or ring main supply or emergency generator(s) should be provided for all on-site wastewater treatment facilities and rainwater reuse treatment system to secure electricity supply.
- Regular maintenance and checking of all on-site wastewater treatment facilities and rainwater reuse treatment system as well as conveying facilities should be carried out to prevent equipment and pipe failure.
- Standby main treatment units and standby equipment parts / accessories should be provided for all on-site wastewater treatment facilities and rainwater reuse treatment system to prevent the occurrence of plant failure.
- Any effluent discharges from the I-PARK2 should be pre-treated to comply with the WPCO requirements, and sited away from the natural water streams.
- The harvested roofing rainwater shall be collected and treated by the rainwater reuse treatment facilities provided on-site and the treated effluent shall meet the water quality standards specified in the “Technical Specifications on Grey Water Reuse and Rainwater Harvesting” issued by the WSD for beneficial reuse with possible human contact (e.g. irrigation, toilet flushing and washing).



An Emergency Response Plan (ERP) should be developed by the future operators of the on-site wastewater treatment systems to deal with emergency situations caused by malfunctioning of the on-site wastewater treatment systems. The ERP should cover the following information:

- Programme of daily or regular integrity checking of the on-site wastewater treatment and conveying systems to inspect malfunctions.
- Details of best management practices and maintenance programme of the on-site wastewater treatment and conveying systems.
- Details of design and operation of backup power supply as well as the duty and standby treatment facilities of suitable capacities for emergency replacement.
- Emergency response and rectification procedures to initiate emergency repairs, restore normal operation of the on-site wastewater treatment systems and other preventive measures such as the provision of temporary wastewater holding facility and / or alternative treatment facility where appropriate to avoid emergency discharge.
- List of contact information including the names and contact information of key personnel and their responsibilities in the ERP.

The ERP should be submitted to the EPD for approval before commencement of the operation.

5.8.2.3 Non-point Source Surface Runoff

Mitigation measures for non-point source surface runoff (as listed below) are recommended for the Project.

5.8.2.3.1 Design Measures

- Exposed surface shall be avoided within the proposed Project site to minimize soil erosion. Development site shall be either hard paved or covered by landscaping area where appropriate to reduce soil erosion.
- The drainage system of the Project should be designed to avoid any case of flooding.

5.8.2.3.2 Surface Runoff Control Measures

- Screening facilities such as standard gully grating and trash grille, with spacing which is capable of screening off large substances such as fallen leaves and rubbish should be provided at the inlet of drainage system.
- A low flow interceptor drainage system shall be deployed at uncovered paved areas within the Project site for handling / delivery of MSW containers and MSW delivery trucks to intercept and convey the first flush of any potentially contaminated surface runoff to the on-site wastewater treatment facility for treatment.
- Roofing rainwater would be harvested and treated for beneficial reuse with possible human contact (see **Section 5.8.2.2**).
- Surface runoff from uncovered paved and development areas within the Project site (except the first flush and roofing rainwater) should be discharged to stormwater drains after



removal of the particles by appropriate facilities (e.g. road gullies with standard design and silt traps,).

5.8.2.3.3 Administrative Measures

- Good management measures such as regular cleaning and sweeping of road surface / open areas is proposed. The road surface / open area cleaning should also be carried out prior to occurrence of rainstorm.
- Manholes, as well as storm water gullies, ditches provided among the development areas should be regularly inspected and cleaned (e.g. monthly). Additional inspection and cleansing should be carried out before forecast heavy rainfall.

5.9 Evaluation of Cumulative Impacts

According to Section 2, “West New Territories Landfill Extension” (WENTX) would be constructed and operated concurrently with the Project.

5.9.1 Construction Phase

5.9.1.1 Land-based Impact

The WENTX would construct / operate concurrently with the Project construction during 2026 to early 2030s. According to the approved EIA Report for WENTX (AEIAR-147/2009) and Supporting Document for Variation of Environmental Permit for the WENTX in 2022, potential water quality impact due to construction and operation of the WENTX would be minimized with proper implementation of the recommended mitigation measures and good site practices.

As no significant water quality impact was expected from the Project and WENTX during construction phase, no adverse cumulative water quality impact would be anticipated.

5.9.1.2 Marine-based Impact

The Modification of Tsang Kok Stream Outfall under the proposed WENT Landfill Extension would be commenced tentatively in 2024. The marine construction work under the proposed WENT Landfill Extension is anticipated to be substantially completed before the commencement of the marine construction work of I-PARK2. No cumulative water quality impact arising from marine construction work is therefore predicted.

5.9.2 Operational Phase

The WENTX would construct / operate concurrently with the Project operation. According to the approved EIA report (AEIAR-147/2009) and Supporting Document for Variation of Environmental Permit for the WENTX in 2022, with the implementation of suitable mitigation measures and good site practices, adverse water quality impact would not be expected from



the WENTX. Based on the findings of this EIA, with all the recommended mitigation measures in place, no significant water quality impact would be expected from the construction and operation of I-PARK2. Therefore, I-PARK2 would not cause adverse cumulative water quality impact with the WENTX project.

No discharge of treated or untreated process waters, domestic sewage and first flush into the Deep Bay is proposed under this Project. The only discharges to Deep Bay from the Project would be the brine from the proposed desalination plant and the spent effluent from the proposed seawater cooling system. The background seawater cooling effluent from BPPS and CPPS as well as the brine discharge from T-PARK has been estimated and included in the modelling exercise for cumulative impact assessment. The model predicted that the Project discharges would not contribute any adverse cumulative water quality impact. The Project effluent discharge at Urmston Road Submarine Outfall in NW WCZ under Option 2 has also been assessed in **Section 5.7.2.4** to cause no adverse cumulative water quality impact with other concurrent discharges.

With proper implementation of the recommended BMPs for stormwater discharge, any water quality impact arising from the non-point source surface runoff generated in the Project site would be highly localized or minimal and would not contribute any adverse cumulative water quality impact.

5.10 Residual Water Quality Impacts

With proper implementation of all the recommended mitigation measures, no residual water quality impact is expected in construction and operational phases.

5.11 Environmental Monitoring and Audit (EM&A) Requirements

5.11.1 Construction Phase

Marine water quality monitoring is recommended to be carried out at representative WSRs and observation points in Deep Bay WCZ during the sand blanket laying and DCM works. Site audit should also be conducted throughout the marine and land-based construction under this Project to ensure that the recommended mitigation measures are properly implemented.

Discharge license(s) should be obtained under the WPCO if there are any construction site discharges. Monitoring of the construction site effluent shall be carried out in accordance with



requirements stipulated in the WPCO discharge licenses.

Details of the environmental monitoring procedures and audit requirements are provided in the standalone EM&A manual.

5.11.2 Operational Phase

Marine water monitoring during the first year of Project operation is recommended to verify the impact predictions. The monitoring locations should include representative WSRs and observation points in Deep Bay WCZ. Details of the monitoring locations, frequency, procedures and audit requirements are provided in the EM&A Manual.

Discharge licenses should be obtained under the WPCO for the brine discharge from the proposed desalination plant and the spent effluent discharge from the proposed seawater cooling system. Regular monitoring of effluent quality may be specified in as a condition of the WPCO discharge license, and any necessary effluent monitoring programme should be implemented in accordance with the WPCO license requirements.

5.12 Conclusions

5.12.1 Construction Phase

5.12.1.1 Land-based Impact

The key sources of water quality impact arising during the land-based construction of the Project include the construction site runoff and drainage, wastewater generated from general construction activities, accidental spillage, general refuse and sewage from the workforce. The impacts could be mitigated and controlled by implementing the recommended mitigation measures. No adverse water quality impact is expected. Regular site inspections should be undertaken to inspect the construction activities and works area to ensure the recommended mitigation measures are properly implemented.

5.12.1.2 Marine-based Impact

Marine-based water quality impact would arise from the seawall modification / construction of new berthing facility for I-PARK2. Non-dredged DCM treatment method is proposed for construction of the foundation for the proposed seawall modification / berthing facility. The DCM method enables *in-situ* stabilisation of the underlying sediments without excavation, dredging, shoring or dewatering, and thus there is less exposure of wastes to the water environment. By placing the sand blanket layer on top of the DCM works areas before the DCM treatment, release of fines and cement slurry from the DCM operation is expected to be negligible.



The water quality impacts due to the sand blanket laying work have been quantitatively assessed by mathematical modelling. Suspended solid (SS) is identified as the parameter of concern. It is predicted that the SS elevations and sedimentation caused by the small-scale sand blanket laying works would be insignificant. Full water quality compliances are predicted at all representative WSRs under the unmitigated scenario. A water quality monitoring and audit programme will be implemented for the marine construction work.

5.12.2 Operational Phase

All process waters, domestic sewage and first flush of the surface runoff generated under the Project would be diverted to the on-site wastewater treatment systems for proper treatment and then reused within I-PARK2 or discharged into the existing Urmston Road Submarine Outfall in North Western Water Control Zone (NW WCZ). The potential water quality changes in NW WCZ due to the treated effluent discharge has been evaluated to be insignificant. Change of coastline configuration due to the proposed seawall modification / berthing facility as well as the brine and spent seawater cooling effluent discharges from the Project operation could affect the local hydrodynamics and water quality conditions. The potential change in hydrodynamics and water quality due to the I-PARK2 operation was assessed by means of mathematical modelling. The hydrodynamics regimes in the assessment area are predicted to be similar before and after the implementation of I-PARK2. The mixing zones of the proposed effluent discharges are predicted to be localized and would not encroach on any WSRs. Full water quality compliances for all concerned parameters are predicted. The Project operation would not cause any adverse hydrodynamics and water quality impact.